

# CITY OF PORTSMOUTH

Department of Public Works

## ADDENDUM #1

This Addendum modifies and is henceforth part of the CONTRACT DOCUMENTS AND SPECIFICATIONS for:

### **BID# 05-21 Spinnaker Fieldhouse Locker Rooms Renovation**

Bidders must acknowledge this Addendum within their bid proposal. Failure to do so may subject a bid to disqualification.

#### INVITATION TO BID

#### **Following second paragraph, Insert:**

Questions from bidders are to be submitted in writing to the purchasing website, <https://www.cityofportsmouth.com/finance/purchasing-bids-and-proposals>, until 4:30 p.m. Tuesday, August 11, 2020.

Answers will be provided as addenda on that website by 4:30 p.m. on Thursday, August 13, 2020

Work is expected to be substantially complete on November 1, 2020.

#### TECHNICAL SPECIFICATIONS

#### SECTION 224000 - PLUMBING FIXTURES

##### **Delete:**

##### 2.5 SHOWER VALVE

- B. Basis of design product: American Standard Colony Pro TU075508XH Trim with cartridge
- 5. One piece double ceramic pressure balance cartridge
- 6. Adjustable hot limit

##### **Replace with:**

##### 2.5 SHOWER VALVE

- A. Replace with compatible new Symmons cartridge with adjustable hot limit
- B. Replace trim with compatible C-96-1X or approved equal.