



City of Portsmouth Department of Public Works
680 Peverly Hill Road
Portsmouth, New Hampshire 03801

ADDENDUM NUMBER 2

Bid #11-19

**Hanover Street Area Roadway Improvements
McDonough Phase 4**

Issued August 20, 2018

This addendum forms part of the original document marked “**Contract Documents and Specifications for Hanover Street Area Roadway Improvements Bid #11-19**”.

Question #1 – Please confirm that per Note #5 on Sheet C-401 “Contractor shall provide sweeps and risers at utility poles and at buildings for final connections, provide weathertight caps.” the following items are to be completed ‘by others’:

- A. Installation of new meter bank and related equipment to allow power service to be transferred underground at buildings.
- B. Reconfiguration of service into existing buildings to accommodate new/relocated underground service.

Answer #1 – This is correct. Scope of work only includes installation of conduit and risers with weathertight caps. Future use of these conduits, wires, connections, etc. Are “by others”.

All else remains unchanged.

Acknowledge this addendum within your proposal. Failure to do so may subject bidder to disqualification.

End of Addendum #2