March 14, 2011 ADDENDUM #3 City of Portsmouth Portsmouth, New Hampshire Public Works Department

Atlantic Heights Streetscape Improvements Concord Way & Porpoise Way

Bid # 25-11

This addendum forms part of the original document marked: Bid #25-11 Atlantic Heights Streetscape Improvements Concord Way & Porpoise Way.

Replace pages numbered 78 and 79 of the original bid document with the attached pages numbered 78 and 79.

The following change was made to page 78:

In the second paragraph, the following sentence was changed to read:

Fences shall be moved or reset in the areas designated below:

And the following was added to page 79:

Fences shall be moved or reset at the following locations: Sheet 7 STA 20+65 LT - 15'

Sheet 8 STA 26+30 RT – 12'

Sheet 9 STA 50+75 LT – 37' STA 53+00 LT - 8' STA 55+35 RT - 15'

Sheet 11 STA 63+30 RT – 35'

Please acknowledge this addendum within your proposal. Failure to do so <u>may</u> cause a bidder to be disqualified.

End of addendum #3

SECTION 607 <u>FENCES</u>

The provisions of Section 607 of the "State of New Hampshire, Department of Transportation, Standard Specifications for Road and Bridge Construction, 2010 Edition" shall apply with the following additions and modifications:

Fences shall be moved or reset in the areas designated below. 72-hour notification to the property resident is required prior to the removal and resetting of any fence. Because the fence serves as a containment area for pets in most instances, **all fences are required to be re-installed within 24 hours of the removal of the existing fabric.**

New rails, fabric, posts and hardware are to be included in each of the locations for chain link fencing. All other fence shall reuse existing materials. All items included in this section shall include all materials, hardware, labor, equipment, specialty equipment and other necessary items to complete the installation of new or existing fences and related items.

Measurement shall be measured by the linear foot of fencing on a continuous line from the existing connecting post to the end of the installation including all pedestrian and driveway gates.

All posts on Item 607.901 and 607.903 shall use 3000 psi concrete to backfill fill each hole. Holes shall be dug or augured to a 3.5' depth, post set and backfilled with 3000 psi concrete to within 8" of existing surface area. Loam shall be placed on top of the posts once the concrete has cured as part of the project clean-up process.

Fences shall be moved or reset at the following locations:

Sheet 7 STA 20+65 LT - 15' Sheet 8 STA 26+30 RT - 12' Sheet 9 STA 50+75 LT - 37' STA 53+00 LT - 8' STA 55+35 RT - 15'

Sheet 11 STA 63+30 RT – 35' Sliding Gate

Chain link style cantilever slide gate shall meet the following requirements at a minimum:

Gate frames shall consist of 2-1/2" O.D. horizontal rails, 2" O.D. vertical bracing, and 1-5/8" diagonal bracing; Shall be welded and galvanized.

Galvanized chain link mesh shall be 9 gauge 2" mesh (1.2 oz. zinc galvanized after weaving). Cantilever

The bottom of the gate shall be a maximum of 4" above the driveway pavement.

Slide Gate shall include all hardware to make the gate operate properly which at a minima should included the following or an approved equivalent:

- 1 5' High x 10' Wide Opening Galvanized Chain Link Cantilever Slide Gate
- 2 4" O.D. x 9' Galvanized SS40 Gate Roller Posts
- 1 3" O.D. x 9' Galvanized SS40 Gate Latch Post
- 2 4" Aluminum Post Caps
- 1 3" Aluminum Post Cap
- 4 4" x 2-1/2" Premium Stealth Nylon Cantilever Rollers
- 2 Custom Polyethylene Top Fit Safety Protective Roller Covers
- 2 Custom Polyethylene Bottom Fit Safety Protective Roller Covers
- 1 Galvanized Slide Gate Mac Latch Fits 3" Latch Post

Payment will be made under:

<u>Pay Item</u>		<u>Pay Unit</u>
607.001	Resetting Fences	Linear Foot
607.002	Sliding Gate – Concord STA 55+50L	Lump Sum
607.35	5' High Chain Link Fence Black Vinyl Coated Steel Fabric	Linear Foot