

Longmeadow Road Extension

Bid number 28-21

Addendum #1

OCTOBER 12, 2021

Questions/Answers

Q1. Is the granular backfill item to be used as per typical detail on C-502?

A1. Granular backfill is to be used as shown in typical pavement and gravel sections and typical road cross sections on sheet C-502.

Q2. Where is the reclaimed base item to be used?

A2. Reclaimed base item shall be used with existing paved areas that are to be rebuilt which include the existing Longmeadow Road cul-de-sac and the sections of Lang Road where the new roadway alignment ties into the existing road.

Q3. Curb is labeled on the plan and bid sheets as straight granite curb. There is a typical that also shows vertical granite curb. Is there any vertical?

A3. There is no vertical granite curb to be constructed as part of this project.

Q4. What are the limits of the cold planing?

A4. The limits of cold planing are shown on sheet C-103 as the light hatched area on Longmeadow Road called out as "pavement to be resurfaced".

Q5. Where is the 10 SY of 6" concrete sidewalk? Is this the raised island?

A5. The 6" concrete sidewalk is the raised island on Lang Road.

Q6. It appears that Item 632.02 is in there twice by mistake. Both have the same quantity.

A6. The bid form has been revised to show all pavement symbols and words shall be 632.32. Item 632.02 has been removed from the bid form.

Q7. The grades of the existing profile do not match. Which is correct?

A7. Profiles on Sheets C-106, C-107 & C-108 have been revised to correctly label the existing and proposed elevations.

Additional Revisions:

- Bid Item 604.72 has been added to the Bid Form.
 - Bid Item 615.0201 has been revised to be Item 615.01201 Traffic Signs, Type A.
 - Route sign configurations on sheet C-103 and C-201 have been revised.
 - Curbed island has been revised to avoid conflicting with an existing sewer manhole cover.
-

The plan set has been revised. The revised plan set is dated October 4, 2021.

The Bid form has been revised. The correct bid form is attached. Please disregard the original bid form.

End of Addendum 1.

PROPOSAL FORM

**Longmeadow Road Extension Project
Bid #28-21**

CITY OF PORTSMOUTH, N.H.

To the City of Portsmouth, New Hampshire, herein called the Owner.

The undersigned, as Bidder, herein referred to as singular and masculine declares as follows:

1. All interested in the Bid as Principals are named herein.
2. This bid is not made jointly, or in conjunction, cooperation or collusion with any other person, firm, corporation, or other legal entity;
3. No officer, agent or employee of the Owner is directly or indirectly interested in this Bid.
4. The bidder has carefully examined the sites of the proposed work and fully informed and satisfied himself as to the conditions there existing, the character and requirements of the proposed work, the difficulties attendant upon its execution and the accuracy of all estimated quantities stated in this Bid, and the bidder has carefully read and examined the Drawings, Agreement, Specifications and other Contract Documents therein referred to and knows and understands the terms and provisions thereof;
5. The bidder understands that the quantities of work calculated in the Bid or indicated on the Drawings or in the Specifications or other Contract Documents are approximate and are subject to increase or decrease or deletion as deemed necessary by the Director of Public Works. Any such changes will not result in or be justification for any penalty or increase in contract prices; and agrees that, if the Bid is accepted the bidder will contract with the Owner, as provided in the Contract Documents, this Bid Form being part of said Contract Documents, and that the bidder will supply or perform all labor, services, plant, machinery, apparatus, appliances, tools, supplies and all other activities required by the Contract Documents in the manner and within the time therein set forth, and that the bidder will take in full payment therefore the following item prices, to wit:

ITEM #	EST. QTY	UNITS	ITEM DESCRIPTION AND UNIT PRICE IN WORDS	UNIT PRICE IN FIGURES	ITEM TOTAL IN FIGURES
TR	50	Ton	Trash and junkyard debris removal (F)	\$ _____	\$ _____
201.01	0.95	AC	Clearing and Grubbing	\$ _____	\$ _____
201.881	650	SY	Invasive Species Control Type 1	\$ _____	\$ _____

ITEM #	EST. QTY	UNITS	ITEM DESCRIPTION AND UNIT PRICE IN WORDS	UNIT PRICE IN FIGURES	ITEM TOTAL IN FIGURES
203.1	4,630	CY	Common Excavation	\$ _____	\$ _____
203.2	1,250	CY	Rock Excavation	\$ _____	\$ _____
209.1	1,381	CY	Granular Backfill	\$ _____	\$ _____
214	1	EA	Fine Grading	\$ _____	\$ _____
304.4	4,065	CY	Crushed Stone (Fine Gradation) (F)	\$ _____	\$ _____
306.112	1,800	SY	Reclaimed Stabilized Base, Processed in Place, 12" Deep (F)	\$ _____	\$ _____
306.36	150	Ton	Stone for Reclaimed Stabilized Base	\$ _____	\$ _____
403.11	2,400	Ton	Hot Bituminous Pavement, Machine Method	\$ _____	\$ _____
403.12	15	Ton	Hot Bituminous Pavement, Hand Method	\$ _____	\$ _____
417	1,788	SY	Cold Planing Bituminous Surfaces	\$ _____	\$ _____

ITEM #	EST. QTY	UNITS	ITEM DESCRIPTION AND UNIT PRICE IN WORDS	UNIT PRICE IN FIGURES	ITEM TOTAL IN FIGURES
603.33212	1	EA	12" HDPE Flared End Section	\$ _____	\$ _____
<hr/>					
603.82212	238	LF	12" HDPE	\$ _____	\$ _____
<hr/>					
604.0007	4	EA	Polyethylene Liner	\$ _____	\$ _____
<hr/>					
604.124	6	EA	Catch Basin (4' Dia.)	\$ _____	\$ _____
<hr/>					
604.242	1	EA	Drop Inlets Type D-B	\$ _____	\$ _____
<hr/>					
604.325	1	EA	Drainage Manhole (5' Dia.)	\$ _____	\$ _____
<hr/>					
604.62	2	EA	Drainage Manhole Cover & Frame	\$ _____	\$ _____
<hr/>					
604.72	7	EA	Grate & Frame Type B	\$ _____	\$ _____
<hr/>					
604.74	1	EA	Grates & Frames, Special High Capacity Grate	\$ _____	\$ _____
<hr/>					
604.9102	1	U	Outlet Control Structure	\$ _____	\$ _____
<hr/>					

ITEM #	EST. QTY	UNITS	ITEM DESCRIPTION AND UNIT PRICE IN WORDS	UNIT PRICE IN FIGURES	ITEM TOTAL IN FIGURES
605.506	1,300	LF	6" Perforated Corrugated Polyethylene Pipe Underdrain	\$ _____	\$ _____
607.38	470	LF	Chain link Fence with Vinyl Coated Steel Fabric, 8' High	\$ _____	\$ _____
607.7382	1	U	Double Gate Chainlink Fence with Vinyl Coated Steel Fabric, 8' High, 20' Wide	\$ _____	\$ _____
608.26	10	SY	6" Concrete Sidewalk (F)	\$ _____	\$ _____
609.01	1,240	LF	Straight Granite Curb	\$ _____	\$ _____
611.811	1	EA	Adjust/Relocate Hydrant	\$ _____	\$ _____
614.523	1	EA	Molded Pull Box for Lighting, 17 by 30"	\$ _____	\$ _____
614.73114	800	LF	3" PVC Conduit, Schedule 40	\$ _____	\$ _____
614.73118	120	LF	3" PVC Conduit, Schedule 80	\$ _____	\$ _____
615.01201	32	SF	Traffic Signs, Type A	\$ _____	\$ _____

ITEM #	EST. QTY	UNITS	ITEM DESCRIPTION AND UNIT PRICE IN WORDS	UNIT PRICE IN FIGURES	ITEM TOTAL IN FIGURES
615.0301	197	SF	Traffic Signs, Type C	\$ _____	\$ _____
615.0601	36	SF	Traffic Signs, Type CC	\$ _____	\$ _____
616.606	1	EA	Traffic Signal Detector Loop 6ft x 6ft	\$ _____	\$ _____
618.61	1	Allow	Uniformed Officers with Vehicle	<u>\$16,000.00</u>	<u>\$16,000.00</u>
618.7	1	HR	Flaggers	<u>\$36,000.00</u>	<u>\$36,000.00</u>
619.1	1	U	Maintenance of Traffic	\$ _____	\$ _____
625.2	2	EA	Concrete Light Pole Bases, Type B	\$ _____	\$ _____
625.52	2	U	Light Pole	\$ _____	\$ _____
628.2	140	LF	Sawed Bituminous Pavement	\$ _____	\$ _____
632.0104	4,100	LF	Retroreflective Paint Pavement Marking, 4" Line (Double Yellow)	\$ _____	\$ _____

ITEM #	EST. QTY	UNITS	ITEM DESCRIPTION AND UNIT PRICE IN WORDS	UNIT PRICE IN FIGURES	ITEM TOTAL IN FIGURES
632.0104	8,700	LF	Retroreflective Paint Pavement Marking, 4" Line (Single White)	\$_____	\$_____
632.3118	100	LF	Retroreflective Thermoplastic Pavement Marking, 18" Line	\$_____	\$_____
632.32	120	SF	Retroreflective Thermoplastic Pavement Marking, Symbol or Word	\$_____	\$_____
641	1,850	CY	Loam	\$_____	\$_____
643.21	1,760	LB	Fertilizer for Re-fertilization	\$_____	\$_____
644.82	100	LB	Salt Tolerant Grass Seed, Type 82	\$_____	\$_____
645.512	2,250	LF	Compost Sock for Perimeter Berm	\$_____	\$_____
650.2	1	Allow	Landscaping	<u>\$2,000.00</u>	<u>\$2,000.00</u>
692	1	EA	Mobilization	\$_____	\$_____

TOTAL FOR PROJECT AND BASIS OF AWARD

In Figures \$ _____

In Words \$ _____

To Bidder:

The City reserves the right, after bid opening and prior to award of the contract, to modify the amount of the work in the event that bids exceed budgeted amounts and/or easements and agreements from one or more impacted property owners are not received.

It is the intention of this contract that the items listed above describe completely and thoroughly the entirety of the work as shown on the plans and as described in the specifications. All other items required to accomplish the above items are considered to be subsidiary work, unless shown as a pay item.

The undersigned agrees that for extra work, if any, performed in accordance with the terms and provisions of the Contract Documents, the bidder will accept compensation as stipulated therein.

Date:

Company

By: _____
Signature

Business Address

Title: _____

City, State, Zip Code

Telephone: _____

All Bids are to be submitted on this form and in a sealed envelope, plainly marked on the outside with the Bidder's name and address and the Project name as it appears at the top of the Proposal Form.

We certify that the Company is currently pre-qualified with the State of New Hampshire for Road Construction.

By: _____
Signature & Title

Date