

Feb. 14, 2014
Addendum #4

Bid #33-14 High/Hanover Parking Facility Emergency Generator Replacement

This Addendum forms part of the original document marked: Bid#33-14 High/Hanover Parking Facility Emergency Generator Replacement.

The answer to Question 4 of Addendum 1 has been changed, deleting bullet that reads "1-20' double gate".

4: Q: Will a 6' high galvanized chain link fence around the generator with approx. 3' of clearance all around with (1) 3' gate be acceptable?

A: Yes. Specifications for the fencing and supports:

- 6' black Permafuse 9 gauge wire fabric
- 3" SS-40 galvanized terminal posts and corner posts, set in concrete
- 2-1/2" SS-40 galvanized line post, driven
- 1-5/8" SS-40 galvanized top rail, corner and end brace
- 9 gauge bottom tension wire
- 6 gauge aluminum tie wire
- All fence fittings to be galvanized steel

All else remains unchanged from the original bid document.

Please acknowledge receipt of this addendum within your bid proposal. Failure to do so may subject a bidder to disqualification.

End of Addendum #4