

# **ADDENDUM NUMBER 1:**

## **CITY OF PORTSMOUTH, NEW HAMPSHIRE MULTI-PURPOSE RECREATION FIELDS & REGIONAL STORMWATER TREATMENT SYSTEM PROJECT**

### **CONTRACT DOCUMENTS AND TECHNICAL SPECIFICATIONS**

**Issued: April 30, 2020  
For Bids Due: May 19, 2020**

This addendum modifies, amends, and supplements parts of the Contract Documents, Technical Specifications, and Construction Drawings for the **City of Portsmouth, NH Multi-Purpose Recreation Fields & Regional Stormwater Treatment System Project**, and is hereby made an integral part thereof by reference and shall be as binding as though inserted in its entirety in the locations specified herein. The Contractor shall notify their subcontractors and suppliers of any changes or modifications contained in this addendum.

Bidders shall acknowledge receipt of this **Addendum No. 1** on the Bid Form.

Bidders are hereby notified that no changes have been made to the bid due date and time. Bids are still due on **May 19, 2020 at 2:00 p.m.**

The Contract Documents, Technical Specifications, and Construction Drawings for the subject project shall be supplemented and/or amended as follows:

#### **A. GENERAL**

1. Select Auto CAD files will be sent to Contractors upon request. To request the files, please email: [pcorbett@cmaengineers.com](mailto:pcorbett@cmaengineers.com). The Owner and Engineer do not warrant the accuracy of electronic files. The project bid and construction are subject to the information in the construction plans.
2. Prior to June 1, 2020, the Owner will cut all trees greater than 3-inches DBH within the project area required to complete the work. The Contractor is responsible for all other clearing, grubbing, and site preparation of the site, including stump removal of trees cut by Owner.

#### **3. BIDDING DOCUMENTS**

##### **1. Bid Proposal**

Clarifications and revisions to the bid items are listed below.

- a. Bid Alternate E (Alternative Infill – Envirofill with Shock Pad) and Alternate F (Alternative Infill – Safesheet with Shock Pad) in the bid form shall be the lump sum to substitute an alternative infill for one field.

4. TECHNICAL SPECIFICATIONS

1. Section 01025 – Measurement and Payment

- a. **BID ALTERNATE E & F – Alternative Infills – Envirofill with Shock Pad & Safeshell with Shock Pad: Section B.1.** shall be revised to read: “1. Alternative Infills shall be paid for at the Contract lump sum price for installation of an alternative infill **in one field.**”

2. Section 02229 – Backfill and Compaction

- a. **Part 2, Section 2.1.B Common Borrow (Embankment in Place)** – The following text shall be added to this section:
5. Common Borrow placed deeper than 4-feet below finished grade may contain stones up to 18” in diameter (average) but must be well mixed with smaller particle soil to minimize voids.
  6. Crushed and recycled concrete and asphalt shall not be used as Common Borrow.

Please acknowledge this Addendum within your proposal; failure to do so may disqualify the Bidder.

END OF ADDENDUM NO. 1