

April 8, 2010
ADDENDUM #2
FOR
City of Portsmouth
Portsmouth, New Hampshire
Bid #42-10
South at Lafayette Intersection Improvements

This Addendum forms part of the original document marked: Bid #42-10 South at Lafayette Intersection Improvements

The following questions have been asked and answered.

Question 1: How are the luminaries to be mounted to the top of the mast arms/poles?

Response – The luminaries shall be tenon mounted utilizing a normal mast pole height.

Question 2: Will you take the Polara Navigator as an equal?

Response - Yes in black

Question 3: Do you want a custom voice message?

Response - No

Question 4: What quantity of buttons do you require?

Response - 4 (one on each corner)

Question 5: Do you want an Intersection graphic on the computer?

Response - yes

Question 6: Why do you need 8 push buttons, when the pedestrian phase is exclusive?

Response - 4 will be required for this project (1 for each corner)

Please acknowledge this addendum within your proposal. Failure to do so may cause a bidder to be disqualified.

End of addendum #2