

May 29, 2014

ADDENDUM NUMBER #1:
Anti-Bird Netting
RFP #42-14

This Addendum forms part of the original document marked: "RFP #42-14 Anti-Bird Netting".

Answers to Questions submitted:

- a. **Question:** Your specification for the netting strand thickness (30-50 mils) size seems to be an overdesign. Did you use a debris netting specification?
Answer: Yes, we did. Disregard the specification for fabric thickness as written in the RFP. Use netting strand thickness that meets the specified breaking strength. Mesh openings are to be no larger than $\frac{3}{4}$ inch.

- b. **Question:** How do we address the 42-foot long pipe that is 3-4 feet below the ceiling in the area of concern?
Answer: The goal of the project is to deny resting/living space for birds in the area above the parking in the garage addition. This pipe serves as resting space for birds, and should therefore be denied to birds at the end of the project. Proposers are free to propose any solution (nets, spikes, cables, etc) that will be effective in keeping birds off this pipe.

- c. **Question:** How much cleaning of bird debris is required?
Answer: As set forth in the specification, the selected vendor must clean bird debris/droppings from the locations of hardware attachment to the garage. No live birds or bird eggs should be left behind the netting at the end of the project.

The pre-bid meeting attendance sign-in sheet is attached and becomes part of this addendum.

All else remains unchanged.

Please acknowledge this addendum within your proposal, failure to do so may subject a proposer to disqualification.

End of Addendum #1

Garage Anti-Bird Netting Pre-Bid Meeting - 5/22/2014

Sign-In Sheet

NAME	FIRM	PHONE	EMAIL
Al Bliss	Flynn Pest Control	508-252-9881	alan@flynnpestcontrol.com
Sean Smith	Ehrlich Bird Control	923 896 8986	Sean.smith@Jehlich.com
Jesse Fouser	Critter Control NH	603-431-7452	NH@CritterControl.com
Jerred Rowels	Ter One Construction	603-497-7522	Jerred@TeroneNH.com
Bud Lyttel	Bird Pest Control	800-272-3661	Budlyttel@BirdPestControl.com
Rich Spredbury	Atlantic Power Cleaning	617-908-1330	info@AtlanticPowercleaning.com
Colton Tlumac	Modern Pest	203-577-0860	ctlumac@modernpest.com
John Fack	Birdmaster	800 562 2473	jjpace@birdmaster.com