

**Table 1
Summary of PFC Analytical Results
Public Water Supply Monitoring Program
Former Pease Air Force Base, New Hampshire**

Well Type	Sample Location	Sample ID	Collection Date	6:2 Fluorotelomer sulfonate (6:2 FTS)	8:2 Fluorotelomer sulfonate (8:2 FTS)	N-Ethyl perfluorooctane sulfonamide (EtFOOSA)	N-Ethyl perfluorooctane sulfonamidoethanol (EtFOSE)	N-Methyl Perfluorooctane Sulfonamide (MEFOOSA)	N-Methyl Perfluorooctane Sulfonamidoethanol (MEFOSE)	Perfluorobutanesulfonic acid (PFBS)	Perfluorobutanoic acid (PFBA)	Perfluorodecane sulfonate (PFDS)	Perfluorodecanoic acid (PFDA)	Perfluorododecanoic acid (PFDoA)	Perfluoroheptane sulfonate (PFHpS)	Perfluoroheptanoic acid (PFHpA)	Perfluorohexanesulfonic acid (PFHxS)	Perfluorohexanoic acid (PFHxA)	Perfluorononanoic acid (PFNA)	Perfluorooctane sulfonamide (FOOSA)	Perfluorooctanesulfonic acid (PFOS)	Perfluorooctanoic acid (PFOA)	Perfluoropentanoic acid (PFPeA)	Perfluorotetradecanoic acid (PFTeDA)	Perfluorotridecanoic acid (PFTrDA)	Perfluoroundecanoic acid (PFUnA)	PFOA+PFOS	
USEPA Health Advisory (HA):				-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0.070	0.070	-	-	-	-	0.070
	DES-OFC-GW_20160526	5/26/16	ND	ND	NA	NA	NA	NA	NA	0.005 J	0.008 J	NA	NA	NA	ND	ND	0.013 J	ND	ND	ND	0.012 J	0.006 J	0.006 J	NA	NA	NA	0.018	
	FIRESTATION3-GW_20160526	5/26/16	ND	ND	NA	NA	NA	NA	NA	0.005 J	0.007 J	NA	NA	NA	ND	ND	0.012 J	ND	ND	ND	0.012 J	0.006 J	0.004 J	NA	NA	NA	0.018	
	HARRISON-GW_20160526	5/26/16	ND	ND	NA	NA	NA	NA	NA	0.005 J	0.009 J	NA	NA	NA	0.005 J	0.005 J	0.024	0.007 J	ND	ND	0.023	0.007 J	0.008 J	NA	NA	NA	0.030	
	SMITH-GW_20160531	5/31/16	ND	ND	NA	NA	NA	NA	NA	0.006 J	ND	NA	NA	NA	ND	ND	0.013 J	0.006 J	ND	ND	0.011 J	0.005 J	0.004 J	NA	NA	NA	0.016	
	COLLINS-04122016	4/12/16	ND	ND	NA	NA	NA	NA	NA	ND	ND	NA	NA	NA	ND	ND	0.006 B	0.007 B	ND	ND	0.006 B	ND	ND	NA	NA	NA	0.006	
	PORTSMOUTH-GW_20160526	5/26/16	ND	ND	NA	NA	NA	NA	NA	0.006 J	0.008 J	NA	NA	NA	ND	ND	0.007 J	ND	ND	ND	0.007 J	0.007 J	0.005 J	NA	NA	NA	0.014	

Notes:

Grey text indicates the parameter was not analyzed or not detected.
 All concentrations in µg/L - micrograms per liter
 All values in micrograms per liter
 D - duplicate sample
 J - The result is an estimated value.
 B - Detected in Blank.
 Q - The analyte is both B qualified because of blank detection and J qualified because of an additional QC issue.

USEPA - Environmental Protection Agency
 NA - Not Analyzed or Not Applicable
 µg/L - micrograms per liter
 ND - Not detected
 HA - Health Advisory screening value (EPA 2016)
 — - No HA available