

Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists



May 25, 2022

Rick Chellman, Chair City of Portsmouth Planning Board 1 Junkins Ave, 3<sup>rd</sup> Floor Portsmouth, NH 03801

#### RE: Planning Board Subdivision & Site Plan Review Applications Proposed 3-Lot Subdivision, 437 Lafayette Road, Portsmouth, Tax Map 229, Lot 1

Dear Mr. Chellman:

On behalf of the Applicant, Artwill, LLC, TFMoran, Inc. is submitting the following plans and supporting documents for the above-referenced project. Hard copies of the following materials have been delivered to the City Planning Department and digital copies have been uploaded to the City's online Land Use Application (LU-22-82) via Viewpoint:

- Letter of Authorization (1 copy)
- Site Plan Application Checklist (1 copy)
- Subdivision Application Checklist (1 copy)
- TAC Notice of Decision Letters (1 copy)
- Abutters List (1 copy) & Abutters Address Labels (3 set of labels)
- Eversource Will Serve Letter (1 copy)
- Unitil Will Serve Letter (1 copy)
- Road Maintenance Agreement (1 copy)
- Drainage Report dated April 19, 2022 (1 copy)
- Plans titled "Site Development Plans, Tax Map 229 Lot 1, Proposed 3 Lot Subdivision, 437 Lafayette Road, Portsmouth, New Hampshire", prepared by TFMoran, Inc., dated April 19, 2022, last revised May 25, 2022 (1 copy 22"x34")
- Architectural Drawings, prepared by Smithfield Construction, Inc. (1 copy)
- NHDES Sewer Connection Permit Application (1 copy)

#### Project Description

This proposal is for the subdivision of a single lot into three proposed lots, and the construction of two single-family dwelling units and an attached accessory dwelling unit. Other improvements associated with this project include, but not limited to grading, utility installation, stormwater management, landscaping, and paving. The existing lot is located at 437 Lafayette Road and is identified on the City of Portsmouth Assessor's Map 229 as Lot 1, and is approximately 65,365 sf (1.50 ac) in size. The site is located in the Single Residence B (SRB) Zone and currently contains one single-family residential building and a detached garage.





#### Planning Board Subdivision & Site Plan Review Applications Proposed 3-Lot Subdivision, 437 Lafayette Road, Portsmouth, Tax Map 229, Lot 1

May 25, 2022

The site is bordered by Lafayette Road to the west, Andrew Jarvis Drive to the north, Artwill Avenue to the south, and Saint Nicholas Greek Orthodox Church to the east. The immediate area surrounding the site consists primarily of residential buildings, while the Portsmouth High School is located at the end of Andrew Jarvis Drive approximately 500 feet to the east.

Based on our review of the City of Portsmouth's Zoning Ordinance, Site Plan Review Regulations, and Subdivision Regulations, it is our understanding that this project requires the following Planning Board approvals:

- Site Plan Review
- Subdivision Review
- Conditional Use Permit for an Attached Accessory Dwelling Unit (AADU)

#### Previous Review & Comments

This project has had reviews and/or meetings with City Staff and the Technical Advisory Committee (TAC). A list of our meetings to dates is shown below:

- March 8, 2022 TAC Work Session Meeting (received preliminary comments)
- May 3, 2022 TAC Meeting (received approval to proceed to Planning Board)

Comments were received from TAC on May 2, 2022 prior to the TAC Meeting. These comments were discussed during the meeting and strategies for resolving each item were addressed. To facilitate your review of the materials submitted, we have provided TAC's comments below, along with our responses, which are shown in *bold blue italics*.

#### Comments Received from TAC on May 2, 2022

Items to be addressed prior to Planning Board approval:

- 1. Gas line to be installed under Artwill Ave and service shall come from that side. A new gas main will be installed on Artwill Avenue with service connections made to the proposed houses on Lot 1 and Lot 3. The proposed gas main will connect to an existing gas main located in Lafayette Road at the intersection of Artwill Avenue and Lafayette Road. Unitil has reviewed our plan and approved the layout. Please see sheet C-05.
- Ensure easements are provided for access across all proposed lots. Access easements are provided for all proposed lots and are shown and described on the Subdivision Plan. Please see sheet S-03.
- 3. Provide maintenance agreement for proposed road maintenance. *A road maintenance agreement is provided with this submittal.*
- Provide an easement plan that identifies each easement with a unique identifier and corresponds to an easement table.
   Existing and proposed easements are shown and described on the Subdivision Plan.

After discussing this matter with TAC at the May 2, 2022 meeting, it was determined that a separate Easement Plan is not necessary. Please see sheet S-03.



#### Planning Board Subdivision & Site Plan Review Applications Proposed 3-Lot Subdivision, 437 Lafayette Road, Portsmouth, Tax Map 229, Lot 1

Items to be addressed Prior to Construction:

- 5. Coordinate final connections of water and sewer services with Portsmouth Water. Further coordination with the City Water Department has transpired with regards to final water and sewer service connections. The Water Department has approved the water and sewer connections shown on our plans.
- 6. Final connection to which main under Andrew Jarvis Dr will be determined by Portsmouth Water.

Through additional coordination, the City Water Department has requested that the 8" water main on Andrew Jarvis Drive be used for water service connections. The Utility Plans have been revised accordingly. Please see sheet C-05.

We trust that the above responses satisfy the concerns expressed in the comments received from TAC on May 2, 2022. We appreciate you consideration of these matters and respectfully request to be placed on the upcoming agenda for the Planning Board meeting on June 16, 2022.

If you have any questions or concerns, please do not hesitate to contact us.

Respectfully, **TFMoran**, Inc.

in Maula

Justin Macek, EIT Project Manager

JSM/jcc

CC:

Joe Caldarola, Smithfield Construction, Inc. (via joe@smithfieldconstruction.com)



Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists



### Letter of Authorization

I, Joeseph Caldarola of Artwill, LLC, PO Box 370, Portsmouth, NH, hereby authorize TFMoran, Inc., 170 Commerce Way, Suite 102, Portsmouth, NH, to act on my behalf concerning property owned by Artwill, LLC, located at 437 Lafayette Road, Portsmouth, NH, known as Tax Map 229, Lot 1.

I hereby appoint TFMoran, Inc. as my agent to act on my behalf in the review process, to include any required signatures.

1 Celdenole

Client Name

3/1/22

Date

 TFMoran, Inc.

 48 Constitution Drive, Bedford, NH 03110

 NH 03801

 T(603) 472-4488

 www.tfmoran.com



TFMoran, Inc. Seacoast Division 170 Commerce Way–Suite 102, Portsmouth, T(603) 431-2222



### **City of Portsmouth, New Hampshire**

### Site Plan Application Checklist

This site plan application checklist is a tool designed to assist the applicant in the planning process and for preparing the application for Planning Board review. The checklist is required to be completed and uploaded to the Site Plan application in the City's online permitting system. A preapplication conference with a member of the planning department is strongly encouraged as additional project information may be required depending on the size and scope. The applicant is cautioned that this checklist is only a guide and is not intended to be a complete list of all site plan review requirements. Please refer to the Site Plan review regulations for full details.

Applicant Responsibilities (Section 2.5.2): Applicable fees are due upon application submittal along with required attachments. The application shall be complete as submitted and provide adequate information for evaluation of the proposed site development. Waiver requests must be submitted in writing with appropriate justification.

Name of Applicant: \_\_\_\_\_Artwill, LLC \_\_\_\_\_ Date Submitted: \_\_\_\_\_4/19/2022

\_\_\_\_\_<sub>Map:</sub> 229 <sub>Lot:</sub> 1

Application # (in City's online permitting): <u>LU-</u>22-82

Site Address: \_437 Lafayette Road

**Application Requirements**  $\mathbf{M}$ **Required Items for Submittal Item Location** Waiver (e.g. Page or Requested Plan Sheet/Note #) Complete application form submitted via the City's web-based N/A  $\checkmark$ Submitted via permitting program (2.5.2.1(2.5.2.3A) Viewpoint All application documents, plans, supporting documentation and N/A  $\mathbf{N}$ Submitted digitally via other materials uploaded to the application form in viewpoint in Viewpoint, and one digital Portable Document Format (PDF). One hard copy of all plans hard copy submitted and materials shall be submitted to the Planning Department by the to Planning Dept. published deadline. (2.5.2.8)

	Site Plan Review Application Required Info	ormation	
Ø	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Waiver Requested
	Statement that lists and describes "green" building components and systems. (2.5.3.1B)	N/A	N/A
Ø	Existing and proposed gross floor area and dimensions of all buildings and statement of uses and floor area for each floor. (2.5.3.1C)	C-03	N/A
Ø	Tax map and lot number, and current zoning of all parcels under Site Plan Review. (2.5.3.1D)	S-01 (Existing) C-03 (Proposed)	N/A

	Site Plan Review Application Required Info	ormation	
Ŋ	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Waiver Requested
Q	Owner's name, address, telephone number, and signature. Name, address, and telephone number of applicant if different from owner. (2.5.3.1E)	C-00	N/A
Ø	Names and addresses (including Tax Map and Lot number and zoning districts) of all direct abutting property owners (including properties located across abutting streets) and holders of existing conservation, preservation or agricultural preservation restrictions affecting the subject property. (2.5.3.1F)	S-01	N/A
Ø	Names, addresses and telephone numbers of all professionals involved in the site plan design. (2.5.3.1G)	C-00	N/A
$\mathbf{\nabla}$	List of reference plans. (2.5.3.1H)	S-01 & S-03	N/A
Ŋ	List of names and contact information of all public or private utilities servicing the site. (2.5.3.1)	C-01	N/A

	Site Plan Specifications		
Ø	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Waiver Requested
Ŋ	Full size plans shall not be larger than 22 inches by 34 inches with match lines as required, unless approved by the Planning Director (2.5.4.1A)	Required on all plan sheets	N/A
Ø	Scale: Not less than 1 inch = 60 feet and a graphic bar scale shall be included on all plans. (2.5.4.1B)	Required on all plan sheets	N/A
Ŋ	GIS data should be referenced to the coordinate system New Hampshire State Plane, NAD83 (1996), with units in feet. (2.5.4.1C)	S-01	N/A
Q	Plans shall be drawn to scale and stamped by a NH licensed civil engineer. (2.5.4.1D)	Required on all plan sheets	N/A
	Wetlands shall be delineated by a NH certified wetlands scientist and so stamped. (2.5.4.1E)	No wetlands within project vicinity	N/A
$\mathbf{\nabla}$	Title (name of development project), north point, scale, legend. (2.5.4.2A)	All plan sheets	N/A
$\mathbf{\nabla}$	Date plans first submitted, date and explanation of revisions. (2.5.4.2B)	C-00	N/A
V	Individual plan sheet title that clearly describes the information that is displayed. (2.5.4.2C)	Required on all plan sheets	N/A
$\mathbf{\nabla}$	Source and date of data displayed on the plan. (2.5.4.2D)	S-01	N/A

Site Plan Application Checklist/December 2020

	Site Plan Specifications – Required Exhibit	s and Data	
Ø	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Waiver Requested
	<ol> <li>Existing Conditions: (2.5.4.3A)         <ul> <li>Surveyed plan of site showing existing natural and built features;</li> <li>Existing building footprints and gross floor area;</li> <li>Existing parking areas and number of parking spaces provided;</li> <li>Zoning district boundaries;</li> <li>Existing, required, and proposed dimensional zoning requirements including building and open space coverage, yards and/or setbacks, and dwelling units per acre;</li> <li>Existing impervious and disturbed areas;</li> <li>Limits and type of existing vegetation;</li> <li>Wetland delineation, wetland function and value assessment (including vernal pools);</li> <li>SFHA, 100-year flood elevation line and BFE data, as required.</li> </ul> </li> </ol>	S-01 & S-03	
V	<ul> <li>2. Buildings and Structures: (2.5.4.3B)</li> <li>Plan view: Use, size, dimensions, footings, overhangs, 1st fl. elevation;</li> <li>Elevations: Height, massing, placement, materials, lighting, façade treatments;</li> <li>Total Floor Area;</li> <li>Number of Usable Floors;</li> <li>Gross floor area by floor and use.</li> </ul>	- Plan sheet C-03 -Architectural Drawings	
	<ol> <li>Access and Circulation: (2.5.4.3C)         <ul> <li>Location/width of access ways within site;</li> <li>Location of curbing, right of ways, edge of pavement and sidewalks;</li> <li>Location, type, size and design of traffic signing (pavement markings);</li> <li>Names/layout of existing abutting streets;</li> <li>Driveway curb cuts for abutting prop. and public roads;</li> <li>If subdivision; Names of all roads, right of way lines and easements noted;</li> <li>AASHTO truck turning templates, description of minimum vehicle allowed being a WB-50 (unless otherwise approved by TAC).</li> </ul> </li> </ol>	C-03 & C-09	
	<ul> <li>4. Parking and Loading: (2.5.4.3D)</li> <li>Location of off street parking/loading areas, landscaped areas/buffers;</li> <li>Parking Calculations (# required and the # provided).</li> </ul>	C-03	
$\mathbf{\nabla}$	<ul> <li>5. Water Infrastructure: (2.5.4.3E)</li> <li>Size, type and location of water mains, shut-offs, hydrants &amp; Engineering data;</li> <li>Location of wells and monitoring wells (include protective radii).</li> </ul>	S-01 & C-05	
$\mathbf{\nabla}$	<ul> <li>6. Sewer Infrastructure: (2.5.4.3F)</li> <li>Size, type and location of sanitary sewage facilities &amp; Engineering data, including any onsite temporary facilities during construction period.</li> </ul>	S-01 & C-05	

Site Plan Application Checklist/December 2020

$\mathbf{V}$	<ul> <li>7. Utilities: (2.5.4.3G)</li> <li>The size, type and location of a</li> <li>Size type and location of generation</li> </ul>	ll above & below ground utilities;	S-01, C-05, C-11	
	fixtures.	ator paus, transformers and other		
	8. Solid Waste Facilities: (2.5.4.3	3H)	N/A (Residential Trash Pickup)	
	• The size, type and location of se	olid waste facilities.		
R	<ul> <li>9. Storm water Management: (2</li> <li>The location, elevation and layor</li> <li>The location of onsite snow stor site snow removal provisions.</li> <li>Location and containment meas</li> <li>Location of proposed temporar locations and distance from weight</li> </ul>	<b>2.5.4.31)</b> but of all storm-water drainage. rage areas and/or proposed off- sures for any salt storage facilities y and permanent material storage	C-03: Snow storage C-04: Stormwater design C-11: Stormwater design	
	stormwater structures.			
	<ul> <li>10. Outdoor Lighting: (2.5.4.3J)</li> <li>Type and placement of all lighti and any other areas of the site)</li> </ul>	ng (exterior of building, parking lot and photometric plan.	N/A	
	<ol> <li>Indicate where dark sky friend been implemented. (10.1)</li> </ol>	lly lighting measures have	N/A	
	<ul> <li>12. Landscaping: (2.5.4.3K)</li> <li>Identify all undisturbed area which is to be retained;</li> <li>Location of any irrigation system</li> </ul>	, existing vegetation and that stem and water source.	S-01, C-02, C-06, C-15	
Ø	<ul> <li>13. Contours and Elevation: (2.5.</li> <li>Existing/Proposed contours grade elevations.</li> </ul>	<b>4.3L)</b> (2 foot minimum) and finished	S-01, C-04	
$\mathbf{\nabla}$	<ul> <li>14. Open Space: (2.5.4.3M)</li> <li>Type, extent and location of</li> </ul>	all existing/proposed open space.	S-01, S-03, C-03	
$\mathbf{N}$	15. All easements, deed restriction ways. (2.5.4.3N)	ons and non-public rights of	S-01 & S-03	
	<ul> <li>16. Character/Civic District (All for included): (2.5.4.3P)</li> <li>Applicable Building Height (1</li> <li>Applicable Special Requirem</li> <li>Proposed building form/type</li> <li>Proposed community space</li> </ul>	Dllowing information shall be 10.5A21.20 & 10.5A43.30); ents (10.5A21.30); e (10.5A43); (10.5A46).	N/A	
	<ul> <li>17. Special Flood Hazard Areas (2.5.</li> <li>The proposed development minimize flood damage;</li> <li>All public utilities and facilit minimize or eliminate flood</li> <li>Adequate drainage is provid flood hazards.</li> </ul>	<b>4.3Q)</b> is consistent with the need to ies are located and construction to damage; led so as to reduce exposure to	N/A	

	Other Required Information				
Ø	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Waiver Requested		
	Traffic Impact Study or Trip Generation Report, as required. (3.2.1-2)	N/A			
$\mathbf{N}$	Indicate where Low Impact Development Design practices have been incorporated. (7.1)	-C-05 (Drainage Plan) -Drainage Report			
V	Indicate whether the proposed development is located in a wellhead protection or aquifer protection area. Such determination shall be approved by the Director of the Dept. of Public Works. <b>(7.3.1)</b>	Drainage Report Appendix J (NHDES OneStop Map)			
$\mathbf{N}$	Stormwater Management and Erosion Control Plan. (7.4)	-C-05, C-07, C-08, C-10 -Drainage Report			
$\mathbf{\nabla}$	Inspection and Maintenance Plan (7.6.5)	Drainage Report Appendix L			

	Final Site Plan Approval Required Infor	mation	
Ø	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Waiver Requested
	All local approvals, permits, easements and licenses required, including but not limited to: Waivers; Driveway permits; Special exceptions; Variances granted; Easements; Licenses. (2.5.3.2A)	C-00	
	<ul> <li>Exhibits, data, reports or studies that may have been required as part of the approval process, including but not limited to: <ul> <li>a. Calculations relating to stormwater runoff;</li> <li>b. Information on composition and quantity of water demand and wastewater generated;</li> </ul> </li> <li>c. Information on air, water or land pollutants to be discharged, including standards, quantity, treatment and/or controls;</li> <li>d. Estimates of traffic generation and counts pre- and post-construction;</li> <li>e. Estimates of noise generation;</li> <li>f. A Stormwater Management and Erosion Control Plan;</li> <li>g. Endangered species and archaeological / historical studies;</li> <li>h. Wetland and water body (coastal and inland) delineations;</li> <li>i. Environmental impact studies.</li> </ul>	a. Drainage Report b. NHDES Sewer Connection Application and Water Demand Report to be provided at Planning Board submittal. c. N/A d. N/A e. N/A f. C-04, C-07, C-08; and Drainage Report g. N/A h. N/A i. N/A	
N	A document from each of the required private utility service providers indicating approval of the proposed site plan and indicating an ability to provide all required private utilities to the site. (2.5.3.2D)	Will Serve Letters (Eversource and Unitil)	

Site Plan Application Checklist/December 2020

	Final Site Plan Approval Required Info	rmation	
Ø	Required Items for Submittal Item Locat (e.g. Page/lin Plan Sheet/N		Waiver Requested
J	A list of any required state and federal permit applications required for the project and the status of same. (2.5.3.2E)	C-00	
A note shall be provided on the Site Plan stating: "All conditions on this Plan shall remain in effect in perpetuity pursuant to the requirements of the Site Plan Review Regulations." (2.5.4.2E)		C-03 Note #5	N/A
	For site plans that involve land designated as "Special Flood Hazard Areas" (SFHA) by the National Flood Insurance Program (NFIP) confirmation that all necessary permits have been received from those governmental agencies from which approval is required by Federal or State law, including Section 404 of the Federal Water Pollution Control Act Amendments of 1972, 33 U.S.C. 1334. (2.5.4.2F)	N/A	
Z	<ul> <li>Plan sheets submitted for recording shall include the following notes:</li> <li>a. "This Site Plan shall be recorded in the Rockingham County Registry of Deeds."</li> <li>b. "All improvements shown on this Site Plan shall be constructed and maintained in accordance with the Plan by the property owner and all future property owners. No changes shall be made to this Site Plan without the express approval of the Portsmouth Planning Director."</li> </ul>	C-03 Note #6 Note #7	N/A

# Applicant's Signature: Juto Music Date: 4/19/2022

Page 6 of 6



### City of Portsmouth, New Hampshire

### Subdivision Application Checklist

This subdivision application checklist is a tool designed to assist the applicant in the planning process and for preparing the application for Planning Board review. A pre-application conference with a member of the planning department is strongly encouraged as additional project information may be required depending on the size and scope. The applicant is cautioned that this checklist is only a guide and is not intended to be a complete list of all subdivision review requirements. Please refer to the Subdivision review regulations for full details.

**Applicant Responsibilities (Section III.C):** Applicable fees are due upon application submittal along with required number of copies of the Preliminary or final plat and supporting documents and studies. Please consult with Planning staff for submittal requirements.

<sub>Owner:</sub> Artwill, LLC	Date Submitted: 4/19/2022
Applicant: Joe Cardarola	
Phone Number: 603-674-5204	<sub>E-mail:</sub> joe@smithfieldconstruction.com
Site Address 1: 437 Lafayette Road	
Site Address 2:	Map: Lot:

	Application Requirements				
Ø	Required Items for Submittal	Item Location (e.g. Page or Plan Sheet/Note #)	Waiver Requested		
	Completed Application form. (III.C.2-3)	Submitted online & (1) copy to City	N/A		
	All application documents, plans, supporting documentation and other materials provided in digital Portable Document Format (PDF) on compact disc, DVD or flash drive. (III.C.4)	Submitted online & (1) copy to City	N/A		

Requirements for Preliminary/Final Plat				
Ø	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Required for Preliminary / Final Plat	Waiver Requested
	Name and address of record owner, any option holders, descriptive name of subdivision, engineer and/or surveyor or name of person who prepared the plat. (Section IV.1/V.1)	C-00	☑ Preliminary Plat ☑ Final Plat	N/A

	Kequirements for Pr	eliminary/Final Plat		
Ø	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Required for Preliminary / Final Plat	Waiver Requested
	Preliminary Plat Names and addresses of all adjoining property owners. (Section IV.2) Final Plat Names and addresses of all abutting property owners, locations of buildings within one hundred (100) feet of the parcel, and any new house numbers within the subdivision. (Section V.2)	S-01 & S-03	☑ Preliminary Plat ☑ Final Plat	N/A
	North point, date, and bar scale. (Section IV.3/V3)	Required on all Plan Sheets	☑ Preliminary Plat ☑ Final Plat	N/A
<	Zoning classification and minimum yard dimensions required. (Section IV.4/V.4)	S-01 & S-03	<ul> <li>✓ Preliminary Plat</li> <li>✓ Final Plat</li> </ul>	N/A
	Preliminary Plat Scale (not to be smaller than one hundred (100) feet = 1 inch) and location map (at a scale of 1" = 1000'). (Section IV.5) Final Plat Scale (not to be smaller than 1"=100'), Location map (at a scale of 1"=1,000') showing the property being subdivided and its relation to the surrounding area within a radius of 2,000 feet. Said location map shall delineate all streets and other major physical features that my either affect or be affected by the proposed development. (Section V.5)	S-01 & S-03	☑ Preliminary Plat ☑ Final Plat	N/A
	Location and approximate dimensions of all existing and proposed property lines including the entire area proposed to be subdivided, the areas of proposed lots, and any adjacent parcels in the same ownership. <b>(Section IV.6)</b>	S-01 & S-03	☑ Preliminary Plat ☑ Final Plat	N/A
	Dimensions and areas of all lots and any and all property to be dedicated or reserved for schools, parks, playgrounds, or other public purpose. Dimensions shall include radii and length of all arcs and calculated bearing for all straight lines. (Section V.6/ IV.7)	S-01 & S-03	☑ Preliminary Plat ☑ Final Plat	N/A
	Location, names, and present widths of all adjacent streets, with a designation as to whether public or private and approximate location of existing utilities to be used. Curbs and sidewalks shall be shown.	S-01 & S-03	☑ Preliminary Plat ☑ Final Plat	N/A

Requirements for Preliminary/Final Plat				
A	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Required for Preliminary / Final Plat	Waiver Requested
	Location of significant physical features, including bodies of water, watercourses, wetlands, railroads, important vegetation, stone walls and soils types that my influence the design of the subdivision. (Section IV.9/V.8)	S-01 & S-03	<ul> <li>✓ Preliminary Plat</li> <li>✓ Final Plat</li> </ul>	N/A
	Preliminary Plat Proposed locations, widths and other dimensions of all new streets and utilities, including water mains, storm and sanitary sewer mains, catch basins and culverts, street lights, fire hydrants, sewerage pump stations, etc. (Section IV.10) Final Plat Proposed locations and profiles of all proposed streets and utilities, including water mains, storm and sanitary sewer mains, catchbasins and culverts, together with typical cross sections. Profiles shall be drawn to a horizontal scale of 1"=50' and a vertical scale of 1"=5', showing existing centerline grade, existing left and right sideline grades, and proposed centerline grade. (Section V.9)	S-03, C-03, C-05	<ul> <li>✓ Preliminary Plat</li> <li>✓ Final Plat</li> </ul>	N/A
	When required by the Board, the plat shall be accompanied by profiles of proposed street grades, including extensions for a reasonable distance beyond the subject land; also grades and sizes of proposed utilities. (Section IV.10)	S-01 & C-04 (Existing & Proposed contours and grades shown on plans)	☑ Preliminary Plat ☑ Final Plat	N/A
	Base flood elevation (BFE) for subdivisions involving greater than five (5) acres or fifty (50) lots. (Section IV.11)	N/A	☑ Preliminary Plat ☑ Final Plat	N/A
	For subdivisions of five (5) lots or more, or at the discretion of the Board otherwise, the preliminary plat shall show contours at intervals no greater than two (2) feet. Contours shall be shown in dotted lines for existing natural surface and in solid lines for proposed final grade, together with the final grade elevations shown in figures at all lot corners. If existing grades are not to be changed, then the contours in these areas shall be solid lines. (Section IV.12/V.12)	S-01 (Subdivision only contains 3 proposed lots)	<ul> <li>✓ Preliminary Plat</li> <li>✓ Final Plat</li> </ul>	N/A

Requirements for Preliminary/Final Plat				
A	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Required for Preliminary / Final Plat	Waiver Requested
	Dates and permit numbers of all necessary permits from governmental agencies from which approval is required by Federal or State law. (Section V.10)	C-00 (Dates and permit numbers pending)	<ul> <li>□ Preliminary Plat</li> <li>☑ Final Plat</li> </ul>	N/A
	For subdivisions involving greater than five (5) acres or fifty (50) lots, the final plat shall show hazard zones and shall include elevation data for flood hazard zones. (Section V.11)	N/A (Subdivision only contains 3 proposed lots)	<ul> <li>□ Preliminary Plat</li> <li>☑ Final Plat</li> </ul>	N/A
	Location of all permanent monuments. (Section V.12)	S-01	<ul> <li>□ Preliminary Plat</li> <li>☑ Final Plat</li> </ul>	N/A

General Requirements <sup>1</sup>			
Þ	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Waiver Requested
	<ol> <li>Basic Requirements: (VI.1)         <ul> <li>a. Conformity to Official Plan or Map</li> <li>b. Hazards</li> <li>c. Relation to Topography</li> <li>d. Planned Unit Development</li> </ul> </li> </ol>	All sheets N/A S-01 NA	N/A
>>>	<ul> <li>2. Lots: (VI.2)</li> <li>a. Lot Arrangement</li> <li>b. Lot sizes</li> <li>c. Commercial and Industrial Lots</li> </ul>	S-03 & C-03 S-03 & C-03 N/A	N/A
	<ul> <li>3. Streets: (VI.3) <ul> <li>a. Relation to adjoining Street System</li> <li>b. Street Rights-of-Way</li> <li>c. Access</li> <li>d. Parallel Service Roads</li> <li>e. Street Intersection Angles</li> <li>f. Merging Streets</li> <li>g. Street Deflections and Vertical Alignment</li> <li>h. Marginal Access Streets</li> <li>i. Cul-de-Sacs</li> <li>j. Rounding Street Corners</li> <li>k. Street Name Signs</li> <li>l. Street Names</li> <li>m. Block Lengths</li> <li>n. Block Widths</li> <li>o. Grade of Streets</li> </ul> </li> </ul>	a. S-03 & C-03 b. S-03 & C-03 c. S-03 & C-03 d. S-03 & C-03 e. S-03 (To be prov.) f. S-03 & C-03 g. S-03 & C-03 h. N/A i. N/A j. C-03 k. NA I. S-03 & C-03 m. N/A n. N/A o. S-01 & C-04 p. N/A	N/A
$\checkmark$	4. Curbing: (VI.4)	C-03 & C-04	N/A
$\checkmark$	5. Driveways: (VI.5)	S-03 & C-03	N/A
$\checkmark$	6. Drainage Improvements: (VI.6)	C-04	N/A
$\checkmark$	7. Municipal Water Service: (VI.7)	S-01 & C-05	N/A
	<ul> <li>8. Municipal Sewer Service: (VI.8)</li> <li>9. Installation of Utilities: (VI.9) <ul> <li>a. All Districts</li> <li>b. Indicator Tape</li> </ul> </li> </ul>	S-01 & C-05	N/A N/A
	10. On-Site Water Supply: (VI.10)	C-05	N/A
	11. On-Site Sewage Disposal Systems: (VI.11)	N/A	N/A
<u> </u> \\\ \	<b>12. Open Space: (VI.12)</b> a. Natural Features b. Buffer Strips c. Parks d. Tree Planting	S-03 & C-03 a. S-01 b. C-03 & C-06 c. NA d. C-06	N/A
	<ul> <li>13. Flood Hazard Areas: (VI.13)</li> <li>a. Permits</li> <li>b. Minimization of Flood Damage</li> <li>c. Elevation and Flood-Proofing Records</li> <li>d. Alteration of Watercourses</li> </ul>	N/A	N/A
✓	14. Erosion and Sedimentation Control (VI.14)	C-07 & C-08	N/A

Subdivision Application Checklist/January 2018

μ			
Ø	Required Items for Submittal	Item Location (e.g. Page/line or Plan Sheet/Note #)	Waiver Requested
	<ul><li>15. Easements (VI.15)</li><li>a. Utilities</li><li>b. Drainage</li></ul>	a. S-03 b. NA	N/A
	16. Monuments: (VI.16)	S-01	N/A
$\overline{\mathbf{V}}$	17. Benchmarks: (VI.17)	S-01	N/A
	18. House Numbers (VI.18)	S-03 & C-03 (Final unit numbers TBD)	N/A

Design Standards				
		Required Items for Submittal	Indicate compliance and/or provide explanation as to alternative design	Waiver Requested
	1.	Streets have been designed according to the designstandards required under Section (VII.1).a.Clearingb.Excavationc.Rough Grade and Preparation of Sub-Graded.Base Coursee.Street Pavingf.Side Slopesg.Approval Specificationsh.Curbingi.Sidewalksj.Inspection and Methods	Yes	N/A
7	2.	<ul> <li>Storm water Sewers and Other Drainage Appurtenances</li> <li>have been designed according to the design standards</li> <li>required under Section (VII.2).</li> <li>a. Design</li> <li>b. Standards of Construction</li> </ul>	Yes	
7	3.	<ul> <li>Sanitary Sewers have been designed according to the design standards required under Section (VII.3).</li> <li>a. Design</li> <li>b. Lift Stations</li> <li>c. Materials</li> <li>d. Construction Standards</li> </ul>	Yes	
~	4.	<ul> <li>Water Mains and Fire Hydrants have been designed according to the design standards required under Section (VII.4).</li> <li>a. Connections to Lots</li> <li>b. Design and Construction</li> <li>c. Materials</li> <li>d. Notification Prior to Construction</li> </ul>	Yes	

Applicant's/Representative's Signature: Justo Musicant Date: 4/19/2022

<sup>1</sup> See City of Portsmouth, NH Subdivision Rules and Regulations for details. Subdivision Application Checklist/January 2018

Page 6 of 6

### **CITY OF PORTSMOUTH**



Planning Department 1 Junkins Avenue Portsmouth, New Hampshire 03801 (603) 610-7216

#### **TECHNICAL ADVISORY COMMITTEE**

May 9, 2022

Artwill, LLC PO Box 370 Portsmouth , New Hampshire 03801

RE: Preliminary and Final Subdivision approval for property located at 437 Lafayette Road (LU-22-82)

Dear Property Owner:

The Technical Advisory Committee, at its regularly scheduled meeting of Thursday, May 3, 2022, considered your application for Preliminary and Final Subdivision approval to subdivide one existing lot with 65,365 square feet of lot area and 123.92 of frontage on Lafayette Road and 336.61 feet of frontage on Andrew Jarvis Drive into three lots as follows: Proposed Lot 1 with 18,434 square feet of lot area and 123.92 feet of frontage on Lafayette Road and 129.57 feet of frontage on Andrew Jarvis Drive, Proposed Lot 2 with 16,606 square feet of lot area and 102.04 feet of frontage on Andrew Jarvis Drive, and Proposed Lot 3 with 30,325 square feet of lot area and 107 feet of frontage on Andrew Jarvis Drive. Said property is shown on Assessor Map 229 Lot 1 and lies within the Single Residence B (SRB) District. As a result of said consideration, the Committee voted to **recommend approval** to the Planning Board with the following stipulations:

#### Items to be addressed prior to Planning Board approval:

1. Access easements will be will be provided to allow access across all proposed lots for travel along Artwill Ave.

2. A maintenance agreement will be provided for proposed Artwill Ave. maintenance.

3. All easements will be identified with unique identifiers and corresponding easement table that lists all easements and their purpose.

4. Gas line is to be installed under Artwill Ave and service shall come from the new line and explore feasibility of servicing the existing unit from Artwill Ave.

This matter will be placed on the agenda for the Planning Board meeting scheduled for **Thursday, June 16, 2022**. One (1) hard copy of all plans and supporting reports and exhibits as well as an updated electronic file (in a PDF format) must be filed in the Planning Department and uploaded to the online permit system no later than **Wednesday, May 25, 2022**.

Per Section 2.5 of the Site Plan Regulations, a site plan review application to the Planning Board must include all applicable information and supporting materials including but not limited to the following items:

- Full updated plan set
- Draft Easements
- Drainage Analysis
- Traffic Studies
- Etc.

All comments, corrections, and conditions identified as "Items to be addressed before Planning Board submittal' must be resolved/corrected for the Planning Board application submittal to be deemed complete.

The minutes and audio recording of this meeting are available by contacting the Planning Department.

Very truly yours,

Benerey Mon-zoult

Beverly Mesa-Zendt, Planning Director

CC:

Justin Macek, TF Moran, Inc.

### #45407,120



### **CITY OF PORTSMOUTH**

Planning Department 1 Junkins Avenue Portsmouth, New Hampshire 03801 (603) 610-7216

#### TECHNICAL ADVISORY COMMITTEE

May 9, 2022

Artwill, LLC PO Box 370 Portsmouth , New Hampshire 03801

RE: Site Plan approval and Conditional Use Permit approval for property located at 437 Lafayette Road (LU-22-82)

Dear Property Owner:

The Technical Advisory Committee, at its regularly scheduled meeting of Thursday, May 3, 2022, considered your application for Site Plan approval and Conditional Use Permit approval as permitted under Section 10814.40 of the Zoning Ordinance to subdivide the lot and construct two new single-family dwellings (one includes an attached dwelling unit) in addition to the existing single-family dwelling. Said property is shown on Assessor Map 229 Lot 1 and lies within the Single Residence B (SRB) District. As a result of said consideration, the Committee voted to **recommend approval** to the Planning Board with the following stipulations:

#### Items to be addressed prior to Planning Board approval:

1. All easements will be identified with unique identifiers and corresponding easement table that lists all easements and their purpose.

#### Prior to Building Permit Issuance:

 Applicant will coordinate final water and sewer connections with Portsmouth Water.
 The final water main connection under Andrew Jarvis Dr. will be determined by Portsmouth Water.

This matter will be placed on the agenda for the Planning Board meeting scheduled for **Thursday, June 16, 2022**. One (1) hard copy of all plans and supporting reports and exhibits as well as an updated electronic file (in a PDF format) must be filed in the Planning Department and uploaded to the online permit system no later than **Wednesday, May 25**, **2022**.

Per Section 2.5 of the Site Plan Regulations, a site plan review application to the Planning Board must include all applicable information and supporting materials including but not limited to the following items:

- Full updated plan set
- Draft Easements
- Drainage Analysis
- Traffic Studies
- Etc.

All comments, corrections, and conditions identified as "Items to be addressed before Planning Board submittal' must be resolved/corrected for the Planning Board application submittal to be deemed complete.

The minutes and audio recording of this meeting are available by contacting the Planning Department.

Very truly yours,

Benerey Wes- gratt

Beverly Mesa-Zendt, Planning Director

cc:

Justin Macek, TF Moran, Inc.

Artwill PO Box 370 PORTSMOUTH, NH 03801

ST. NICHOLAS GREEK ORTHODOX CHURCH 40 ANDREW JARVIS DRIVE PORTSMOUTH, NH 03801

KARONA LLC 36 ARTWILL AVENUE PORTSMOUTH, NH 03801

KRISTIN M. & CHRISTOPHER M. CHASE 34 ARTWILL AVENUE PORTSMOUTH, NH 03801

FRIENDS OF LAFAYETTE HOUSE PO BOX 4545 PORTSMOUTH, NH 03802

CHURCH OF JESUS CHRIST C/O TAX DIVISION 50E NORTH TEMPLE STREET FLOOR 22 SALT LAKE CITY, UT 84150

TERRY A. & ANDREA C. SMITH 7 ANDREW JARVIS DRIVE PORTSMOUTH, NH 03801

VINCENT A. & ALICIA B. RICCO 440 LAFAYETTE ROAD PORTSMOUTH, NH 03801

CINDI S. BLANCHETTE 95 GREENLEAF AVENUE PORTSMOUTH, NH 03801

TFMORAN, INC. 170 COMMERCE WAY - SUITE 102 PORTSMOUTH, NH 03801 Artwill PO Box 370 PORTSMOUTH, NH 03801

ST. NICHOLAS GREEK ORTHODOX CHURCH 40 ANDREW JARVIS DRIVE PORTSMOUTH, NH 03801

KARONA LLC 36 ARTWILL AVENUE PORTSMOUTH, NH 03801

KRISTIN M. & CHRISTOPHER M. CHASE 34 ARTWILL AVENUE PORTSMOUTH, NH 03801

FRIENDS OF LAFAYETTE HOUSE PO BOX 4545 PORTSMOUTH, NH 03802

CHURCH OF JESUS CHRIST C/O TAX DIVISION 50E NORTH TEMPLE STREET FLOOR 22 SALT LAKE CITY, UT 84150

TERRY A. & ANDREA C. SMITH 7 ANDREW JARVIS DRIVE PORTSMOUTH, NH 03801

VINCENT A. & ALICIA B. RICCO 440 LAFAYETTE ROAD PORTSMOUTH, NH 03801

CINDI S. BLANCHETTE 95 GREENLEAF AVENUE PORTSMOUTH, NH 03801

TFMORAN, INC. 170 COMMERCE WAY - SUITE 102 PORTSMOUTH, NH 03801 Artwill PO Box 370 PORTSMOUTH, NH 03801

ST. NICHOLAS GREEK ORTHODOX CHURCH 40 ANDREW JARVIS DRIVE PORTSMOUTH, NH 03801

KARONA LLC 36 ARTWILL AVENUE PORTSMOUTH, NH 03801

KRISTIN M. & CHRISTOPHER M. CHASE 34 ARTWILL AVENUE PORTSMOUTH, NH 03801

FRIENDS OF LAFAYETTE HOUSE PO BOX 4545 PORTSMOUTH, NH 03802

CHURCH OF JESUS CHRIST C/O TAX DIVISION 50E NORTH TEMPLE STREET FLOOR 22 SALT LAKE CITY, UT 84150

TERRY A. & ANDREA C. SMITH 7 ANDREW JARVIS DRIVE PORTSMOUTH, NH 03801

VINCENT A. & ALICIA B. RICCO 440 LAFAYETTE ROAD PORTSMOUTH, NH 03801

CINDI S. BLANCHETTE 95 GREENLEAF AVENUE PORTSMOUTH, NH 03801

TFMORAN, INC. 170 COMMERCE WAY - SUITE 102 PORTSMOUTH, NH 03801



Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists

# **Abutters List**

#### Smithfield Construction 437 Lafayette Road, Portsmouth, NH

May 24, 2022 45407-120

Assessors Map		Abuttor Nome	Mailing Address	
Мар	Lot			
220	1	Artwill	PO Box 370	
229	L L		PORTSMOUTH, NH 03801	
220	2	ST. NICHOLAS GREEK ORTHODOX	40 ANDREW JARVIS DRIVE	
223	۷	CHURCH	PORTSMOUTH, NH 03801	
220	4		36 ARTWILL AVENUE	
229	4	KARONA LLC	PORTSMOUTH, NH 03801	
220	5		34 ARTWILL AVENUE	
229		KKISTIN IVI. & CHKISTOPHER IVI. CHASE	PORTSMOUTH, NH 03801	
220	23A	FRIENDS OF LAFAYETTE HOUSE	PO BOX 4545	
250			PORTSMOUTH, NH 03802	
220	24	CHURCH OF JESUS CHRIST	50E NORTH TEMPLE STREET FLOOR 22	
250		C/O TAX DIVISION	SALT LAKE CITY, UT 84150	
220	25	TERRY A. & ANDREA C. SMITH	7 ANDREW JARVIS DRIVE	
250			PORTSMOUTH, NH 03801	
221	1	VINCENT A. & ALICIA B. RICCO	440 LAFAYETTE ROAD	
251			PORTSMOUTH, NH 03801	
221	59	CINDI S. BLANCHETTE	95 GREENLEAF AVENUE	
231			PORTSMOUTH, NH 03801	
		T	170 Commerce Way - Suite 102	
Civil Enginee	ers / Surveyor	TFMoran, Inc.	Destere puth NUL 02801	
j i j			Portsmouth, NH 03801	



March 1, 2022

Joseph Caldarola, Manager Artwill LLC 170 Dennett Street #2 Portsmouth, NH 03801

Dear Mr. Caldarola:

1700 Lafayette Road Portsmouth, NH 03801

Michael J Busby 603-436-7708 x555-5678 michael.busby@eversource.com

I am responding to your request to confirm the availability of electric service for the proposed 437 Lafayette Road Lots 1, 2 and 3, Portsmouth, NH project being constructed for/by Artwill LLC.

The proposed project consists of two new single family building lots, each with one residential unit. The proposed development will be constructed along Artwill Street.

The developer will be responsible for the installation of all underground facilities and infrastructure required to service the new building. The service will be as shown on attached marked up utility plan. The proposed building service will be fed from a new riser pole to be determined by Eversource Engineering as depicted on Site Layout Plan 3 lot subdivision. The developer will work with Eversource to obtain all necessary easements and licenses for the proposed overhead and underground facilities listed above.

This letter serves as confirmation that Eversource has sufficient capacity in the area to provide service to this proposed development. The cost of extending service to the aforementioned location and any associated infrastructure improvements necessary to provide service will be borne by the developer unless otherwise agreed upon.

The attached drawing titled "Proposed 3 Lot Subdivision 437 Lafayette Rd Portsmouth NH" dated April 19,2022 shows transformer locations to service your proposed project.

Eversource approves the locations shown; assuming the final installed locations meet all clearances, physical protection, and access requirements as outlined in Eversource's "Information & Requirements For Electric Supply" (https://www.eversource.com/content/docs/default-source/pdfs/requirements-for-electric-service-connections.pdf?sfvrsn=2).

If you require additional information or I can be of further assistance please do not hesitate to contact me at our Portsmouth Office, 603-436-7708 Ext. 555-5678

Respectfully.

NH Eastern Regional Engineering, Eversource

cc: (via e-mail) Thomas Boulter, Eastern Region Operations Manager, Eversource Nickolai Kosko, Field Supervisor, Electric Design, Eversource



### NOTES

SEE UTILTIY NOTES ON SHEET C-01. CONTRACTOR SHALL COORDINATE WITH CITY OF PORTSMOUTH DPW PRIOR TO CONSTRUCTING SEWER MANHOLE CONNECTION.



TAX MAP 229 LOT 1 UTILITY PLAN

### PROPOSED 3 LOT SUBDIVISION **437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

OWNED BY & PREPARE FOR **ARTWILL, LLC** 

1"=40' (11"X17") SCALE: 1"=20' (22"X34")

**APRIL 19, 2022** 



Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists

45407-120\_UTILITY

C-05

| 48 Constitution Drive

Bedford, NH 03110

Fax (603) 472-9747

www.tfmoran.com

Phone (603) 472-4488



February 24, 2022

Artwill LLC PO Box 267 Portsmouth NH 03802-0267

RE: Natural Gas Availability to 437 Lafayette Rd Portsmouth NH Project

Dear Mr. Caldarola

Unitil's natural gas division has reviewed the requested site for natural gas service.

Unitil hereby confirms natural gas service will be available to 437 Lafayette Rd Portsmouth NH Project, to serve two single family homes.

Installation is pending an authorized installation agreement with Artwill, LLC and a street opening approval from the City of Portsmouth DPW.

Let me know if you have any questions. You can email me at oliver@unitil.com. My phone number is 603-294-5174.

Sincerely,

Janet Oliver Senior Business Development Representative Transfer Stamps: \$0.00 Non-Contractual Transfer

#### ACCESS AND UTILITY EASEMENT AGREEMENT

This Access and Utility Easement Agreement is made by and between Artwill LLC, a New Hampshire Limited Liability Company, of 437 Lafayette Road, Portsmouth, NH 03801, Karona LLC, a New Hampshire Limited Liability Company, of 36 Artwill Avenue, Portsmouth, NH 03801, and Christopher M. Chase and Kristin M. Chase, a married couple, of 34 Artwill Avenue, Portsmouth, NH 03801 ("Chase")

#### WITNESSETH

WHEREAS, Artwill LLC is the owner of three (3) parcels of land with the buildings thereon located in the City of Portsmouth, County of Rockingham, State of New Hampshire, identified as "Lot 1", "Lot 2", and "Lot 3" on a subdivision plan entitled, "Tax Map 229, Lot 1 Subdivision Plan Proposed 3-Lot Subdivision 437 Lafayette Road, Portsmouth, New Hampshire County of Rockingham Owned by Artwill LLC", dated April 19, 2022, as revised May 25, 2022 or, and recorded in Rockingham County Registry of Deeds (the "RCRD") as Plan #D-(the "Subdivision Plan"). *See* Warranty Deed, dated September 27, 2021, and recorded in the RCRD at Book 6334, Page 455; and

WHEREAS, Karona LLC is the owner of real property at 36 Artwill Avenue, Portsmouth, NH 03801, identified on Portsmouth Tax Map 229 as Lot 4 (the "Karona Property"). *See* Foreclosure Deed, dated May 18, 2017, recorded in the RCRD at Book 5821, Page 1630; and

WHEREAS, Chase is the owner of real property at 34 Artwill Avenue, Portsmouth, NH 03801, identified on Portsmouth Tax Map 229, as Lot 5 (the "Chase Property"). *See* Warranty Deed, dated March 3, 2015, recorded in the RCRD at Book 5599, Page 0453; and

WHEREAS, Lot 1, Lot 2, Lot 3, the Karona Property and the Chase Property are all accessed by a private street known referred to and known as "Artwill Avenue", as shown on the Subdivision Plan; and

WHEREAS, Artwill Avenue comprises portions of Lot 1, Lot 2, and Lot 3 as shown on the Subdivision Plan; and

WHEREAS, Artwill LLC is the owner of Artwill Avenue by virtue of its ownership of Lot 1, Lot 2 and Lot 3; and

WHEREAS, Artwill LLC wishes to enter into an agreement with Karona LLC and Chase to clarify, grant, reserve and agree upon certain easement rights and landowner obligations in Artwill Avenue relative to access and utilities.

**NOW THEREFORE**, in consideration for the mutual covenants, promises and representations contained herein and other good and valuable consideration, the Parties hereby enter into the following Access and Utility Easement Agreement.

#### I. ACCESS EASEMENTS

#### A. Reservation of Access Easement for Lot 2

Artwill LLC hereby reserves a perpetual access easement for the benefit of Lot 2 and its future owners across Lot 1 to pass and repass by vehicle, foot, and other lawful modes of transportation over that portion of Artwill Avenue that is located within the boundaries of Lot 1. This access easement right shall be held in common with the future owner of Lot 3, Karona LLC and Chase.

#### B. Reservation of Access Easement for Lot 3

Artwill LLC hereby reserves a perpetual access easement for the benefit of Lot 3 and its future owners across Lot 1 and Lot 2 to pass and repass by vehicle, foot, and other lawful modes of transportation over that portion of Artwill Avenue that is located within the boundaries of Lot 1 and Lot 2. This access easement right shall be held in common with the future owner of Lot 2, Karona LLC, and Chase.

#### C. Access Easement for Chase Property

Chase shall have a perpetual access easement across Lot 1 and Lot 2 to pass and repass by vehicle, foot, and other lawful modes of transportation over that portion of Artwill Avenue that is located within the boundaries of Lot 1 and Lot 2. This access easement right shall be held in common with the future owners of Lot 2 (as to access across Lot 1) and Lot 3, and Karona LLC.

#### **D.** Access Easement for Karona LLC Property

Karona LLC shall have a perpetual access easement across Lot 1, Lot 2, and Lot 3 to pass and repass by vehicle, foot, and other lawful modes of transportation over that portion of Artwill Avenue that is located within the boundaries of Lot 1, Lot 2 and Lot 3. This access easement right shall be held in common with the future owners of Lot 2 (as to access across Lot 1), Lot 3 (as to access across Lot 1 and Lot 2), and Chase (as to access across Lot 1 and Lot 2).

#### E. Easement Area Maintenance Responsibilities

The owners of Lot 1, Lot 2, Lot 3, the Chase Property and the Karona LLC Property (each a "Lot Owner" and collectively the "Lot Owners") shall be equally responsible to:

- (1) Remove snow, ice and debris from Artwill Avenue in a timely fashion if such service is not provided for by the City of Portsmouth;
- (2) Periodically inspect and assess the condition of Artwill Avenue;
- (3) Maintain, repair, replace and improve Artwill Avenue as necessary, in accordance with City standards for roadway maintenance, repair, replacement and/or improvement standards, to provide for safe and convenient access; and
- (4) Prohibit any encroachments from being located within Artwill Avenue that would interfere with, frustrate, or make difficult the intended use of the street as contemplated herein; and
- (5) Contribute equally to the costs associated with performing the obligations set forth herein.

#### F. Easement Area Financial Responsibilities

The Lot Owners shall be equally financially responsible for the necessary maintenance, repair, replacement and improvement of Artwill Avenue, except as otherwise provided for herein. If any Lot Owner incurs a greater share of costs associated with necessary maintenance, repair, replacement or improvement of the street as a result of any other Lot Owner's failure to contribute its share of the costs, the Lot Owner(s) paying the greater share of costs shall be entitled to reimbursement from the other Lot Owner(s) for their proportionate share of the costs within thirty (30) days of delivering written notice of the costs incurred together with receipts or other reasonable evidence thereof. If any written request for reimbursement remains unpaid beyond thirty (30) days from when written notice was delivered, the Lot Owner paying the greater share of costs may bring legal action to collect the unpaid balance against the other Lot Owner and shall be entitled to a lien for the same. The prevailing party in any such action shall be entitled to reasonable costs and attorney fees incurred.

#### II. UTILITY EASEMENTS

#### A. Wastewater Discharge

#### 1. Reservation of Easement for Lot 2 to Force Main

Artwill LLC hereby reserves a perpetual easement for the benefit of Lot 2 to discharge wastewater through the Force Main running through that portion of Artwill Avenue located within the boundaries of Lot 1. This easement right shall be held in common with the owners of the *benefiting lots*, as that term is more specifically defined below in Section 5. If any damage or

disturbance is caused to any portion of Artwill Avenue as a result of the owner of Lot 2 exercising its easement rights, including but not limited to maintenance or repair of any sewer pipe benefiting Lot 2, the owner shall comply with the obligations set forth in Section I.E(3) above, which is hereby incorporated by reference.

#### 2. Reservation of Easement for Lot 3 to Force Main

Artwill LLC hereby reserves a perpetual easement for the benefit of Lot 3 to discharge wastewater through the Force Main running through that portion of Artwill Avenue located within the boundaries of Lot 1 and Lot 2. This easement right shall be held in common with the owners of the *benefiting lots*, as that term is more specifically defined below in Section 5. If any damage or disturbance is caused to any portion of Artwill Avenue as a result of the owner of Lot 2 exercising its easement rights, including but not limited to maintenance or repair of any sewer pipe benefiting Lot 2, the owner shall comply with the obligations set forth in Section I.E(3) above, which is hereby incorporated by reference

#### 3. Reservation of Easement for Chase Property to Force Main

Artwill LLC hereby reserves a perpetual easement for the benefit of the Chase Property to install a sewer pipe through Lot 1 to connect to the Force Main, to discharge wastewater through the Force Main running through that portion of Artwill Avenue located within the boundaries of Lot 1, and to maintain, repair, replace and improve said sewer line. The right to discharge wastewater through the Force Main shall be held in common with the owners of the other *benefiting lots*.

The easement area shall be five feet (5') in width on either side of the sewer pipe running through Lot 1 to the point of connection to the Force Main. The owner of the Chase Property shall be responsible for restoring any damage or disturbance caused to Lot 1 after exercising their rights within the easement area and shall comply with the obligations set forth in Section I.E(3) above, which is hereby incorporated by reference.

#### 4. Reservation of Easement for Karona LLC Property to Force Main

Artwill LLC hereby reserves a perpetual easement for the benefit of the Karona LLC Property to install a sewer pipe through Lot 2 to connect to the Force Main, to discharge wastewater through the Force Main running through that portion of Artwill Avenue located within the boundaries of Lot 1 and Lot 2, and to maintain, repair, replace and improve said sewer line. The right to discharge wastewater through the Force Main shall be held in common with the owners of the other *benefiting lots*.

The easement area shall be five feet (5') in width on either side of the sewer pipe running through Lot 2 to the point of connection with the Force Main. The owner of the Karona LLC Property shall be responsible for restoring any damage or disturbance caused to Lot 2 after exercising their rights within the easement area and shall comply with the obligations set forth in Section I.E(3) above, which is hereby incorporated by reference.

#### 5. Easement in Common to Force Main

The owners of the *benefiting lots* (individually a "Lot Owner" and collectively the "Lot Owners") shall have an easement in common with one another a width of feet (5') on either side of the Force Main through Lot 1, Lot 2, and Lot 3 to perform necessary maintenance, repair, replacement and improvement to the Force Main. The Lot Owners shall be collectively responsible for performing necessary maintenance, repair, replacement and improvement to the Force Main.

For purposes of Section II of this Easement Agreement, "benefiting lots" shall mean those lots those that are actually connected to and discharge wastewater through the Force Main.

Any portions of Lot 1, Lot 2 or Lot 3 that are damaged or disturbed as a result of performing necessary maintenance, repair, replacement and improvement to the Force Main shall be restored by the Lot Owners within a reasonable time, in accordance with Section I.A(3) above, which is hereby incorporated by reference.

Each Lot Owner shall be individually responsible for the maintenance, repair, replacement and improvement of any sewer line or portion thereof benefiting their lot to the point of connection to the Force Main and any costs associated therewith.

#### 6. Easement Area Maintenance Responsibilities

The owners of the *benefiting lots* shall be equally responsible to:

- (a) Periodically inspect and assess the condition of the Force Main;
- (b) Maintain, repair, replace and improve the Force Main as necessary so that it functions properly for its intended purpose;
- (c) Prohibit any encroachments from being located within Artwill Avenue that would interfere with, frustrate, or make difficult access, maintenance, repair, replacement and improvement of the Force Main;
- (d) Contribute to the costs associated with performing the obligations set forth herein.

Any owner of a *benefiting lot* causing damage to the Force Main shall be responsible to the owners of the other *benefiting lots* for any repair costs.

#### 7. Easement Area Financial Responsibilities

The owners of the *benefiting lots* shall be equally financially responsible for the maintenance, repair, replacement and improvement of the Force Main, except as otherwise provided for herein. If any owner of a *benefiting lot* incurs a greater share of costs associated with necessary maintenance, repair, replacement or improvement of the Force Main as a result of any other *benefiting lot* owner's failure to contribute its share of the costs, the owner of the *benefiting* 

*lot* paying the greater share of costs shall be entitled to reimbursement from the other *benefiting lot* owners for their proportionate share of the costs within thirty (30) days of delivering written notice of the costs incurred together with receipts or other reasonable evidence thereof. If any written request for reimbursement remains unpaid beyond thirty (30) days from when written notice was delivered, the owner of the *benefiting lot* paying the greater share of costs may bring legal action to collect the unpaid balance against the other *benefiting lot* owners and shall be entitled to a lien for the same. The prevailing party in any such action shall be entitled to reasonable costs and attorney fees incurred.

#### **B.** Electricity

#### 1. Reservation of Reciprocal Easements for Lot 1 and Lot 2

Artwill LLC hereby reserves perpetual easements that are reciprocal in nature benefiting and burdening Lot 1 and Lot 2 for purposes of drawing electricity from any underground electric lines installed along the common boundary of Lot 1 and Lot 2. Said easements shall be subject to any future restrictions and obligations placed upon Lot 1, Lot 2 and Lot 3 by the utility company as a condition of supplying electricity through the underground electric lines.

#### 2. Reservation of Easement for Lot 3

Artwill LLC hereby reserves a perpetual easement for the benefit of Lot 3 for the purpose of drawing electricity from any underground electric lines installed along the common boundary of Lot 1 and Lot 2. The benefit of said easement shall be held in common with the owners of Lot 1 and Lot 2 and shall be subject to any future restrictions and obligations placed upon Lot 1, Lot 2 and Lot 3 by the utility company as a condition of supplying electricity through the underground electric lines.

#### III. MISCELLANOUS

#### A. Written Notice

Any written notice required under this Easement Agreement shall be valid if sent by certified mail or hand-delivered to the Party's last known address listed with the City of Portsmouth Assessing Department.

#### **B.** Amendment

This Easement Agreement and the rights contained herein may only be amended by written agreement of the Party(ies) that would be affected thereby, which agreement shall be recorded in the Rockingham County Registry of Deeds.

#### C. Bind and Inure

This Easement Agreement and the rights and obligations contained herein shall be binding upon and inure to the benefit of the Parties hereto and their respective heirs, successors and assigns.

#### D. Non-Contractual Transfer

This foregoing is a non-contractual transfer that is exempt from the New Hampshire Real Estate Transfer Tax pursuant to RSA 78-B:2, IX.

#### [SEPARATE SIGNATURE PAGES TO FOLLOW]

Executed this \_\_\_\_\_day of \_\_\_\_\_, 2022.

#### ARTWILL LLC

Joseph S. Caldarola, Member/Manager Duly Authorized

Nicola Douglass, Member/Manager Duly Authorized

#### STATE OF NEW HAMPSHIRE COUNTY OF ROCKINGHAM

This \_\_\_\_\_\_day of \_\_\_\_\_\_, 2022 personally appeared, Joseph S. Caldarola and Nicola Douglass, in their capacities as members/managers of Artwill LLC, duly authorized, known to me, or satisfactorily proven, to be the persons whose names are subscribed to the foregoing instrument and acknowledged that they executed the same for the purposes therein contained.

Before me,

Notary Public: Commission expires: Executed this \_\_\_\_\_day of \_\_\_\_\_, 2022.

#### KARONA LLC

[Insert Name] [Insert Title, Duly Authorized]

#### STATE OF NEW HAMPSHIRE COUNTY OF ROCKINGHAM

This \_\_\_\_\_\_day of \_\_\_\_\_\_, 2022 personally appeared, \_\_\_\_\_\_\_, in their capacity as member/manager of Karona LLC, duly authorized, known to me, or satisfactorily proven, to be the persons whose names is subscribed to the foregoing instrument and acknowledged that they executed the same for the purposes therein contained.

Before me,

Notary Public: Commission expires: Executed this \_\_\_\_\_day of \_\_\_\_\_, 2022.

Kristin M. Chase

Christopher M. Chase

#### STATE OF NEW HAMPSHIRE COUNTY OF ROCKINGHAM

This \_\_\_\_\_\_day of \_\_\_\_\_\_, 2022 personally appeared, Christopher M. Chase and Kristin M. Chase, known to me, or satisfactorily proven, to be the persons whose names are subscribed to the foregoing instrument and acknowledged that they executed the same for the purposes therein contained.

Before me,

Notary Public: Commission expires:

## DRAINAGE ANALYSIS

### FOR

# Proposed 3 Lot Subdivision

437 Lafayette Road Portsmouth, NH Rockingham County

Tax Map 229, Lot 1

April 19, 2022



**Prepared By:** 



Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists
## Contents

1.0 - SUMMARY & PROJECT DESCRIPTION	1
2.0 - CALCULATION METHODS	1
3.0 – EXISTING SITE CONDITIONS	2
4.0 - PRE-DEVELOPMENT CONDITIONS	3
5.0 - POST-DEVELOPMENT CONDITIONS	3
6.0 – REGULATORY COMPLIANCE	4
6.1 – ALTERATION OF TERRAIN (AOT) CRITERIA	
7.0 – BEST MANAGEMENT PRACTICES	5
7.1 – TEMPORARY PRACTICES5	
7.2 – PERMANENT PRACTICES6	
7.3 – BEST MANAGEMENT PRACTICE EFFICIENCIES6	
7.3.1 – LID PRACTICES	
8.0 – CONCLUSION	7
APPENDIX A – EXTREME PRECIPITATION RATES	
APPENDIX B – PRE-DEVELOPMENT CALCULATIONS	
APPENDIX C – PRE-DEVELOPMENT CALCULATIONS (10-YEAR STORM EVENT)	
APPENDIX D – POST-DEVELOPMENT CALCULATIONS	
APPENDIX E – POST-DEVELOPMENT CALCULATIONS (10-YEAR STORM EVENT)	
APPENDIX F - BMP WORKSHEETS	
APPENDIX G - RIRPRAP CALCULATIONS	
APPENDIX H - NRCS WEB SOILS SURVEY	
APPENDIX I - TEST PIT LOGS & INFILTRATION CALCULATIONS	
APPENDIX J – NHDES ONE STOP DATA MAPPER	
APPENDIX K – PRE AND POST-DEVELOPMENT DRAINAGE PLANS	
APPENDIX L – OPERATION AND MAINTENANCE MANUAL	

## Table of Figures

Table 1 – 24-Hour Rainfall Rates	2
Table 2 – Pre and Post Flows	3

## **1.0 - SUMMARY & PROJECT DESCRIPTION**

This project includes the subdivision of a single lot into three proposed lots, and the construction of two new homes. The existing lot is located at 437 Lafayette Road and is identified on the City of Portsmouth Assessor's Map 229 as Lot 1, and is approximately 65,365 sf (1.50 ac) in size. The site is located in the Single Residence B (SRB) Zone and currently contains one residential building. The site is bordered by Lafayette Road to the west, Andrew Jarvis Drive to the north, Artwill Avenue to the south, and Saint Nocholas Greek Orthodox Church to the east. The immediate area surrounding the site consists of mostly residential buildings, and the Portsmouth High School is located at the end of Andrew Jarvis Drive to the east.

The proposed subdivision includes three lots in total with access being provided through Artwill Avenue. The first lot is located at the intersection of Lafayette Road and Artwill Avenue and is 18,434 sf (0.42 ac) in size. A two-story residential house (1,832 sf footprint) is proposed on the first lot, with a screened porch and backyard patio area. The second lot is located in the middle of the subdivision and is 16,606 sf (0.38 ac) in size. This lot contains the existing one-story residential house (2,143 sf footprint). The existing house footprint is to remain the same in proposed conditions, and a new walkway is being proposed along the west property line. The third lot is located to the east of lot two and is 30,325 sf (0.70 ac) in size. A one-story residential house (4,249 sf footprint) is proposed on the third lot, with an attached accessory dwelling unit (AADU), backyard patio, and deck. The ADDU is located on the east side of the principle dwelling unit and has a gross area of 747 sf. Associated improvements include, but are not limited to, utility installation, stormwater management, grading, residential driveways, and landscaping.

This analysis has been completed to verify the project will not pose adverse stormwater effects on-site and off-site. The post-development stormwater management system has been designed to reduce peak runoff rates, runoff volume, risk of erosion and sedimentation, and to improve stormwater runoff quality. There is no increase in runoff from the post-development conditions compared to the pre-development conditions in any of the analyzed storm events. In addition, Best Management Practices will be employed to assure stormwater quality both during and after construction. The following summarizes the findings from the study.

### 2.0 - CALCULATION METHODS

The design storms analyzed in this study are the 2-year, 10-year, 25-year and 50-year 24-hour storm events. The software program, HydroCAD version 10.10-7a<sup>1</sup> was utilized to calculate the peak runoff rates from these storm events. The program estimates the peak rates using the TR-20 method. A Type III storm pattern was used in the model. Rainfall frequencies for the analyzed region were also incorporated into the model. Rainfall frequencies from the higher of the Extreme Precipitation Rates from Cornell University's Northeast Regional Climate Center (see Appendix A) were used to determine the storm-event intensities, see Table 1. The site lies within the Great Bay Region, and the rainfalls were increased to take this into account. Design standards were taken from the New Hampshire Stormwater Manual, December 2008<sup>2</sup>.

<sup>&</sup>lt;sup>1</sup> HydroCAD version 10.10-7a, HydroCAD Software Solutions LLC, Chocorua, NH, 2013.

<sup>&</sup>lt;sup>2</sup> New Hampshire Stormwater Manual: Volume One - Stormwater and Antidegradation, December 2008; Volume Two - Post-Construction Best Management Practices Selection and Design, December 2008; Volume Three - Erosion and Sediment Controls During Construction, December 2008.

	24-HOUR RAINFALL RATES									
Storm-Event (year)	Cornell University Rainfall (in)	Factor of Increase For the Great Bay Region	Design Rainfall (in)							
2	3.22	115%	3.70							
10	4.88	115%	5.61							
25	6.19	115%	7.12							
50	7.41	115%	8.52							

Table 1 – 24-Hour Rainfall Rates

Time of Concentration (Tc) is the time it takes for water to flow from the hydraulically most remote point in the watershed (with the longest travel time) to the watershed outlet. This time is determined by calculating the time it takes runoff to travel this route under one of three hydrologic conditions: sheet flow, shallow concentrated flow, or channel flow. Because the Intensity-Duration-Frequency (IDF) curve is steep with short Tc's, estimating the actual intensity is subject to error and overestimates actual runoff. Due to this, the Tc's are adjusted to a minimum of 6 minutes.

The proposed stormwater management system has been designed to capture the majority of new impervious area introduced to the site as part of this development, consisting of residential roofs, driveways, patios, and walkways. Within the drainage analysis limits, the amount of impervious area not treated in pre-development conditions (18,435 s.f.) is less than the impervious area not treated in post-development conditions (14,689 s.f.).

### 3.0 - EXISTING SITE CONDITIONS

The soils within the proposed area of disturbance are identified in accordance with the Natural Resources Conservation Service (NRCS) Web Soil Survey Report (see Appendix H). This report identifies the soils within the disturbed project area entirely as Urban Land-Canton Complex. The soil composition is estimated to consist of approximately 55% urban land, 20% canton and similar soils, and 25% minor components. This soil type is considered to be well drained and NRCS categorizes the soil as hydrologic soil group (HSG) A. Test pits were performed throughout the project site, and the western half of the existing lot displayed significantly higher infiltration rates than the eastern half. To account for these field observations, the western half of the analysis area was modeled as HSG-A soils and the eastern half as HSG-B soils in both pre- and post-development conditions.

Due to existing grade along the north and west borders of the subject lot, very minimal runoff enters the project analysis area from off-site locations. The site currently drains to the southeast corner of the property to a flatter area where runoff ultimately discharges to adjacent properties to the south and east. The NRCS Web Soil Survey Report identifies an area downstream of the analysis limits as Udorthents (smoothed). Limited information is provided with regards to this soil's physical and hydrologic attributes.

#### 4.0 - PRE-DEVELOPMENT CONDITIONS

The pre-development condition is characterized by three watersheds. Pre-development subcatchment areas are depicted on the attached plan entitled "Pre-Development Drainage Map," Sheet D-01 (see Appendix K).

Stormwater runoff from the site that does not infiltrate into the ground, drains to the southeast corner of the site to existing point of interest (EPOI-01). Runoff throughout the existing site is generated from grassed and paved areas, as well as the roof of the existing house.

In the pre-development conditions, the total impervious area is 18,434 sf over a total drainage analysis area of 65,306 sf.

#### 5.0 - POST-DEVELOPMENT CONDITIONS

The post-development condition is characterized by seven watersheds. Post-development subcatchment areas are depicted on the attached plan entitled "Post-Development Drainage Map," sheet D-02 (see Appendix K).

In the post-development condition, the total impervious area is 23,198 sf over a total drainage analysis area of 65,306 sf. Impervious area from the project consists of three residential buildings, driveways, patios, decks, walkways, and pavement on Artwill Avenue. Four raingardens are proposed to treat and mitigate the stormwater runoff from the impact of the new impervious area from the proposed development.

The proposed project maintains or reduces peak rates of runoff compared to existing conditions for all storm events, in accordance with City stormwater regulations. For Channel protection, the State Regulations require analysis between the pre-development to post-development 2-year 24-hour storm event volumes that flow into major water bodies. In post-development condition, there is not an increase in in runoff volume during the 2-year 24-hour storm event, and there are no adverse effects on the abutting properties from the proposed stormwater management system. See Table 2 for storm event flow and volume summary.

Appendices B and D summarizes all 24-hour storm events for pre- and post-development drainage calculations using HydroCAD analysis. Appendices C and E provide a full summary of the 10-year, 24-hour storm for the pre- and post-development drainage calculations using HydroCAD analysis.

Analysis	2-Y	ear	2-۲	∕ear	10-	Year	25-۱	/ear	50-Year		
Point ID	(Flow	- cfs)	Volume)	– acre/ft)	(Flov	v - cfs)	(Flow	- cfs)	(Flow - cfs)		
	Pre-	Post	Pre-	Post	Pre-	Post	Pre-	Post	Pre-	Post	
	Dev.	Dev.	Dev.	Dev.	Dev.	Dev.	Dev.	Dev.	Dev.	Dev.	
POI-1	1.9	1.2	0.2	0.1	3.6	3.0	5.3	5.1	7.0	6.5	

### Table 2- Pre and Post Flows

## 6.0 - REGULATORY COMPLIANCE

The project shall meet the stricter of the stormwater standards identified in the New Hampshire Department of Environmental Services (DES) Env-Wq 1500 Alteration of Terrain Regulations and City stormwater management regulations.

#### 6.1 - ALTERATION OF TERRAIN (AOT) CRITERIA

The following regulatory requirements are provided to show the project conformance to the applicable criteria of the NHDES Env-Wq 1500 Alteration of Terrain Regulations which include and are not limited to the following:

<u>Env-Wq 1507.03(a)</u> Pollutant Discharge Minimization Requirements: Stormwater treatment practices described in Env-Wq 1508.03 through Env-Wq 1508.10 shall be acceptable methods for minimizing pollutant discharges to surface waters.

Stormwater is treated using bioretention systems which are considered a filtration BMP. Specifically, there are a total of four rain gardens throughout the site that provide filtration treatment and have the ability to infiltrate some runoff into the ground. The rain gardens are designed in accordance with the applicable criteria of Env-Wq 1508.06 as follows:

Per 1508.06(e), the volume of the practice shall be large enough to contain the WQV without depending on infiltration. Refer to the corresponding BMP Worksheet in Appendix F for verification.

Per 1508.06(f), the practice completely drains the WQV within 72 hours or less. Refer to the corresponding BMP Worksheet in Appendix F for verification.

# <u>Env-Wq 1507.03(c)</u> Pollutant Discharge Minimization Requirements: Stormwater treatment practices shall be designed with infiltration rates in accordance with Env-Wq 1504.14

Per 1508.06(a), the design infiltration rate of underlaying native soil was considered in accordance with Env-Wq 1504.14. The design infiltration rate for each subsurface infiltration basin is the average from each infiltration test in each basin. Refer to the corresponding Infiltration Rate Calculations in Appendix I for verification.

<u>Env-Wq 1507.03(e)</u> Pollutant Discharge Minimization Requirements: Stormwater treatment practices shall be designed for the WQV/WQF, calculated in accordance with Env-Wq 1504.10 and Env-Wq 1504.11.

The regulation is met. Refer to the corresponding BMP Worksheets in Appendix F.

<u>Env-Wq 1507.04(a)</u> Groundwater Recharge Requirements: The proposed development shall reduce to the maximum extent practicable by using groundwater recharge practices as described in Env-Wq 1508.16.

The regulation is met. Refer to the corresponding BMP Worksheet in Appendix F for verification.

<u>Env-Wq 1507.04(c)</u> Groundwater Recharge Requirements: Design Infiltration rates for groundwater recharge practices shall be determined in accordance with Env-Wq 1504.14.

Design infiltration rates were obtained per Ksat testing using a Constant Compact Head Permeameter (Amoozemeter) per Env-Wq 1504.14(d). The design infiltration rate for each subsurface infiltration basin is the average from each infiltration test in each basin. Refer to the corresponding Infiltration Rate Calculations in Appendix I for verification.

<u>Env-Wq 1507.05</u> Channel Protection Requirements: The 2-year 24-hour post development peak rate shall not exceed the pre-development peak flow rate for all flows leaving the site and the conditions of Env-Wq 1507.05(b), Env-Wq 1507.05(b)(2), or Env-Wq 1507.05(b)(3).

The 2-year, 24-hour post-development peak flow rate generated from the proposed disturbance is equal to or less than the 2-year, 24-hour pre-development peak flow rate and the 2 year, 24-hour post-development storm volume, directed to the nearest water body has not increased over the pre-development volume by more than 0.1 acre-feet.

The regulation is met. Refer to Table 2 for peak discharge rate and 2-year stormwater volume comparisons.

<u>Env-Wq 1507.06</u> Control Peak Runoff: The 2-year, 10-year and 50-year 24-hour post development peak rate shall not exceed the pre-development peak flow rate for all flows leaving the site.

The regulation is met. Refer to Table 2 for peak discharge rate comparison.

#### 7.0 - BEST MANAGEMENT PRACTICES

Best Management Practices will be developed in accordance with the *New Hampshire Stormwater Manual, Volumes Two and Three, December 2008*<sup>3</sup> to formulate a plan that assures stormwater quality both during and after construction. The intent of the outlined measures is to minimize erosion and sedimentation during construction, stabilize and protect the site from erosion after construction is complete and mitigate any adverse impacts to stormwater quality resulting from development. Best Management Practices for this project include:

- Temporary practices to be implemented during construction.
- Permanent practices to be implemented after construction.

#### 7.1 – TEMPORARY PRACTICES

- 1. Erosion, sediment, and stormwater detention measures must be installed as directed by the engineer.
- 2. All disturbed areas, as well as loam stockpiles, shall be seeded and contained by a silt barrier.
- 3. Silt barriers must be installed prior to any construction commencing. All erosion control devices including silt barriers and storm drain inlet filters shall be inspected

<sup>&</sup>lt;sup>3</sup> New Hampshire Stormwater Manual: Volume One - Stormwater and Antidegradation, December 2008; Volume Two - Post-Construction Best Management Practices Selection and Design, December 2008; Volume Three - Erosion and Sediment Controls During Construction, December 2008.

at least once per week and following any rainfall. All necessary maintenance shall be completed within twenty-four (24) hours.

- 4. Any silt barriers found to be failing must be replaced immediately. Sediment is to be removed from behind the silt fence if found to be one-third the height of the silt barrier or greater.
- 5. Any area of the site, which has been disturbed and where construction activity will not occur for more than twenty-one (21) days, shall be temporarily stabilized by mulching and seeding.
- 6. No construction materials shall be buried on-site.
- 7. After all areas have been stabilized, temporary practices are to be removed, and the area they are removed from must be smoothed and revegetated.
- 8. Areas must be temporarily stabilized within 14 days of disturbance or seeded and mulched within 3 days of final stabilization.
- 9. After November 15<sup>th</sup>, incomplete driveways or parking areas must be protected with a minimum of 3" of crushed gravel, meeting the standards of NHDOT item 304.3.
- 10. An area shall be considered stable if one of the following has occurred:
  - a) Base course gravels are installed in areas to be paved.
  - b) A minimum of 85% vegetated growth has been established.
  - c) A minimum of 3" of non-erosive material such as stone or rip rap has been installed.
  - d) Erosion control blankets have been properly installed.

### 7.2 – PERMANENT PRACTICES

The objectives for developing permanent Best Management Practices for this site include the following:

- 1. Maintain existing runoff flow characteristics.
  - a) Drainage is structured to minimize any offsite increase in runoff.
- 2. Treatment BMP's are established to ensure the water quality.
- 3. Maintenance schedules are set to safeguard the long term working of the stormwater BMP's.

A Stormwater Management Operations & Maintenance Manual is provided to ensure the proper functioning of the system over time.

#### 7.3 – BEST MANAGEMENT PRACTICE EFFICIENCIES

Appendix E of Volume 2 of the New Hampshire Stormwater <sup>4</sup> lists the pollutant removal efficiencies of various BMP's. All proposed BMP's meet all state and City requirements for

<sup>&</sup>lt;sup>4</sup> New Hampshire Stormwater Manual: Volume One - Stormwater and Antidegradation, December 2008; Volume Two - Post-Construction Best Management Practices Selection and Design, December 2008; Volume Three - Erosion and Sediment Controls During Construction, December 2008.

total suspended solids (TSS) and pollutant removal, Total Nitrogen (TN), and Total Phosphorous (TP).

Bioretention Systems (rain gardens) have a 90% TSS removal efficiency, 65% TN removal efficiency, and 65% TP efficiency.

Proposed Rain Gardens #1-4 receive runoff from yards, residential roofs, and potions of residential driveways. Due to the nature of the areas contributing runoff to the rain gardens, no pretreatment is required.

### 7.3.1 - LID PRACTICES

Bioretention Areas, including rain gardens, are considered to be a Low Impact Design (LID) filtering practice. The goal of LID systems is to mimic a site's precondition hydrology by infiltrating, filtering, storming, evaporating and detaining stormwater but use of natural landscape features. These treatments filter and detain the stormwater. They use natural processes, such as soil filtration, evapotranspiration (from the vegetation in the system) and anaerobic and aerobic treatment of stormwater. They detain the stormwater and release it to mimic the predevelopment storm flows.

The inclusion of rain gardens in the proposed site design allows for stormwater to infiltrate back into the ground. During heavier storm events, a perforated subdrain located below each rain garden's filtration layer has the ability to convey treated flows to other areas on-site to prevent extended ponding periods. Each rain garden is equipped with an outlet control structure that regulates discharge rates during these heavier storms through the implementation of orifices and overflow grates.

### 8.0 - CONCLUSION

The proposed stormwater management system will treat, infiltrate, and mitigate the runoff generated from the proposed development and provide protection of groundwater and surface waters as required through the Alteration of Terrain Bureau and City stormwater management regulations. Furthermore, the stormwater management for this project has been designed to pose no adverse effects on the surrounding properties.

Respectfully, **TFMoran, Inc.** 

uter Mult

Justin Macek, EIT Project Manager

# **APPENDIX A – EXTREME PRECIPITATION RATES**

## **Extreme Precipitation Tables**

## Northeast Regional Climate Center

Data represents point estimates calculated from partial duration series. All precipitation amounts are displayed in inches.

Smoothing	Yes
State	New Hampshire
Location	
Longitude	70.769 degrees West
Latitude	43.058 degrees North
Elevation	0 feet
Date/Time	Fri, 07 Jan 2022 14:42:09 -0500

## **Extreme Precipitation Estimates**

	5min	10min	15min	30min	60min	120min		1hr	2hr	3hr	6hr	12hr	24hr	48hr		1day	2day	4day	7day	10day	
1yr	0.26	0.40	0.50	0.65	0.82	1.04	1yr	0.70	0.98	1.21	1.56	2.03	2.66	2.93	1yr	2.36	2.82	3.23	3.95	4.56	1yr
2yr	0.32	0.50	0.62	0.81	1.02	1.30	2yr	0.88	1.18	1.52	1.94	2.49	3.22	3.58	2yr	2.85	3.44	3.94	4.69	5.34	2yr
5yr	0.37	0.58	0.73	0.98	1.25	1.61	5yr	1.08	1.47	1.89	2.43	3.14	4.08	4.59	5yr	3.61	4.41	5.05	5.95	6.72	5yr
10yr	0.41	0.65	0.82	1.12	1.45	1.89	10yr	1.25	1.73	2.23	2.90	3.76	<mark>4.88</mark>	5.54	10yr	4.32	5.33	6.10	7.12	8.00	10yr
25yr	0.48	0.76	0.97	1.34	1.77	2.34	25yr	1.53	2.14	2.78	3.63	4.75	<mark>6.19</mark>	7.12	25yr	5.47	6.84	7.82	9.05	10.08	25yr
50yr	0.54	0.86	1.10	1.54	2.07	2.76	50yr	1.79	2.53	3.29	4.33	5.67	7.41	8.60	50yr	6.56	8.27	9.45	10.84	12.01	50yr
100yr	0.60	0.97	1.25	1.77	2.42	3.26	100yr	2.09	2.98	3.91	5.16	6.78	8.88	10.40	100yr	7.85	10.00	11.42	13.00	14.31	100yr
200yr	0.67	1.10	1.43	2.05	2.83	3.84	200yr	2.44	3.52	4.62	6.14	8.10	10.64	12.58	200yr	9.41	12.10	13.80	15.59	17.07	200yr
500yr	0.80	1.31	1.71	2.49	3.48	4.77	500yr	3.00	4.38	5.77	7.72	10.24	13.52	16.18	500yr	11.96	15.56	17.73	19.84	21.56	500yr

## **Lower Confidence Limits**

	5min	10min	15min	30min	60min	120min		1hr	2hr	3hr	6hr	12hr	24hr	48hr		1day	2day	4day	7day	10day	
1yr	0.23	0.36	0.44	0.59	0.73	0.88	1yr	0.63	0.86	0.92	1.33	1.68	2.24	2.51	1yr	1.98	2.42	2.87	3.18	3.90	1yr
2yr	0.32	0.49	0.60	0.81	1.00	1.19	2yr	0.86	1.16	1.37	1.82	2.34	3.06	3.46	2yr	2.71	3.33	3.83	4.56	5.09	2yr
5yr	0.35	0.54	0.67	0.92	1.17	1.40	5yr	1.01	1.37	1.61	2.12	2.73	3.80	4.21	5yr	3.36	4.05	4.73	5.55	6.26	5yr
10yr	0.39	0.59	0.74	1.03	1.33	1.60	10yr	1.15	1.57	1.81	2.39	3.06	4.39	4.88	10yr	3.88	4.70	5.47	6.44	7.22	10yr
25yr	0.44	0.67	0.83	1.19	1.56	1.90	25yr	1.35	1.86	2.10	2.76	3.54	4.73	5.93	25yr	4.19	5.70	6.69	7.84	8.72	25yr
50yr	0.48	0.73	0.91	1.31	1.77	2.17	50yr	1.53	2.12	2.35	3.07	3.93	5.35	6.85	50yr	4.73	6.58	7.78	9.10	10.07	50yr
100yr	0.54	0.81	1.02	1.47	2.02	2.47	100yr	1.74	2.42	2.63	3.41	4.35	6.01	7.91	100yr	5.32	7.61	9.06	10.58	11.63	100yr
200yr	0.59	0.89	1.13	1.64	2.29	2.82	200yr	1.97	2.75	2.94	3.78	4.79	6.74	9.14	200yr	5.97	8.79	10.54	12.32	13.45	200yr
500yr	0.69	1.02	1.32	1.92	2.72	3.37	500yr	2.35	3.29	3.41	4.31	5.46	7.85	11.06	500yr	6.94	10.63	12.87	15.10	16.29	500yr

## **Upper Confidence Limits**

	5min	10min	15min	30min	60min	120min		1hr	2hr	3hr	6hr	12hr	24hr	48hr		1day	2day	4day	7day	10day	
1yr	0.29	0.44	0.54	0.72	0.89	1.08	1yr	0.77	1.06	1.26	1.74	2.20	2.99	3.16	1yr	2.65	3.04	3.59	4.38	5.06	1yr
2yr	0.34	0.52	0.64	0.86	1.07	1.27	2yr	0.92	1.24	1.48	1.96	2.51	3.43	3.71	2yr	3.04	3.56	4.09	4.84	5.64	2yr
5yr	0.40	0.62	0.77	1.05	1.34	1.62	5yr	1.15	1.58	1.88	2.53	3.25	4.35	4.96	5yr	3.85	4.77	5.39	6.38	7.16	5yr
10yr	0.47	0.72	0.89	1.25	1.61	1.98	10yr	1.39	1.93	2.28	3.10	3.95	5.35	6.20	10yr	4.73	5.96	6.81	7.84	8.75	10yr
25yr	0.58	0.88	1.09	1.56	2.05	2.57	25yr	1.77	2.51	2.95	4.07	5.14	7.80	8.33	25yr	6.90	8.01	9.13	10.34	11.41	25yr
50yr	0.67	1.02	1.27	1.83	2.46	3.13	50yr	2.12	3.06	3.59	5.00	6.31	9.76	10.44	50yr	8.64	10.04	11.41	12.72	13.96	50yr
100yr	0.79	1.19	1.49	2.16	2.96	3.81	100yr	2.55	3.72	4.37	6.15	7.75	12.21	13.07	100yr	10.81	12.57	14.25	15.68	17.08	100yr
200yr	0.92	1.39	1.76	2.55	3.55	4.65	200yr	3.07	4.55	5.33	7.57	9.51	15.32	16.39	200yr	13.56	15.76	17.82	19.33	20.90	200yr
500yr	1.15	1.70	2.19	3.19	4.53	6.04	500yr	3.91	5.90	6.92	10.01	12.52	20.70	22.10	500yr	18.32	21.25	23.96	25.47	27.32	500yr



# <u>APPENDIX B – PRE-DEVELOPMENT</u> <u>CALCULATIONS</u>



## 45407-120\_Pre & Post Development

Prepared by TFMoran Inc.	Printed 4/18/2022
HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC	Page 1

## Area Listing (selected nodes)

Area	CN	Description
(acres)		(subcatchment-numbers)
0.03	68	<50% Grass cover, Poor, HSG A (ES01)
0.04	79	<50% Grass cover, Poor, HSG B (ES02)
0.30	39	>75% Grass cover, Good, HSG A (ES01, ES03)
0.63	61	>75% Grass cover, Good, HSG B (ES02, ES03)
0.12	98	Paved parking, HSG A (ES01)
0.17	98	Paved parking, HSG B (ES02, ES03)
0.08	98	Roofs, HSG A (ES01, ES03)
0.06	98	Roofs, HSG B (ES02)
0.08	60	Woods, Fair, HSG B (ES02, ES03)
1.50	68	TOTAL AREA

## 45407-120\_Pre & Post Development

Prepared by TFMoran Inc. HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC Printed 4/18/2022 Page 2

## Soil Listing (selected nodes)

Area	Soil	Subcatchment
(acres)	Group	Numbers
0.53	HSG A	ES01, ES03
0.97	HSG B	ES02, ES03
0.00	HSG C	
0.00	HSG D	
0.00	Other	
1.50		TOTAL AREA

	Pre	-Developmen	t Drainage
45407-120_Pre & Post Development	Type III 24-hr	<mark>2-Year</mark> Rail	nfall=3.70"
Prepared by TFMoran Inc.		Printed	4/18/2022
HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions	LLC		Page 3

SubcatchmentES01: ES-01	Runoff Area=19,795 sf 29.23% Impervious Runoff Depth>1.10" Flow Length=165' Tc=6.5 min CN=WQ Runoff=0.5 cfs 0.0 af
SubcatchmentES02: ES-02	Runoff Area=38,970 sf 17.93% Impervious Runoff Depth>1.20" Flow Length=286' Tc=7.6 min CN=WQ Runoff=1.0 cfs 0.1 af
SubcatchmentES03: ES-03	Runoff Area=6,541 sf 86.52% Impervious Runoff Depth>3.05" Flow Length=390' Tc=6.0 min CN=WQ Runoff=0.5 cfs 0.0 af
Reach ER01: ER-01	Avg. Flow Depth=0.06' Max Vel=1.36 fps Inflow=0.5 cfs 0.0 af n=0.023 L=250.0' S=0.0220 '/' Capacity=23.0 cfs Outflow=0.5 cfs 0.0 af
Link EPOI01: EPOI-01	(Inflow=1.9 cfs) (0.2 af

Primary=1.9 cfs 0.2 af

Total Runoff Area = 1.50 ac Runoff Volume = 0.2 af Average Runoff Depth = 1.36" 71.77% Pervious = 1.08 ac 28.23% Impervious = 0.42 ac

	Pre-Development Drainage
45407-120_Pre & Post Development	Type III 24-hr <mark>10-Year</mark> Rainfall=5.61"
Prepared by TFMoran Inc.	Printed 4/18/2022
HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software So	olutions LLC Page 4
	-

SubcatchmentES01: ES-01	Runoff Area=19,795 sf 29.23% Impervious Runoff Depth>1.95" Flow Length=165' Tc=6.5 min CN=WQ Runoff=0.8 cfs 0.1 af
SubcatchmentES02: ES-02	Runoff Area=38,970 sf 17.93% Impervious Runoff Depth>2.45" Flow Length=286' Tc=7.6 min CN=WQ Runoff=2.2 cfs 0.2 af
SubcatchmentES03: ES-03	Runoff Area=6,541 sf 86.52% Impervious Runoff Depth>4.81" Flow Length=390' Tc=6.0 min CN=WQ Runoff=0.7 cfs 0.1 af
Reach ER01: ER-01	Avg. Flow Depth=0.08' Max Vel=1.61 fps Inflow=0.8 cfs 0.1 af n=0.023 L=250.0' S=0.0220 '/' Capacity=23.0 cfs Outflow=0.7 cfs 0.1 af
Link EPOI01: EPOI-01	Inflow=3.6 cfs 0.3 af

Primary=3.6 cfs 0.3 af

Total Runoff Area = 1.50 acRunoff Volume = 0.3 afAverage Runoff Depth = 2.54"71.77% Pervious = 1.08 ac28.23% Impervious = 0.42 ac

	Pr	e-Developmen	t Drainage
45407-120_Pre & Post Development	Type III 24-hr	<mark>25-Year</mark> Rail	nfall=7.12"
Prepared by TFMoran Inc.		Printed	4/18/2022
HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solution	ns LLC		Page 5

SubcatchmentES01: ES-01	Runoff Area=19,795 sf 29.23% Impervious Runoff Depth>2.77" Flow Length=165' Tc=6.5 min CN=WQ Runoff=1.1 cfs 0.1 af
SubcatchmentES02: ES-02	Runoff Area=38,970 sf 17.93% Impervious Runoff Depth>3.58" Flow Length=286' Tc=7.6 min CN=WQ Runoff=3.3 cfs 0.3 af
SubcatchmentES03: ES-03	Runoff Area=6,541 sf 86.52% Impervious Runoff Depth>6.22" Flow Length=390' Tc=6.0 min CN=WQ Runoff=0.9 cfs 0.1 af
Reach ER01: ER-01	Avg. Flow Depth=0.10' Max Vel=1.83 fps Inflow=1.1 cfs 0.1 af n=0.023 L=250.0' S=0.0220 '/' Capacity=23.0 cfs Outflow=1.1 cfs 0.1 af
Link EPOI01: EPOI-01	<mark>(Inflow=5.3 cfs</mark> ) 0.4 af Primary=5.3 cfs) 0.4 af

Total Runoff Area = 1.50 acRunoff Volume = 0.5 afAverage Runoff Depth = 3.60"71.77% Pervious = 1.08 ac28.23% Impervious = 0.42 ac

	Pre-Development Drainage
45407-120_Pre & Post Development	Type III 24-hr <mark>50-Year</mark> Rainfall=8.52"
Prepared by TFMoran Inc.	Printed 4/18/2022
HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software So	olutions LLC Page 6
	-

SubcatchmentES01: ES-01	Runoff Area=19,795 sf 29.23% Impervious Runoff Depth>3.63" Flow Length=165' Tc=6.5 min CN=WQ Runoff=1.6 cfs 0.1 af
SubcatchmentES02: ES-02	Runoff Area=38,970 sf 17.93% Impervious Runoff Depth>4.71" Flow Length=286' Tc=7.6 min CN=WQ Runoff=4.4 cfs 0.4 af
SubcatchmentES03: ES-03	Runoff Area=6,541 sf 86.52% Impervious Runoff Depth>7.55" Flow Length=390' Tc=6.0 min CN=WQ Runoff=1.1 cfs 0.1 af
Reach ER01: ER-01	Avg. Flow Depth=0.12' Max Vel=2.03 fps Inflow=1.6 cfs 0.1 af n=0.023 L=250.0' S=0.0220 '/' Capacity=23.0 cfs Outflow=1.5 cfs 0.1 af
Link EPOI01: EPOI-01	Inflow=7.0 cfs 0.6 af

Primary=7.0 cfs 0.6 af

Total Runoff Area = 1.50 acRunoff Volume = 0.6 afAverage Runoff Depth = 4.67"71.77% Pervious = 1.08 ac28.23% Impervious = 0.42 ac

## <u>APPENDIX C – PRE-DEVELOPMENT</u> CALCULATIONS (10-YEAR STORM EVENT)

#### Summary for Subcatchment ES01: ES-01

Runoff = 0.8 cfs @ 12.09 hrs, Volume= 0.1 af, Depth> 1.95" Routed to Reach ER01 : ER-01

Runoff by SCS TR-20 method, UH=SCS, Weighted-Q, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Type III 24-hr 10-Year Rainfall=5.61"

A	rea (sf)	CN I	Description						
	12,608	39 :	39 >75% Grass cover, Good, HSG A						
	1,400	68 ·	<50% Gras	s cover, Po	or, HSG A				
	664	98 I	Roofs, HSG	βA					
	5,123	98 I	Paved park	ing, HSG A					
	19,795	١	Neighted A	verage					
	14,008	-	70.77% Pei	vious Area					
	5,787		29.23% Imp	pervious Are	ea				
Тс	Length	Slope	Velocity	Capacity	Description				
(min)	(feet)	(ft/ft)	(ft/sec)	(cfs)					
6.1	100	0.0550	0.27		Sheet Flow, Grass Yard				
					Grass: Short n= 0.150 P2= 3.70"				
0.4	65	0.0230	3.08		Shallow Concentrated Flow, Grass Yard				
					Paved Kv= 20.3 fps				
6.5	165	Total							

#### Summary for Subcatchment ES02: ES-02

Runoff = 2.2 cfs @ 12.11 hrs, Volume= 0.2 af, Depth> 2.45" Routed to Link EPOI01 : EPOI-01

Runoff by SCS TR-20 method, UH=SCS, Weighted-Q, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Type III 24-hr 10-Year Rainfall=5.61"

Area (sf)	CN	Description
26,796	61	>75% Grass cover, Good, HSG B
1,553	79	<50% Grass cover, Poor, HSG B
3,632	60	Woods, Fair, HSG B
2,444	98	Roofs, HSG B
4,545	98	Paved parking, HSG B
38,970		Weighted Average
31,981		82.07% Pervious Area
6,989		17.93% Impervious Area
1,553 3,632 2,444 4,545 38,970 31,981 6,989	79 60 98 98	Voods, Fair, HSG B Roofs, HSG B Paved parking, HSG B Weighted Average 82.07% Pervious Area 17.93% Impervious Area

<b>45407-</b> Prepare	<b>120_Pre</b> d by TFI	<b>e &amp; Pos</b> Moran In	<b>t Develo</b> c.	Pre-Development Drainage 10-Year "Type III 24-hr 10-Year Rainfall=5.61 Printed 4/18/2022	
HydroCA	D® 10.10	-7a_s/n_00	)866 © 202	21 HydroCAI	D Software Solutions LLC Page 2
Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
5.4	100	0.0750	0.31		Sheet Flow, Grass Yard (East) Grass: Short n= 0.150 P2= 3.70"
1.7	141	0.0375	1.36		Shallow Concentrated Flow, Grass Yard (East) Short Grass Pasture Ky= 7.0 fps

7.6 286 Total

45 0.0750

0.5

## Summary for Subcatchment ES03: ES-03

**Shallow Concentrated Flow, Brush** 

Woodland Kv= 5.0 fps

Runoff = 0.7 cfs @ 12.09 hrs, Volume= 0.1 af, Depth> 4.81" Routed to Link EPOI01 : EPOI-01

1.37

Runoff by SCS TR-20 method, UH=SCS, Weighted-Q, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Type III 24-hr 10-Year Rainfall=5.61"

A	rea (sf)	CN I	Description						
	525	61 >75% Grass cover, Good, HSG B							
	0	79 ·	79 <50% Grass cover, Poor, HSG B						
	0	98	Roofs, HSC	βB					
	2,744	98	Paved park	ing, HSG E	6				
	337	39 :	>75% Gras	s cover, Go	bod, HSG A				
	2,915	98	Roofs, HSC	β A					
	20	60	Noods, Fai	r, HSG B					
	6,541	1	Neighted A	verage					
	882		13.48% Pei	rvious Area					
	5,659	8	36.52% Imp	pervious Ar	ea				
_		<u> </u>							
Тс	Length	Slope	Velocity	Capacity	Description				
Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description				
Tc (min) 0.8	Length (feet) 100	Slope (ft/ft) 0.0425	Velocity (ft/sec) 2.00	Capacity (cfs)	Description Sheet Flow, Paved Road				
Tc (min) 0.8	Length (feet) 100	Slope (ft/ft) 0.0425	Velocity (ft/sec) 2.00	Capacity (cfs)	Description Sheet Flow, Paved Road Smooth surfaces n= 0.011 P2= 3.70"				
Tc (min) 0.8 1.0	Length (feet) 100 190	Slope (ft/ft) 0.0425 0.0250	Velocity (ft/sec) 2.00 3.21	Capacity (cfs)	Description Sheet Flow, Paved Road Smooth surfaces n= 0.011 P2= 3.70" Shallow Concentrated Flow, Paved Road				
Tc (min) 0.8 1.0	Length (feet) 100 190	Slope (ft/ft) 0.0425 0.0250	Velocity (ft/sec) 2.00 3.21	Capacity (cfs)	Description Sheet Flow, Paved Road Smooth surfaces n= 0.011 P2= 3.70" Shallow Concentrated Flow, Paved Road Paved Kv= 20.3 fps				
Tc (min) 0.8 1.0 1.8	Length (feet) 100 190 100	Slope (ft/ft) 0.0425 0.0250 0.0170	Velocity (ft/sec) 2.00 3.21 0.91	Capacity (cfs)	Description         Sheet Flow, Paved Road         Smooth surfaces n= 0.011 P2= 3.70"         Shallow Concentrated Flow, Paved Road         Paved Kv= 20.3 fps         Shallow Concentrated Flow, Grass Shoulder				
Tc (min) 0.8 1.0 1.8	Length (feet) 100 190 100	Slope (ft/ft) 0.0425 0.0250 0.0170	Velocity (ft/sec) 2.00 3.21 0.91	Capacity (cfs)	Description         Sheet Flow, Paved Road         Smooth surfaces n= 0.011 P2= 3.70"         Shallow Concentrated Flow, Paved Road         Paved Kv= 20.3 fps         Shallow Concentrated Flow, Grass Shoulder         Short Grass Pasture Kv= 7.0 fps				
Tc (min) 0.8 1.0 1.8 2.4	Length (feet) 100 190 100	Slope (ft/ft) 0.0425 0.0250 0.0170	Velocity (ft/sec) 2.00 3.21 0.91	Capacity (cfs)	Description         Sheet Flow, Paved Road         Smooth surfaces n= 0.011 P2= 3.70"         Shallow Concentrated Flow, Paved Road         Paved Kv= 20.3 fps         Shallow Concentrated Flow, Grass Shoulder         Short Grass Pasture Kv= 7.0 fps         Direct Entry, Min Tc				

## Summary for Reach ER01: ER-01

The Manning's Number used is an average of rough pavement and short grassed area. The reach channel is off the shoulder of the road in grassed area, however as the channel water elevation rises, pavement is introduced to the channel side slopes.



Inflow A	Area =	= 1.50 ac,	28.23% Impe	ervious,	Inflow Depth >	2.53" fo	r 10-Year event
Inflow	=	3.6 cfs @	) 12.11 hrs,	Volume=	= 0.3 af		
Primary	y =	3.6 cfs @	) 12.11 hrs,	Volume=	= 0.3 af,	Atten= 0	%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs

# <u>APPENDIX D – POST-DEVELOPMENT</u> <u>CALCULATIONS</u>



April 19, 2022

## 45407-120\_Pre & Post Development

Prepared by TFMoran Inc. Printer HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC

Printed 4/18/2022 Page 1

## Area Listing (selected nodes)

Area	CN	Description
(acres)		(subcatchment-numbers)
0.04	68	<50% Grass cover, Poor, HSG A (PS01, PS02, PS07)
0.04	79	<50% Grass cover, Poor, HSG B (PS04, PS05, PS06)
0.30	39	>75% Grass cover, Good, HSG A (PS01, PS02, PS03, PS07)
0.54	61	>75% Grass cover, Good, HSG B (PS03, PS04, PS05, PS06)
0.06	98	Paved parking, HSG A (PS01, PS02, PS07)
0.20	98	Paved parking, HSG B (PS03, PS04, PS05, PS06)
0.13	98	Roofs, HSG A (PS01, PS02, PS03, PS07)
0.14	98	Roofs, HSG B (PS04, PS05, PS06)
0.04	60	Woods, Fair, HSG B (PS03, PS04)
1.50	70	TOTAL AREA
# 45407-120\_Pre & Post Development

Prepared by TFMoran Inc. HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC Printed 4/18/2022 Page 2

# Soil Listing (selected nodes)

Area	Soil	Subcatchment
(acres)	Group	Numbers
0.53	HSG A	PS01, PS02, PS03, PS07
0.97	HSG B	PS03, PS04, PS05, PS06
0.00	HSG C	
0.00	HSG D	
0.00	Other	
1.50		TOTAL AREA

<b>45407-120_Pre &amp; Post Development</b> Prepared by TFMoran Inc. HydroCAD® 10, 10-7a, s/n 00866, © 2021 HydroCAD Software Solutions	Post-Development Drainage <i>Type III 24-hr</i> 2-Year Rainfall=3.70" Printed 4/18/2022 LLC Page 3
Time span=0.00-24.00 hrs, dt=0.05 hrs Runoff by SCS TR-20 method, UH=SCS Reach routing by Dyn-Stor-Ind method - Pond routir	, 481 points , Weighted-Q ng by Dyn-Stor-Ind method
SubcatchmentPS01: PS-01 Runoff Area=11,255 sf Flow Length=71' Slope=0.0280 '/' Tc=	16.98% Impervious Runoff Depth>0.72" =6.1 min CN=WQ Runoff=0.2 cfs 0.0 af
SubcatchmentPS02: PS-02Runoff Area=6,297 sfFlow Length=149'Tc=	34.43% Impervious Runoff Depth>1.29" =6.0 min CN=WQ Runoff=0.2 cfs 0.0 af
SubcatchmentPS03: PS-03Runoff Area=6,541 sfFlow Length=390'Tc=	86.52% Impervious Runoff Depth>3.05" =6.0 min CN=WQ Runoff=0.5 cfs 0.0 af
SubcatchmentPS04: PS-04Runoff Area=17,880 sfFlow Length=245'Tc=	38.38% Impervious Runoff Depth>1.74" =8.1 min CN=WQ Runoff=0.7 cfs 0.1 af
SubcatchmentPS05: PS-05Runoff Area=15,305 sfFlow Length=70'Tc=	22.05% Impervious Runoff Depth>1.38" =6.2 min CN=WQ Runoff=0.5 cfs 0.0 af
SubcatchmentPS06: PS-06 Runoff Area=5,793 sf Flow Length=72' Slope=0.0694 '/' Tc=	35.75% Impervious Runoff Depth>1.72" =6.0 min CN=WQ Runoff=0.2 cfs 0.0 af
SubcatchmentPS07: PS-07 Runoff Area=2,235 sf Tc:	51.59% Impervious Runoff Depth>1.85" =6.0 min CN=WQ Runoff=0.1 cfs 0.0 af
Reach PR01: PR-01         Avg. Flow Depth=0.04           n=0.022         L=25.0'         S=0.0200 '/'	' Max Vel=0.99 fps Inflow=0.2 cfs 0.0 af Capacity=14.6 cfs Outflow=0.2 cfs 0.0 af
Reach PR02: PR-02         Avg. Flow Depth=0.03'           n=0.022         L=210.0'           S=0.0262 '/'         0	' Max Vel=1.04 fps Inflow=0.2 cfs 0.0 af Capacity=16.7 cfs Outflow=0.2 cfs 0.0 af
Reach PR03: PR-03         Avg. Flow Depth=0.05'           n=0.030         L=60.0'         S=0.0117 '/'	' Max Vel=0.73 fps Inflow=0.7 cfs 0.1 af Capacity=21.9 cfs Outflow=0.6 cfs 0.1 af
Pond RG01: Rain Garden 01         Peak Elev=33.09           Discarded=0.0 cfs         0.0 af         Primary=0.0 cfs         0.0 af         Secondard	9' Storage=153.1 cf Inflow=0.2 cfs 0.0 af ary=0.0 cfs 0.0 af Outflow=0.0 cfs 0.0 af
Pond RG02: Rain Garden 02         Peak Elev=32.87           Discarded=0.0 cfs         0.0 af         Primary=0.0 cfs         0.0 af         Secondard	7' Storage=876.7 cf Inflow=0.5 cfs 0.0 af ary=0.0 cfs 0.0 af Outflow=0.1 cfs 0.0 af
Pond RG03: Rain Garden 03Peak Elev=29.94Discarded=0.0 cfs0.0 afPrimary=0.1 cfs0.0 afSeconda	4' Storage=363.6 cf Inflow=0.2 cfs 0.0 af ary=0.0 cfs 0.0 af Outflow=0.1 cfs 0.0 af
Pond RG04: Rain Garden 04       Peak Elev=31.94         Discarded=0.0 cfs       0.0 af       Primary=0.0 cfs       0.0 af       Secondard	4' Storage=111.3 cf Inflow=0.1 cfs 0.0 af ary=0.0 cfs 0.0 af Outflow=0.0 cfs 0.0 af
Link PPOI01: PPOI-01	<mark>(Inflow=1.2 cfs) (0.1 af</mark> ) Primary=1.2 cfs (0.1 af)

Total Runoff Area = 1.50 acRunoff Volume = 0.2 afAverage Runoff Depth = 1.57"64.48% Pervious = 0.97 ac35.52% Impervious = 0.53 ac

		Post-Development Drain	nage
45407-120_Pre & Post Devel	lopment	Type III 24-hr <mark>10-Year</mark> Rainfall=	5.61"
Prepared by TFMoran Inc.		Printed 4/18/2	2022
<u>HydroCAD® 10.10-7a s/n 00866 © 2</u>	021 HydroCAD Software Solut	tions LLC Pa	<u>ge 4</u>
Time s Runoff b Roach routing by Dyn	pan=0.00-24.00 hrs, dt=0.05 y SCS TR-20 method, UH=S	5 hrs, 481 points SCS, Weighted-Q	
Reach fouling by Dyr		outing by Dyn-Stor-Ind Method	
SubcatchmentPS01: PS-01	Runoff Area=11,255	5 sf 16.98% Impervious Runoff Depth>1	.42"
Flow	Length=71' Slope=0.0280 '/'	Tc=6.1 min CN=WQ Runoff=0.3 cfs 0.	0 af
SubcatchmentPS02: PS-02	Runoff Area=6,29	7 sf 34.43% Impervious Runoff Depth>2	2.23"
	Flow Length=149'	Tc=6.0 min CN=WQ Runoff=0.3 cfs 0.	.0 af
SubcatchmentPS03: PS-03	Runoff Area=6,54	1 sf 86.52% Impervious Runoff Depth>4	.81"
	Flow Length=390'	Tc=6.0 min CN=WQ Runoff=0.7 cfs 0.	.1 af
SubcatchmentPS04: PS-04	Runoff Area=17,880	0 sf 38.38% Impervious Runoff Depth>3	8.14"
	Flow Length=245'	Tc=8.1 min CN=WQ Runoff=1.2 cfs 0.	.1 af
SubcatchmentPS05: PS-05	Runoff Area=15,309	5 sf 22.05% Impervious Runoff Depth>2	2.69"
	Flow Length=70'	Tc=6.2 min CN=WQ Runoff=1.0 cfs 0.	.1 af
SubcatchmentPS06: PS-06	Runoff Area=5,793	3 sf 35.75% Impervious Runoff Depth>3	8.13"
Flow	Length=72' Slope=0.0694 '/'	Tc=6.0 min CN=WQ Runoff=0.4 cfs 0.	.0 af
SubcatchmentPS07: PS-07	Runoff Area=2,23	5 sf 51.59% Impervious Runoff Depth>3 Tc=6.0 min CN=WQ Runoff=0.1 cfs 0.	8.04" .0 af
Reach PR01: PR-01	Avg. Flow Depth=0	0.05' Max Vel=1.17 fps Inflow=0.3 cfs 0	.0 af
	n=0.022 L=25.0' S=0.0200	) '/' Capacity=14.6 cfs Outflow=0.3 cfs 0	.0 af
Reach PR02: PR-02	Avg. Flow Depth=0	0.04' Max Vel=1.24 fps Inflow=0.3 cfs 0	.0 af
	n=0.022 L=210.0' S=0.0262	2 '/' Capacity=16.7 cfs Outflow=0.3 cfs 0	.0 af
Reach PR03: PR-03	Avg. Flow Depth=0	0.10' Max Vel=1.07 fps Inflow=1.9 cfs 0	.2 af
	n=0.030 L=60.0' S=0.0117	' '/' Capacity=21.9 cfs Outflow=1.9 cfs 0	.2 af
Pond RG01: Rain Garden 01	Peak Elev=3	33.85' Storage=383.3 cf Inflow=0.3 cfs 0	.0 af
Discarded=0.0 cfs 0.0 af	Primary=0.0 cfs 0.0 af Seco	condary=0.0 cfs 0.0 af Outflow=0.0 cfs 0.	0 af
Pond RG02: Rain Garden 02	Peak Elev=33	0.00' Storage=1,023.1 cf Inflow=1.0 cfs 0	.1 af
Discarded=0.0 cfs 0.0 af	Primary=0.6 cfs 0.0 af Seco	condary=0.2 cfs 0.0 af Outflow=0.8 cfs 0.	1 af
Pond RG03: Rain Garden 03	Peak Elev=2	29.98' Storage=378.3 cf Inflow=0.4 cfs 0	.0 af
Discarded=0.0 cfs 0.0 af	Primary=0.2 cfs 0.0 af Seco	condary=0.2 cfs 0.0 af Outflow=0.4 cfs 0.	0 af
Pond RG04: Rain Garden 04	Peak Elev=3	33.66' Storage=217.1 cf Inflow=0.1 cfs 0	.0 af
Discarded=0.0 cfs 0.0 af	Primary=0.0 cfs 0.0 af Seco	condary=0.0 cfs 0.0 af Outflow=0.0 cfs 0.	0 af
Link PPOI01: PPOI-01		<mark>(Inflow=3.0 cfs</mark> ) Primary=3.0 cfs_0	).3 af ).3 af

Total Runoff Area = 1.50 acRunoff Volume = 0.4 afAverage Runoff Depth = 2.81"64.48% Pervious = 0.97 ac35.52% Impervious = 0.53 ac

45407-120 Pre & Post Devel	opment	Post-D Type III 24-hr <mark>25</mark>	evelopment Drainage <mark>-Year</mark> Rainfall=7.12″
Prepared by TFMoran Inc.		J1	Printed 4/18/2022
HydroCAD® 10.10-7a s/n 00866 © 20	021 HydroCAD Software Solut	ions LLC	Page 5
Time sp	oan=0.00-24.00 hrs, dt=0.05	hrs, 481 points	method
Runoff by	y SCS TR-20 method, UH=S	SCS, Weighted-Q	
Reach routing by Dyn	i-Stor-Ind method , Pond ro	puting by Dyn-Stor-Ind	
SubcatchmentPS01: PS-01	Runoff Area=11,255	5 sf 16.98% Impervious	Runoff Depth>2.15"
Flow	Length=71' Slope=0.0280 '/'	Tc=6.1 min CN=WQ	Runoff=0.5 cfs 0.0 af
SubcatchmentPS02: PS-02	Runoff Area=6,297	7 sf 34.43% Impervious	Runoff Depth>3.12"
	Flow Length=149'	Tc=6.0 min CN=WQ	Runoff=0.4 cfs 0.0 af
SubcatchmentPS03: PS-03	Runoff Area=6,54	1 sf 86.52% Impervious	Runoff Depth>6.22"
	Flow Length=390'	Tc=6.0 min CN=WQ	Runoff=0.9 cfs 0.1 af
SubcatchmentPS04: PS-04	Runoff Area=17,880	0 sf 38.38% Impervious	Runoff Depth>4.36"
	Flow Length=245'	Tc=8.1 min CN=WQ	Runoff=1.8 cfs 0.1 af
SubcatchmentPS05: PS-05	Runoff Area=15,305	5 sf 22.05% Impervious	Runoff Depth>3.86"
	Flow Length=70'	Tc=6.2 min CN=WQ	Runoff=1.5 cfs 0.1 af
SubcatchmentPS06: PS-06 Flow	Runoff Area=5,793	3 sf 35.75% Impervious	Runoff Depth>4.35"
	Length=72' Slope=0.0694 '/'	Tc=6.0 min CN=WQ	Runoff=0.6 cfs 0.0 af
SubcatchmentPS07: PS-07	Runoff Area=2,23	5 sf 51.59% Impervious Tc=6.0 min CN=WQ	Runoff Depth>4.08" Runoff=0.2 cfs 0.0 af
Reach PR01: PR-01	Avg. Flow Depth=0	0.06' Max Vel=1.32 fps	Inflow=0.4 cfs 0.0 af
	n=0.022 L=25.0' S=0.0200	'/' Capacity=14.6 cfs	Outflow=0.4 cfs 0.0 af
Reach PR02: PR-02	Avg. Flow Depth=0	0.05' Max Vel=1.40 fps	Inflow=0.4 cfs 0.0 af
	n=0.022 L=210.0' S=0.0262	'/' Capacity=16.7 cfs	Outflow=0.4 cfs 0.0 af
Reach PR03: PR-03	Avg. Flow Depth=0	0.14' Max Vel=1.30 fps	Inflow=3.3 cfs 0.2 af
	n=0.030 L=60.0' S=0.0117	'/' Capacity=21.9 cfs	Outflow=3.2 cfs 0.2 af
Pond RG01: Rain Garden 01	Peak Elev=3	5.61' Storage=748.8 cf	Inflow=0.5 cfs 0.0 af
Discarded=0.0 cfs 0.0 af	Primary=0.0 cfs 0.0 af Seco	ondary=0.0 cfs 0.0 af (	Dutflow=0.0 cfs 0.0 af
Pond RG02: Rain Garden 02	Peak Elev=33.	04' Storage=1,028.1 cf	Inflow=1.5 cfs 0.1 af
Discarded=0.0 cfs 0.0 af	Primary=0.9 cfs 0.1 af Seco	ondary=0.7 cfs 0.0 af (	Dutflow=1.5 cfs 0.1 af
Pond RG03: Rain Garden 03	Peak Elev=2	9.99' Storage=383.3 cf	Inflow=0.6 cfs 0.0 af
Discarded=0.0 cfs 0.0 af	Primary=0.3 cfs 0.0 af Seco	ondary=0.3 cfs 0.0 af (	Dutflow=0.6 cfs 0.0 af
Pond RG04: Rain Garden 04	Peak Elev=3	3.87' Storage=280.8 cf	Inflow=0.2 cfs 0.0 af
Discarded=0.0 cfs 0.0 af	Primary=0.0 cfs 0.0 af Seco	ondary=0.0 cfs 0.0 af (	Dutflow=0.0 cfs 0.0 af
Link PPOI01: PPOI-01			<mark>Inflow=5.1 cfs</mark> 0.4 af Primary=5.1 cfs  0.4 af

Total Runoff Area = 1.50 acRunoff Volume = 0.5 afAverage Runoff Depth = 3.92"64.48% Pervious = 0.97 ac35.52% Impervious = 0.53 ac

45407 120 Pro & Post Dovol	onmont	Post-Development Draina	ige 52″
Prepared by TEMoran Inc	opment	Printed 4/18/20	122
HydroCAD® 10.10-7a s/n 00866 © 20	021 HydroCAD Software Solution	ions LLC Page	e 6
Time sp	oan=0.00-24.00 hrs, dt=0.05	hrs, 481 points	
Runoff by	/ SCS TR-20 method, UH=S	SCS, Weighted-Q	
Reach routing by Dyn	-Stor-Ind method - Pond ro	outing by Dyn-Stor-Ind method	
SubcatchmentPS01: PS-01	Runoff Area=11,255	5 sf 16.98% Impervious Runoff Depth>2.9	3"
Flow I	Length=71' Slope=0.0280 '/'	Tc=6.1 min CN=WQ Runoff=0.7 cfs 0.1	af
SubcatchmentPS02: PS-02	Runoff Area=6,297	7 sf 34.43% Impervious Runoff Depth>4.0	2"
	Flow Length=149'	Tc=6.0 min CN=WQ Runoff=0.6 cfs 0.0	af
SubcatchmentPS03: PS-03	Runoff Area=6,541	1 sf 86.52% Impervious Runoff Depth>7.5	5"
	Flow Length=390'	Tc=6.0 min CN=WQ Runoff=1.1 cfs 0.1	af
SubcatchmentPS04: PS-04	Runoff Area=17,880	) sf 38.38% Impervious Runoff Depth>5.5	5"
	Flow Length=245'	Tc=8.1 min CN=WQ Runoff=2.3 cfs 0.2	af
SubcatchmentPS05: PS-05	Runoff Area=15,305	5 sf 22.05% Impervious Runoff Depth>5.0	2"
	Flow Length=70'	Tc=6.2 min CN=WQ Runoff=1.9 cfs 0.1	af
SubcatchmentPS06: PS-06	Runoff Area=5,793	3 sf 35.75% Impervious Runoff Depth>5.5	4"
Flow I	Length=72' Slope=0.0694 '/'	Tc=6.0 min CN=WQ Runoff=0.8 cfs 0.1	af
SubcatchmentPS07: PS-07	Runoff Area=2,235	5 sf 51.59% Impervious Runoff Depth>5.1 Tc=6.0 min CN=WQ Runoff=0.3 cfs 0.0	1" af
Reach PR01: PR-01	Avg. Flow Depth=0	0.07' Max Vel=1.47 fps Inflow=0.6 cfs 0.1	af
	n=0.022 L=25.0' S=0.0200 '	'/' Capacity=14.6 cfs Outflow=0.6 cfs 0.1	af
Reach PR02: PR-02	Avg. Flow Depth=0	0.06' Max Vel=1.56 fps Inflow=0.6 cfs 0.1	af
	=0.022 L=210.0' S=0.0262	'/' Capacity=16.7 cfs Outflow=0.5 cfs 0.1	af
Reach PR03: PR-03	Avg. Flow Depth=0	0.16' Max Vel=1.41 fps Inflow=4.0 cfs 0.3	af
	n=0.030 L=60.0' S=0.0117 '	'/' Capacity=21.9 cfs Outflow=4.1 cfs 0.3	af
Pond RG01: Rain Garden 01	Peak Elev=35.8	87' Storage=1,103.8 cf Inflow=0.7 cfs 0.1	af
Discarded=0.0 cfs 0.0 af	Primary=0.0 cfs  0.0 af   Seco	ondary=0.0 cfs 0.0 af Outflow=0.1 cfs 0.1	af
Pond RG02: Rain Garden 02	Peak Elev=33.0	06' Storage=1,028.1 cf Inflow=1.9 cfs 0.1	af
Discarded=0.0 cfs 0.0 af	Primary=1.0 cfs 0.1 af Seco	ondary=0.8 cfs 0.0 af Outflow=1.8 cfs 0.1	af
Pond RG03: Rain Garden 03	Peak Elev=29	9.99' Storage=387.6 cf Inflow=0.8 cfs 0.1	af
Discarded=0.0 cfs 0.0 af	Primary=0.3 cfs 0.0 af Seco	ondary=0.5 cfs 0.0 af Outflow=0.8 cfs 0.1	af
Pond RG04: Rain Garden 04	Peak Elev=33	3.90' Storage=291.8 cf Inflow=0.3 cfs 0.0	af
Discarded=0.0 cfs 0.0 af	Primary=0.1 cfs 0.0 af Seco	ondary=0.0 cfs 0.0 af Outflow=0.1 cfs 0.0	af
Link PPOI01: PPOI-01		<mark>(Inflow=6.5 cfs</mark> ) 0.5 Primary=6.5 cfs 0.5	af af

Total Runoff Area = 1.50 acRunoff Volume = 0.6 afAverage Runoff Depth = 5.01"64.48% Pervious = 0.97 ac35.52% Impervious = 0.53 ac

# <u>APPENDIX E – POST-DEVELOPMENT</u> CALCULATIONS (10-YEAR STORM EVENT)

(This Page Is Intentionally Blank)

#### Summary for Subcatchment PS01: PS-01

Runoff = 0.3 cfs @ 12.09 hrs, Volume= 0.0 af, Depth> 1.42" Routed to Pond RG01 : Rain Garden 01

Runoff by SCS TR-20 method, UH=SCS, Weighted-Q, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Type III 24-hr 10-Year Rainfall=5.61"

A	rea (sf)	CN	Description				
	8,038	39	>75% Gras	s cover, Go	bod, HSG A		
	1,306	68	<50% Gras	s cover, Po	oor, HSG A		
	1,624	98	Roofs, HSC	θA			
	287	98	Paved park	ing, HSG A			
	11,255		Weighted A	verage			
	9,344		83.02% Pei	rvious Area			
	1,911		16.98% Impervious Area				
Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description		
6.1	71	0.0280	0.20		Sheet Flow, Grass Yard Grass: Short n= 0.150 P2= 3.70"		

## Summary for Subcatchment PS02: PS-02

Runoff = 0.3 cfs @ 12.09 hrs, Volume= 0.0 af, Depth> 2.23" Routed to Reach PR01 : PR-01

Runoff by SCS TR-20 method, UH=SCS, Weighted-Q, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Type III 24-hr 10-Year Rainfall=5.61"

Area (sf)	CN	Description
3,621	39	>75% Grass cover, Good, HSG A
508	68	<50% Grass cover, Poor, HSG A
0	36	Woods, Fair, HSG A
157	98	Roofs, HSG A
2,011	98	Paved parking, HSG A
6,297		Weighted Average
4,129		65.57% Pervious Area
2,168		34.43% Impervious Area

Post-Development Drainage 10-Year 45407-120\_Pre & Post Development Type III 24-hr 10-Year Rainfall=5.61" Prepared by TFMoran Inc. Printed 4/18/2022 HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC Page 2 Slope Velocity Capacity Description Tc Length (min) (feet) (ft/ft) (ft/sec) (cfs) 4.9 65 0.0400 0.22 Sheet Flow, Grass Yard Grass: Short n= 0.150 P2= 3.70" 04 35 0.0250 1 31 Sheet Flow, Driveway/Road

0.4	00	0.0200	1.01		oneet now, billeway/read
					Smooth surfaces n= 0.011 P2= 3.70"
0.1	27	0.0250	3.21		Shallow Concentrated Flow, Road
					Paved Kv= 20.3 fps
0.1	22	0.0250	2.87	5.75	Channel Flow, Swale
					Area= 2.0 sf Perim= 9.0' r= 0.22'
					n= 0.030 Short grass
0.5					Direct Entry, Min Tc
6.0	140	Total			

6.0 149 Total

.

#### Summary for Subcatchment PS03: PS-03

0.1 af, Depth> 4.81"

Runoff	=	0.7 cfs @	2 12.09 hrs,	Volume=
Routed	to Link	PPOI01 :	PPOI-01	

Runoff by SCS TR-20 method, UH=SCS, Weighted-Q, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Type III 24-hr 10-Year Rainfall=5.61"

Ar	rea (sf)	CN I	Description		
	525	61 >	>75% Gras	s cover, Go	bod, HSG B
	0	79 •	<50% Gras	s cover, Po	oor, HSG B
	0	98 I	Roofs, HSC	βB	
	2,744	98 I	Paved park	ing, HSG B	}
	337	39 >	>75% Gras	s cover, Go	bod, HSG A
	2,915	98 I	Roofs, HSC	βA	
	20	60 \	Noods, Fai	r, HSG B	
	6,541	١	Neighted A	verage	
	882		13.48% Pei	rvious Area	l
	5,659	8	36.52% Imp	pervious Ar	ea
_					
TC	Length	Slope	Velocity	Capacity	Description
(min)	(feet)	(ft/ft)	(ft/sec)	(cfs)	
0.8	100	0.0425	2.00		Sheet Flow, Paved Road
					Smooth surfaces n= 0.011 P2= 3.70"
1.0	190	0.0250	3.21		Shallow Concentrated Flow, Paved Road
					Paved Kv= 20.3 fps
1.8	100	0.0170	0.91		Shallow Concentrated Flow, Grass Shoulder
					Short Grass Pasture Kv= 7.0 fps
2.4					Direct Entry, Min Tc
6.0	390	Total			

#### Summary for Subcatchment PS04: PS-04

Runoff = 1.2 cfs @ 12.12 hrs, Volume= 0.1 af, Depth> 3.14" Routed to Reach PR03 : PR-03

Runoff by SCS TR-20 method, UH=SCS, Weighted-Q, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Type III 24-hr 10-Year Rainfall=5.61"

А	rea (sf)	CN	Description		
-	9,038	61	>75% Gras	s cover, Go	ood, HSG B
	<sup></sup> 154	79	<50% Gras	s cover, Po	bor, HSG B
	1,352	98	Roofs, HSC	θB	
	5,502	98	Paved park	ing, HSG B	}
	1,826	60	Woods, Fai	r, HSG B	
	8	98	Paved park	ing, HSG B	
	17,880		Weighted A	verage	
	11,018		61.62% Pe	rvious Area	
	6,862		38.38% Im	pervious Ar	ea
Та	l e e este	Class	Valasity	Conseitu	Description
IC (min)	Lengin (foot)	Siope		Capacity	Description
	(1661)			(015)	Chaot Flow, Croop Vord
0.3	100	0.0500	0.26		Sneet Flow, Grass Yard
0.0	00	0.0450	1 1 1 0		Glass. Short n= 0.150 P2= 5.70 Shallow Concentrated Flow Side Vard (Fact Bronarty Ling
0.9	00	0.0430	1.40		Short Crass Posture, Ky= 7.0 fre
0.4	30	0.0600	1 22		Shallow Concentrated Flow Woods Side Vard
0.4	50	0.0000	5 1.22		Woodland $K_{v} = 5.0 \text{ fns}$
0.5	35	0.0140	) 1.20	4,57	Channel Flow, Wooded Swale
0.0		0.011			Area= 3.8 sf Perim= 19.0' r= 0.20'
					n= 0.050 Scattered brush, heavy weeds
8.1	245	Total			· · ·

245 Total

#### Summary for Subcatchment PS05: PS-05

Runoff = 1.0 cfs @ 12.10 hrs, Volume= 0.1 af, Depth> 2.69" Routed to Pond RG02 : Rain Garden 02

Runoff by SCS TR-20 method, UH=SCS, Weighted-Q, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Type III 24-hr 10-Year Rainfall=5.61"

Area (sf)	CN	Description
10,534	61	>75% Grass cover, Good, HSG B
1,397	79	<50% Grass cover, Poor, HSG B
3,141	98	Roofs, HSG B
233	98	Paved parking, HSG B
0	60	Woods, Fair, HSG B
15,305		Weighted Average
11,931		77.95% Pervious Area
3,374		22.05% Impervious Area

45407-	120 Pre	e & Pos	t Develo	oment	Post-Development Drainage 10-Year Type III 24-hr 10-Year Rainfall=5.61
Prepare	d by TFI	Moran In	с_с.		Printed 4/18/2022
HydroCA	D® 10.10	-7a s/n 00	)866 © 202	21 HydroCA	D Software Solutions LLC Page 4
					-
Тс	Length	Slope	Velocity	Capacity	Description
(min)	(feet)	(ft/ft)	(ft/sec)	(cfs)	
3.3	20	0.0250	0.10		Sheet Flow, Landscape
		0 0000	0.00		Grass: Dense n= 0.240 P2= 3.70"
2.9	50	0.0900	0.29		Sheet Flow, Back Yard
	70	Tatal			Grass: Short h= 0.150 P2= 3.70
0.2	70	Total			
			Summ	om for S	ubaatahmant DS06, DS 06
			Summ	ary ior Si	
Runoff Route	= ed to Pon	0.4 cfs d RG03 :	@ 12.09 Rain Gare	hrs, Volun den 03	ne= 0.0 af, Depth> 3.13"
Runoff b Type III :	y SCS Tł 24-hr 10-	R-20 met -Year Rai	hod, UH=S infall=5.61	SCS, Weigh "	nted-Q, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs
A	rea (sf)	CN D	escription		
	3,415	61 >	75% Gras	s cover, Go	bod, HSG B
	307	79 <	50% Gras	s cover, Po	oor, HSG B
	1,803	98 F	Roofs, HSC	B HOOF	
	268	98 P	aved park	ing, HSG E	
	<u> </u>	<u> </u>	Volus, rai		
	5,193 2 7 2 2	V G	4 25% Da	werage	
	2 071	3	4.23 /0 F E		- 
	2,071	0	0.7070 111		
Tc	Lenath	Slope	Velocitv	Capacity	Description
(min)	(feet)	(ft/ft)	(ft/sec)	(cfs)	·
4.3	72	0.0694	0.28	· /	Sheet Flow, Grass Yard
					Grass: Short n= 0.150 P2= 3.70"
1.7					Direct Entry, Min Tc
6.0	72	Total			

## Summary for Subcatchment PS07: PS-07

Explanation for "Tc to Account for Porous Pavers"

Per HydroCAD.net - When modeling porous pavement, a Tc value of 790 minutes has produced good predictions for final discharge from porous pavement with a 41" base (this approach has been studied by UNH Stormwater Center). It is believed that a proportional Tc can be used for smaller base thicknesses, as long as the layers remain proportional and in accordance with the UNH Specifications.

Since the proposed porous paver thickness is 20" (4" paver, 2" bedding course, 6" base course, 8" sub-base course), a proportional Tc value of 385 min would be consistent with the aformentioned information from HydroCAD.net. As a result, a direct value of 380.5 minutes is being entered to create a total Tc value of 385 minutes for the subcatchment.

Runoff = 0.1 cfs @ 12.09 hrs, Volume= Routed to Pond RG04 : Rain Garden 04 0.0 af, Depth> 3.04"

Type III 24-hr 10-Year Rainfall=5.61" Printed 4/18/2022 Page 5

Runoff by SCS TR-20 method, UH=SCS, Weighted-Q, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Type III 24-hr 10-Year Rainfall=5.61"

Area (sf) (	CN Description
962	39 >75% Grass cover, Good, HSG A
120	68 <50% Grass cover, Poor, HSG A
898	98 Roofs, HSG A
255	98 Paved parking, HSG A
2,235	Weighted Average
1,082	48.41% Pervious Area
1,153	51.59% Impervious Area
Tc Length	Slope Velocity Capacity Description
(min) (feet)	(IT/IT) (IT/SEC) (CIS)
6.0	Direct Entry, Min 1C
	Summary for Reach PR01: PR-01
Inflow Area = Inflow = Outflow = Routed to Reach	0.45 ac, 26.44% Impervious, Inflow Depth > 0.71" for 10-Year event 0.3 cfs @ 12.09 hrs, Volume= 0.0 af 0.3 cfs @ 12.09 hrs, Volume= 0.0 af, Atten= 0%, Lag= 0.3 min n PR02 : PR-02
Routing by Dyn-Sto Max. Velocity= 1.17 Avg. Velocity = 0.32	r-ind method, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs 7 fps, Min. Travel Time= 0.4 min 2 fps, Avg. Travel Time= 1.3 min
Peak Storage= 6.4 Average Depth at P Bank-Full Depth= 0.	cf @ 12.09 hrs 'eak Storage= 0.05' , Surface Width= 5.93' .40'  Flow Area= 3.6 sf,  Capacity= 14.6 cfs
5.00' x 0.40' deep Side Slope Z-value= Length= 25.0' Slop Inlet Invert= 31.50',	o channel, n= 0.022 Earth, clean & straight = 10.0 '/' Top Width= 13.00' be= 0.0200 '/' Outlet Invert= 31.00'
+	
+	
	Summary for Reach PR02: PR-02

[61] Hint: Exceeded Reach PR01 outlet invert by 0.04' @ 12.10 hrs

Post-Development Drainage 10-Year Type III 24-hr 10-Year Rainfall=5.61" 45407-120 Pre & Post Development Prepared by TFMoran Inc. Printed 4/18/2022 HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC Page 6 Inflow Area = 0.45 ac, 26.44% Impervious, Inflow Depth > 0.71" for 10-Year event Inflow 0.3 cfs @ 12.09 hrs, Volume= 0.0 af = = 0.3 cfs @ 12.12 hrs, Volume= Outflow 0.0 af, Atten= 6%, Lag= 1.7 min Routed to Link PPOI01 : PPOI-01 Routing by Dyn-Stor-Ind method, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Max. Velocity= 1.24 fps, Min. Travel Time= 2.8 min Avg. Velocity = 0.36 fps, Avg. Travel Time= 9.8 min Peak Storage= 47.3 cf @ 12.12 hrs Average Depth at Peak Storage= 0.04', Surface Width= 5.83' Bank-Full Depth= 0.40' Flow Area= 3.6 sf, Capacity= 16.7 cfs 5.00' x 0.40' deep channel, n= 0.022 Earth, clean & straight Side Slope Z-value= 10.0 '/' Top Width= 13.00' Length= 210.0' Slope= 0.0262 '/' Inlet Invert= 31.00', Outlet Invert= 25.50' ‡ Summary for Reach PR03: PR-03 Inflow Area = 0.76 ac, 30.85% Impervious, Inflow Depth > 2.48" for 10-Year event 1.9 cfs @ 12.16 hrs, Volume= Inflow 0.2 af = 1.9 cfs @ 12.17 hrs, Volume= 0.2 af, Atten= 2%, Lag= 0.8 min Outflow = Routed to Link PPOI01 : PPOI-01 Routing by Dyn-Stor-Ind method, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Max. Velocity= 1.07 fps, Min. Travel Time= 0.9 min Avg. Velocity = 0.27 fps, Avg. Travel Time= 3.7 min Peak Storage= 103.5 cf @ 12.17 hrs Average Depth at Peak Storage= 0.10', Surface Width= 19.05' Bank-Full Depth= 0.40' Flow Area= 9.2 sf, Capacity= 21.9 cfs 15.00' x 0.40' deep channel, n= 0.030 Short grass Side Slope Z-value= 20.0 '/' Top Width= 31.00' Length= 60.0' Slope= 0.0117 '/' Inlet Invert= 26.00', Outlet Invert= 25.30' ‡

## Summary for Pond RG01: Rain Garden 01

Inflow Area	a =	0.26 ac, 1	6.98% Impe	ervious,	Inflow D	epth >	1.42"	for 10	)-Year	event
Inflow	=	0.3 cfs @	12.09 hrs,	Volume	=	0.0 af				
Outflow	=	0.0 cfs @	11.75 hrs,	Volume	=	0.0 af,	Atten=	88%,	Lag= (	0.0 min
Discarded	=	0.0 cfs @	11.75 hrs,	Volume	=	0.0 af			•	
Primary	=	0.0 cfs @	0.00 hrs,	Volume	=	0.0 af				
Routed	to Reac	h PR01 : Pl	R-01							
Secondary	=	0.0 cfs @	0.00 hrs,	Volume	=	0.0 af				
Routed	to Reac	h PR01 : Pl	R-01							

Routing by Dyn-Stor-Ind method, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Peak Elev= 33.85' @ 13.06 hrs Surf.Area= 753 sf Storage= 383.3 cf

Plug-Flow detention time= 75.7 min calculated for 0.0 af (100% of inflow) Center-of-Mass det. time= 75.4 min ( 879.1 - 803.7 )

Volume	Invert	Avail.	Storage	Storage Description				
#1	35.50'		720.0 cf	Pond Area (Irregula	<b>ar)</b> Listed below (Re	ecalc) -Impervious		
#2	34.00'		225.9 cf	Filter Media (Irregu	lar)Listed below (R	Recalc) -Impervious		
				1,129.5 cf Overall x	20.0% Voids			
#3	32.58'		427.7 ct	Gravel & Pea Gravel (Irregular)Listed below (Recalc)				
		4	070.0.5	T,069.3 Cf Overall X	40.0% Voids			
		1,	373.6 CT	Total Available Stora	age			
Elevatio	on Surf.	Area	Perim.	Inc.Store	Cum.Store	Wet.Area		
(fee	et) (:	sq-ft)	(feet)	(cubic-feet)	(cubic-feet)	(sq-ft)		
35.5	50	753	309.0	0.0	0.0	753		
36.0	0 2	2,262	329.0	720.0	720.0	1,781		
_					<b>a a</b> /			
Elevatio	on Surf.	Area	Perim.	Inc.Store	Cum.Store	Wet.Area		
(tee	et) (S	sq-tt)	(teet)	(CUDIC-TEET)	(CUDIC-TEET)	<u>(sq-π)</u>		
34.0	00	753	309.0	0.0	0.0	753		
35.5	50	753	309.0	1,129.5	1,129.5	1,217		
Elevatio	on Surf.	Area	Perim.	Inc.Store	Cum.Store	Wet Area		
(fee	et) (s	sq-ft)	(feet)	(cubic-feet)	(cubic-feet)	(sq-ft)		
32.5	58	753	309.0	0.0	0.0	753		
34.0	00	753	309.0	1,069.3	1,069.3	1,192		
Device	Routing	Inver	t Outlet	Devices				
#1	Primary	32.83	3' <b>8.0"</b> I	Round Culvert				
			L= 55	.0' CPP, square edge	e headwall, Ke= 0.	500		
			Inlet /	Outlet Invert= 32.83' /	' 32.00' S= 0.0151	'/' Cc= 0.900		
			n= 0.0	)13 Corrugated PE, si	mooth interior, Flor	w Area= 0.35 sf		
#2	Discarded	32.58	3' <b>2.150</b>	in/hr Exfiltration over	er Horizontal area	Phase-In= 0.01'		
#3	Secondary	35.95	5' <b>10.0'</b>	long x 3.0' breadth E	Broad-Crested Re	ctangular Weir		
	-		Head	(feet) 0.20 0.40 0.60	0.80 1.00 1.20	1.40 1.60 1.80 2.00		
			2.50	3.00 3.50 4.00 4.50				
			Coef.	(English) 2.44 2.58	2.68 2.67 2.65 2.	64 2.64 2.68 2.68		

	Post-Development Drainage 10-Year
45407-120_Pre & Post Development	Type III 24-hr 10-Year Rainfall=5.61"
Prepared by TFMoran Inc.	Printed 4/18/2022
HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solution	ons LLC Page 8

2.72	2.81	2.92	2.97	3.07	3.32	
 		_				

#4	Device 1	35.85'	12.0" Horiz. Grate	C= 0.600	Limited to weir flow at low heads
#5	Device 1	35.75'	1.0" Vert. Orifice	C= 0.600	Limited to weir flow at low heads

**Discarded OutFlow** Max=0.0 cfs @ 11.75 hrs HW=32.62' (Free Discharge) **2=Exfiltration** (Exfiltration Controls 0.0 cfs)

Primary OutFlow Max=0.0 cfs @ 0.00 hrs HW=32.58' TW=31.50' (Dynamic Tailwater) 1=Culvert (Controls 0.0 cfs) 4=Grate (Controls 0.0 cfs) 5=Orifice (Controls 0.0 cfs)

Secondary OutFlow Max=0.0 cfs @ 0.00 hrs HW=32.58' TW=31.50' (Dynamic Tailwater) -3=Broad-Crested Rectangular Weir( Controls 0.0 cfs)

#### Summary for Pond RG02: Rain Garden 02

Inflow Area	a =	0.35 ac, 2	22.05% Impe	ervious, I	nflow De	pth >	2.69"	for 10	)-Year ev	ent
Inflow	=	1.0 cfs @	12.10 hrs,	Volume=	:	0.1 af				
Outflow	=	0.8 cfs @	12.17 hrs,	Volume=	:	0.1 af,	Atten=	20%,	Lag= 4.7	' min
Discarded	=	0.0 cfs @	6.85 hrs,	Volume=	:	0.0 af				
Primary	=	0.6 cfs @	12.17 hrs,	Volume=	:	0.0 af				
Routed	to Reac	h PR03 : P	R-03							
Secondary	=	0.2 cfs @	12.17 hrs,	Volume=	:	0.0 af				
Routed	to Reac	h PR03 : P	R-03							

Routing by Dyn-Stor-Ind method, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Peak Elev= 33.00' @ 12.17 hrs Surf.Area= 637 sf Storage= 1,023.1 cf

Plug-Flow detention time= 140.5 min calculated for 0.1 af (75% of inflow) Center-of-Mass det. time= 48.4 min (855.3 - 806.9)

Volume	Invert A	vail.Storage	Storage Description							
#1	32.50'	475.2 cf	Pond Area (Irregula	Pond Area (Irregular)Listed below (Recalc) -Impervious						
#2	31.00'	191.1 cf	Filter Media (Irregu	Filter Media (Irregular)Listed below (Recalc) -Impervious						
		004.0.5	955.5 cf Overall x 2	955.5 cf Overall x 20.0% Voids						
#3	29.58	361.8 CT	004 5 of Overall x 4	Gravel & Pea Gravel (Irregular)Listed below (Recalc)						
		1 028 1 of	Total Available Stor							
		1,020.1 Ci		aye						
Elevation	Surf.Area	Perim.	Inc.Store	Cum.Store	Wet.Area					
(feet)	(sq-ft)	(feet)	(cubic-feet)	(cubic-feet)	(sq-ft)					
32.50	637	202.0	0.0	0.0	637					
33.00	1,303	324.0	475.2	475.2	5,745					
	Cumf Ameri	Denime		Ourse Otherse						
Elevation	Surf.Area	Perim.	Inc.Store	Cum.Store	wet.Area					
(feet)	(sq-ft)	(feet)	(cubic-feet)	(cubic-feet)	<u>(sq-ft)</u>					
31.00	637	202.0	0.0	0.0	637					
32.50	637	202.0	955.5	955.5	940					

<b>45407-</b> Prepare <u>HydroCA</u>	• <b>120_Pre</b> ed by TFM •D® 10.10-	<b>&amp; Post Dev</b> loran Inc. 7a s/n 00866 ©	elopmei 2021 Hyd	nt roCAD Software Solu	Post-Develop <i>Type III 24-hr</i> tions LLC	oment Drainage 10-Year 10-Year Rainfall=5.61' Printed 4/18/2022 Page 9
Elevatio (fee	on et)	Surf.Area F (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
29.8 31.0	58 00	637 637	202.0 202.0	0.0 904.5	0.0 904.5	637 924
Device	Routing	Invert	Outlet D	Devices		
#1	Primary	29.33'	8.0" Ro L= 112. Inlet / O n= 0.01	ound Culvert 0' CMP, square ed outlet Invert= 29.33' / 3 Corrugated PE, si	ge headwall, Ke= 0. ′ 26.00′  S= 0.0297 ′ mooth interior,  Flow	500 /' Cc= 0.900 / Area= 0.35 sf
#2	Discarde	d 29.58'	0.350 ir	h/hr Exfiltration ove	er Horizontal area	Phase-In= 0.01'
#3 #4 #5	Device 1 Device 1 Seconda	32.85' 32.75' ry 32.95'	<b>12.0" H</b> <b>1.0" Ve</b> <b>10.0' lo</b> Head (fe 2.50 3.1 Coef. (E	oriz. Grate C= 0.6 rt. Orifice C= 0.60 ng x 3.0' breadth E eet) 0.20 0.40 0.60 00 3.50 4.00 4.50 English) 2.44 2.58	00 Limited to weir flo 0 Limited to weir flo <b>Broad-Crested Rec</b> 0 0.80 1.00 1.20 1 2.68 2.67 2.65 2.6	flow at low heads ow at low heads t <b>angular Weir</b> .40 1.60 1.80 2.00 4 2.64 2.68 2.68

**Discarded OutFlow** Max=0.0 cfs @ 6.85 hrs HW=29.62' (Free Discharge) **2=Exfiltration** (Exfiltration Controls 0.0 cfs)

**Primary OutFlow** Max=0.5 cfs @ 12.17 hrs HW=32.99' TW=26.10' (Dynamic Tailwater)

-1=Cuivert (Passes 0.5 cis of 2.6 cis potential now)

-3=Grate (Weir Controls 0.5 cfs @ 1.22 fps)

-4=Orifice (Orifice Controls 0.0 cfs @ 2.14 fps)

Secondary OutFlow Max=0.2 cfs @ 12.17 hrs HW=32.99' TW=26.10' (Dynamic Tailwater) 5=Broad-Crested Rectangular Weir (Weir Controls 0.2 cfs @ 0.48 fps)

#### Summary for Pond RG03: Rain Garden 03

0.13 ac, 35.75% Impervious, Inflow Depth > 3.13" for 10-Year event Inflow Area = 0.4 cfs @ 12.09 hrs, Volume= Inflow 0.0 af = 0.4 cfs @ 12.10 hrs, Volume= Outflow = 0.0 af, Atten= 0%, Lag= 0.5 min Discarded = 0.0 cfs @ 2.95 hrs, Volume= 0.0 af 0.2 cfs @ 12.10 hrs, Volume= 0.0 af Primary = Routed to Link PPOI01 : PPOI-01 Secondary = 0.2 cfs @ 12.10 hrs, Volume= 0.0 af Routed to Link PPOI01 : PPOI-01

Routing by Dyn-Stor-Ind method, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Peak Elev= 29.98' @ 12.10 hrs Surf.Area= 240 sf Storage= 378.3 cf

Plug-Flow detention time= 144.4 min calculated for 0.0 af (77% of inflow) Center-of-Mass det. time= 57.5 min ( 846.3 - 788.8 )

Post-Development Drainage 10-Year Type III 24-hr 10-Year Rainfall=5.61" Printed 4/18/2022

Page 10

# 45407-120\_Pre & Post Development

Prepared by TFMoran Inc. HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC

Volume	Invert	Avail.St	torage	Storage Description				
#1 #2	29.50' 28.00'	18 7	32.2 cf 72.0 cf	Pond Area (Irregula Filter Media (Irregul 360.0 cf Overall x 20	<b>r)</b> Listed below (Re <b>ar)</b> Listed below (Re 0.0% Voids	calc) -Impervious ecalc) -Impervious		
#3	26.58'	13	36.3 cf	Gravel & Pea Grave 340.8 cf Overall x 40	I (Irregular)Listed   0.0% Voids	below (Recalc)		
		39	90.5 cf	Total Available Stora	ge			
Elevatio (feet	n Surf.A t) (so	vrea P q-ft) (	erim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)		
29.5 30.0	0	240 505	125.0 140.0	0.0 182.2	0.0 182.2	240 563		
Elevatio (feet	n Surf.A t) (so	vrea P q-ft) (	erim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)		
28.0 29.5	0	240 1 240 1	125.0 125.0	0.0 360.0	0.0 360.0	240 428		
Elevatio (feet	n Surf.A t) (so	vrea P q-ft) (	erim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)		
26.5 28.0	8 0	240 240 240 240 240 240 240 240 240 240	125.0 125.0	0.0 340.8	0.0 340.8	240 418		
Device	Routing	Invert	Outlet	Devices				
#1 #2 #3	Primary Discarded Device 1	28.00' 26.58' 29.90'	6.0" R L= 13.0 Inlet / 0 n= 0.0" 0.150 i 12.0" I	Cound Culvert D' CMP, square edge Dutlet Invert= 28.00' / 13 Corrugated PE, sn n/hr Exfiltration ove Horiz. Grate C= 0.60	e headwall, Ke= 0.3 27.70' S= 0.0231 nooth interior, Flow <b>r Horizontal area</b> 00 Limited to weir	500 '/' Cc= 0.900 w Area= 0.20 sf Phase-In= 0.01' flow at low heads		
#4 #5	Device 1 Secondary	29.83' 29.95'	<b>1.0" V</b> <b>20.0' l</b> Head ( 2.50 3 Coef. ( 2.85 3	"Vert. Orifice C= 0.600 Limited to weir flow at low heads 0' long x 2.0' breadth Broad-Crested Rectangular Weir ad (feet) 0.20 0.40 0.60 0.80 1.00 1.20 1.40 1.60 1.80 2 0 3.00 3.50 ef. (English) 2.54 2.61 2.61 2.60 2.66 2.70 2.77 2.89 2.8 5 3.07 3.20 3.32				
Discarde 1 2=Ex1	ed OutFlow Ma filtration (Exfilt	ax=0.0 cfs ration Cor	@ 2.95 htrols 0.0	hrs HW=26.61' (Fre ) cfs)	e Discharge)			

Primary OutFlow Max=0.2 cfs @ 12.10 hrs HW=29.98' TW=0.00' (Dynamic Tailwater) 1=Culvert (Passes 0.2 cfs of 1.2 cfs potential flow) -3=Grate (Weir Controls 0.2 cfs @ 0.90 fps) -4=Orifice (Orifice Controls 0.0 cfs @ 1.55 fps)

Secondary OutFlow Max=0.2 cfs @ 12.10 hrs HW=29.98' TW=0.00' (Dynamic Tailwater) 5=Broad-Crested Rectangular Weir (Weir Controls 0.2 cfs @ 0.40 fps)

## Summary for Pond RG04: Rain Garden 04

Inflow Area	a =	0.05 ac, 5	1.59% Impe	ervious, Inflow D	)epth >	3.04"	for 10	)-Year e	vent
Inflow	=	0.1 cfs @	12.09 hrs,	Volume=	0.0 af				
Outflow	=	0.0 cfs @	11.35 hrs,	Volume=	0.0 af,	Atten=	93%,	Lag= 0.	.0 min
Discarded	=	0.0 cfs @	11.35 hrs,	Volume=	0.0 af			•	
Primary	=	0.0 cfs @	0.00 hrs,	Volume=	0.0 af				
Routed	to Reac	h PR01 : PF	R-01						
Secondary	=	0.0 cfs @	0.00 hrs,	Volume=	0.0 af				
Routed	to Reac	h PR01 : PF	R-01						

Routing by Dyn-Stor-Ind method, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs Peak Elev= 33.66' @ 13.75 hrs Surf.Area= 205 sf Storage= 217.1 cf

Plug-Flow detention time= 167.2 min calculated for 0.0 af (100% of inflow) Center-of-Mass det. time= 167.0 min (927.8 - 760.8)

Volume	Invert	Ava	il.Storage	Storage Description						
#1	33.50'		156.7 cf	Pond Area (Irregular)Listed below (Recalc) - Impervious						
#2	32.00'		61.5 cf	Filter Media (Irregu	Filter Media (Irregular)Listed below (Recalc) -Impervious					
			440.4.5	307.5 cf Overall x 20.0% Voids						
#3	30.58		116.4 Cf	Gravel & Pea Grave	el (Irregular)Listed	below (Recalc)				
			334 6 cf	Total Available Stora	de					
Elevatio	on Su	rf.Area	Perim.	Inc.Store	Cum.Store	Wet.Area				
(fee	et)	(sq-ft)	(feet)	(cubic-feet)	(cubic-feet)	(sq-ft)				
33.5	50	205	108.0	0.0	0.0	205				
34.0	00	436	121.0	156.7	156.7	449				
Elevatio	on Su	rf.Area	Perim.	Inc.Store	Cum.Store	Wet.Area				
(fee	et)	(sq-ft)	(feet)	(cubic-feet)	(cubic-feet)	(sq-ft)				
32.0	00	205	108.0	0.0	0.0	205				
33.5	50	205	108.0	307.5	307.5	367				
Elevatio	on Su	rf.Area	Perim.	Inc.Store	Cum.Store	Wet.Area				
(fee	et)	(sq-ft)	(feet)	(cubic-feet)	(cubic-feet)	(sq-ft)				
30.5	58	205	108.0	0.0	0.0	205				
32.0	00	205	108.0	291.1	291.1	358				
Device	Routing	Inv	ert Outlet	Devices						
#1	Primary	31.5	50' <b>6.0"  </b>	Round Culvert						
	-		L= 15.	L= 15.0' CPP, square edge headwall, Ke= 0.500						
			Inlet /	nlet / Outlet Invert= 31.50 / 31.40' S= 0.0067 '/' Cc= 0.900						
			n= 0.0	13 Corrugated PE, si	mooth interior, Flow	w Area= 0.20 sf				
#2	Discarded	30.5	58' <b>2.150</b>	in/hr Exfiltration ove	er Horizontal area	Phase-In= 0.01'				
#3	Secondary	33.9	95' <b>10.0'</b> I	long x 2.0' breadth E	Broad-Crested Red	ctangular Weir				
				(1eel) U.20 U.40 U.60 3 00 3 50	0.80 1.00 1.20	1.40 1.60 1.80 2.00				
			2.00 v Coef	(English) 254 261	261 260 266 2	70 2 77 2 80 2 88				
			Coef.	(English) 2.54 2.61	2.61 2.60 2.66 2.	70 2.77 2.89 2.88				

	Post-Development Drainage 10-Year
45407-120_Pre & Post Development	Type III 24-hr 10-Year Rainfall=5.61"
Prepared by TFMoran Inc.	Printed 4/18/2022
HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solution	ns LLC Page 12

		2.85 3.07 3.20 3.3	32	
Device 1	33.85'	12.0" Horiz. Grate	C= 0.600	Limited to weir flow at low heads
Device 1	33.75'	1.0" Vert. Orifice	C= 0.600	Limited to weir flow at low heads

**Discarded OutFlow** Max=0.0 cfs @ 11.35 hrs HW=30.62' (Free Discharge) **2=Exfiltration** (Exfiltration Controls 0.0 cfs)

#4

#5

**Primary OutFlow** Max=0.0 cfs @ 0.00 hrs HW=30.58' TW=31.50' (Dynamic Tailwater) -1=Culvert (Controls 0.0 cfs) **4=Grate** (Controls 0.0 cfs) -5=Orifice ( Controls 0.0 cfs)

Secondary OutFlow Max=0.0 cfs @ 0.00 hrs HW=30.58' TW=31.50' (Dynamic Tailwater) -3=Broad-Crested Rectangular Weir( Controls 0.0 cfs)

## Summary for Link PPOI01: PPOI-01

1.50 ac, 35.52% Impervious, Inflow Depth > 2.16" for 10-Year event Inflow Area = Inflow 3.0 cfs @ 12.15 hrs, Volume= 0.3 af = Primary 3.0 cfs @ 12.15 hrs, Volume= = 0.3 af, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-24.00 hrs, dt= 0.05 hrs

# **APPENDIX F – BMP WORKSHEETS**

(This Page Is Intentionally Blank)



# FILTRATION PRACTICE DESIGN CRITERIA (Env-Wq 1508.07)

## Type/Node Name:

#### Rain Garden 01 (RG-01)

Enter the type of filtration practice (e.g., bioretention system) and the node name in the drainage analysis, if applicable.

		Check if you reviewed the restrictions on unlined systems outlined in Env-Wq 1508.0	7(a).
0.26	ас	A = Area draining to the practice	
0.04	ас	A <sub>I</sub> = Impervious area draining to the practice	
0.17	decimal	I = Percent impervious area draining to the practice, in decimal form	
0.20	unitless	Rv = Runoff coefficient = 0.05 + (0.9 x l)	
0.05	ac-in	WQV= 1" x Rv x A	
191	cf	WQV conversion (ac-in x 43,560 sf/ac x 1ft/12")	
48	cf	25% x WQV (check calc for sediment forebay volume)	
143	cf	75% x WQV (check calc for surface sand filter volume)	
		_Method of Pretreatment? (not required for clean or roof runoff)	
	cf	V <sub>SED</sub> = Sediment forebay volume, if used for pretreatment	<u>&gt;</u> 25%WQV
Calculate ti	me to drair	n if system IS NOT underdrained:	
753	sf	A <sub>SA</sub> = Surface area of the practice	
2.15	- iph	Ksat <sub>DESIGN</sub> = Design infiltration rate <sup>1</sup>	
	_ `	If Ksat (prior to factor of safety) is < 0.50 iph, has an underdrain been provided?	
	Yes/No	(Use the calculations below)	
1.4	hours	$T_{DRAIN} = Drain time = V / (A_{SA} * I_{DESIGN})$	<u>&lt;</u> 72-hrs
Calculate ti	me to drair	n if system IS underdrained:	
	ft	E <sub>WQV</sub> = Elevation of WQV (attach stage-storage table)	
	- -	$\Omega_{\rm c}$ = Discharge at the $\Gamma_{\rm c}$ (attack stage discharge table)	
	CTS	$Q_{WQV}$ = Discharge at the E <sub>WQV</sub> (attach stage-discharge table)	
-	hours	$T_{\text{DRAIN}}$ = Drain time = 2WQV/Q <sub>WQV</sub>	<u>&lt;</u> 72-hrs
- 34.00	hours feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2$	<u>&lt;</u> 72-hrs
- 34.00	hours feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable$	<u>&lt;</u> 72-hrs
- 34.00 30.40	hours feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test place)$	<b>≤ 72-hrs</b> it)
- 34.00 30.40 26.64	feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test pilter E_{ROCK} = Elevation te$	<b>≤ 72-hrs</b> it) pit)
- 34.00 30.40 26.64 34.00	hours feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test piece elevation of bedrock (if none found, enter the lowest elevation of the test piece elevation of the test piece elevation of the bottom of the bottom of the filter course elevation of the test piece elevation of the bottom of the filter course elevation of the test piece elevation test piece elevation of the test piece elevation elevation of the test piece elevation elevat$	≤ 72-hrs it) ≥ 1'
- 34.00 30.40 26.64 34.00 7.36	hours feet feet feet feet feet feet	$\begin{aligned} & Q_{WQV} = Discharge at the  E_{WQV} \text{ (attach stage-discharge table)} \\ & T_{DRAIN} = Drain time = 2WQV/Q_{WQV} \\ & E_{FC} = E levation of the bottom of the filter course material^2 \\ & E_{UD} = Invert elevation of the underdrain (UD), if applicable \\ & E_{SHWT} = E levation of SHWT  (if none found, enter the lowest elevation of the test provide the test of tes$	≤ 72-hrs it) ≥ 1' ≥ 1'
- 34.00 30.40 26.64 34.00 7.36 3.60	hours feet feet feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test place) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test place) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to SHWT from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'</pre>
- 34.00 30.40 26.64 34.00 7.36 3.60 35.87	hours feet feet feet feet feet feet feet fee	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis)$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'</pre>
- 34.00 30.40 26.64 34.00 7.36 3.60 35.87 36.00	feet feet feet feet feet feet feet feet	$\begin{aligned} & Q_{WQV} = Discharge at the E_{WQV} (\text{attach stage-discharge table}) \\ & T_{DRAIN} = Drain time = 2WQV/Q_{WQV} \\ & E_{FC} = Elevation of the bottom of the filter course material^2 \\ & E_{UD} = Invert elevation of the underdrain (UD), if applicable \\ & E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test place elevation of bedrock (if none found, enter the lowest elevation of the test place elevation of bedrock (if none found, enter the lowest elevation of the test place elevation of the test of test $	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'</pre>
- 34.00 30.40 26.64 34.00 7.36 3.60 35.87 36.00 YES	hours feet feet feet feet feet feet feet ft ft	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test provide the test of tes$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre>
- 34.00 30.40 26.64 34.00 7.36 3.60 35.87 36.00 YES If a surface	hours feet feet feet feet feet feet ft ft sand filter	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation \leq Elevation of the top of the practice or underground sand filter is proposed:$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ∴ yes
- 34.00 30.40 26.64 34.00 7.36 3.60 35.87 36.00 YES If a surface YES	feet feet feet feet feet feet feet ft ft sand filter ac	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test provide the test of test of the test of test of$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes  < 10 ac
- 34.00 30.40 26.64 34.00 7.36 3.60 35.87 36.00 YES If a surface YES	cis hours feet feet feet feet feet ft ft sand filter ac cf	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test p) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test p) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course D_{ext} = Elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation ≤ Elevation of the top of the practice Drainage Area check. V = Volume of storage3 (attach a stage-storage table)$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <pre>&lt; 10 ac ≥ 75%WQV</pre>
- 34.00 30.40 26.64 34.00 7.36 3.60 35.87 36.00 YES If a surface YES	cis hours feet feet feet feet feet feet ft ft sand filter ac cf inches	$T_{DRAIN} = Discharge at the E_{WQV} (attach stage-discharge table)$ $T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test p) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test p) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation < Elevation of the top of the practice Drainage Area check. V = Volume of storage3 (attach a stage-storage table) D_{FC} = Filter course thickness$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <pre>&lt; 10 ac </pre> <pre>&gt; 75%WQV 18", or 24" if within GPA</pre>
- 34.00 26.64 34.00 7.36 3.60 35.87 36.00 YES If a surface YES Sheet	feet feet feet feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test p) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test p) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation < Elevation of the top of the practice Drainage Area check. V = Volume of storage3 (attach a stage-storage table) D_{FC} = Filter course thickness Note what sheet in the plan set contains the filter course specification.$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <10 ac  > 75%WQV 18", or 24" if within GPA

If a biorete	ention are	a is proposed:	
YES	ас	Drainage Area no larger than 5 ac?	← yes
501	_cf	V = Volume of storage <sup>3</sup> (attach a stage-storage table)	<u>≥</u> WQV
18.0	inches	D <sub>FC</sub> = Filter course thickness	18", or 24" if within GPA
Sheet	. C-1	1 Note what sheet in the plan set contains the filter course specification	
4.0	:1	Pond side slopes	<u>&gt; 3</u> :1
Sheet	C-0	6 Note what sheet in the plan set contains the planting plans and surface cover	
If porous p	avement	is proposed:	
		Type of pavement proposed (Concrete? Asphalt? Pavers? Etc.)	
	acres	A <sub>SA</sub> = Surface area of the pervious pavement	
	:1	Ratio of the contributing area to the pervious surface area	≤ 5:1
	inches	D <sub>FC</sub> = Filter course thickness	12", or 18" if within GPA
	-		mod. 304.1 (see
Sheet		Note what sheet in the plan set contains the filter course spec.	spec)

1. Rate of the limiting layer (either the filter course or the underlying soil). Ksat<sub>design</sub> includes factor of safey. See Env-Wq 1504.14 for guidance on determining the infiltration rate.

2. See lines 34, 40 and 48 for required depths of filter media.

3. Volume without depending on infiltration. The volume includes the storage above the filter (but below the invert of the outlet stucture, if any), the filter media voids, and the pretreatment area. The storage above the filter media shall not include the volume above the outlet structure, if any.

Designer's Notes: The rain garden is equipped with an underdrain to promote pond drainage during heavier storm events. The pond drains via infiltration alone in less than 72 hours.

NHDES Alteration of Terrain

Last Revised: January 2019

Prepared by TFMoran Inc. HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC

Ele	evation	Horizontal	Storage	Elevation	Horizontal	Storage	
		<u>(sq-π)</u>	(cubic-teet)		<u>(sq-π)</u>		
	32.58	/53	0.0	35.18	753	605.4	
	32.63	/53	15.1	35.23	753	612.9	
	32.68	/53	30.1	35.28	753	620.5	
	32.73	/53	45.2	35.33	753	628.U	
	32.78	/ 03 750	00.2 75.2	30.38	753	030.0	
	3∠.03 22.03	753	75.3	30.43	753	043.1 650.6	
	32.00 32.02	753	90.4	30.40	753	677 2	
	32.93	753	100.4	35.55	753	721.2	
	33.03	753	120.5	35.63	753	721.2	
	33.03	753	150.5	35.68	753	828.1	
	33.00	753	165.7	35.00 35.73	753	801.8	1" Orifico
	33 18	753	180.7	35.78	753	962.9	
	33.23	753	195.8	35.83	753	1 041 7	Elevation
	33.28	753	210.8	35.88	753	1 128 8	
	33 33	753	210.0	35.00	753	1 224 5	
	33.38	753	220.0	35.98	753	1 329 1	
	33 43	753	256.0	00.00	100	1,02011	
	33 48	753	271 1				
	33.53	753	286.1				
	33.58	753	301.2			1	
	33.63	753	316.3	Volum	e of Storage		
	33.68	753	331.3	927 cf	-426  cf = 501  cf		
	33.73	753	346.4		RMP Markshoot)		
	33.78	753	361.4		SIVIE VUIKSIIEEL)		
	33.83	753	376.5			_	
	33.88	753	391.6				
_	33.93	753	406.6				
Bottom	<mark>33.98</mark>	753	421.7				
<b>Filter Elev</b>	34.03	753	432.2				
	34.08	753	439.8				
	34.13	753	447.3				
	34.18	753	454.8				
	34.23	753	462.3				
	34.28	753	469.9				
	34.33	753	477.4				
	34.38	753	484.9				
	34.43	753	492.5				
	34.48	753	500.0				
	34.53	753	507.5				
	34.58	753	515.1				
	34.63	/53	522.6				
	34.68	/53	530.1				
	34.73	/53	537.6				
	34.78	/53	545.2				
	34.83	/53	552.7				
	34.00 24.02	100	50U.Z				
	34.93	100	501.0 575.2				
	34.90	100	010.0 500 0				
	35.03	100	JOZ.0 500 4				
	35.00	100	090.4 507 0				
	55.15	100	591.9				
				•			

## Stage-Area-Storage for Pond RG01: Rain Garden 01

(This Page Is Intentionally Blank)



# FILTRATION PRACTICE DESIGN CRITERIA (Env-Wq 1508.07)

## Type/Node Name:

#### Rain Garden 02 (RG-02)

Enter the type of filtration practice (e.g., bioretention system) and the node name in the drainage analysis, if applicable.

		Check if you reviewed the restrictions on unlined systems outlined in Env-Wq 1508.07	7(a).
0.35	ас	A = Area draining to the practice	
0.08	ас	A <sub>I</sub> = Impervious area draining to the practice	
0.22	decimal	I = Percent impervious area draining to the practice, in decimal form	
0.25	unitless	Rv = Runoff coefficient = 0.05 + (0.9 x l)	
0.09	ac-in	WQV= 1" x Rv x A	
315	cf	WQV conversion (ac-in x 43,560 sf/ac x 1ft/12")	
79	cf	25% x WQV (check calc for sediment forebay volume)	
236	cf	75% x WQV (check calc for surface sand filter volume)	
		_Method of Pretreatment? (not required for clean or roof runoff)	
	cf	V <sub>SED</sub> = Sediment forebay volume, if used for pretreatment	<u>&gt;</u> 25%WQV
Calculate ti	me to drair	n if system IS NOT underdrained:	
637	sf	A <sub>SA</sub> = Surface area of the practice	
0.35	- iph	Ksat <sub>DESIGN</sub> = Design infiltration rate <sup>1</sup>	
	-	If Ksat (prior to factor of safety) is < 0.50 iph, has an underdrain been provided?	
	Yes/No	(Use the calculations below)	
17.0	hours	$T_{\text{DRAIN}} = \text{Drain time} = V / (A_{\text{SA}} * I_{\text{DESIGN}})$	<u>&lt;</u> 72-hrs
Calculate ti	me to drair	n if system IS underdrained:	
	ft	$E_{WOV}$ = Elevation of WQV (attach stage-storage table)	
	-		
	CTS	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table)	
-	hours	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) T <sub>DRAIN</sub> = Drain time = 2WQV/Q <sub>WQV</sub>	<u>&lt;</u> 72-hrs
- 31.00	hours feet	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) T <sub>DRAIN</sub> = Drain time = 2WQV/Q <sub>WQV</sub> $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup>	<u>&lt;</u> 72-hrs
- 31.00	feet feet	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = 2WQV/ $Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable	<u>&lt;</u> 72-hrs
- 31.00 30.00	hours feet feet feet	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = 2WQV/ $Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pi	<b>≤ 72-hrs</b>
- 31.00 30.00 28.03	cts hours feet feet feet feet	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = $2WQV/Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter E <sub>ROCK</sub> = Elevation of bedrock (if none found, enter the lowest elevation of the test	<u>≤</u> 72-hrs it) pit)
- 31.00 30.00 28.03 31.00	cts hours feet feet feet feet feet	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = 2WQV/ $Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter E <sub>ROCK</sub> = Elevation of bedrock (if none found, enter the lowest elevation of the test D <sub>FC to UD</sub> = Depth to UD from the bottom of the filter course	≤ 72-hrs it) ≥ 1'
- 31.00 30.00 28.03 31.00 2.97	cts hours feet feet feet feet feet feet	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = $2WQV/Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilt $E_{ROCK}$ = Elevation of bedrock (if none found, enter the lowest elevation of the test pilt $D_{FC to UD}$ = Depth to UD from the bottom of the filter course $D_{FC to ROCK}$ = Depth to bedrock from the bottom of the filter course	≤ 72-hrs it) ≥ 1' ≥ 1'
- 31.00 30.00 28.03 31.00 2.97 1.00	cts hours feet feet feet feet feet feet feet	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = 2WQV/ $Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter EROCK = Elevation of bedrock (if none found, enter the lowest elevation of the test pilter to UD from the bottom of the filter course $D_{FC to UD}$ = Depth to UD from the bottom of the filter course $D_{FC to ROCK}$ = Depth to bedrock from the bottom of the filter course $D_{FC to SHWT}$ = Depth to SHWT from the bottom of the filter course	≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'
- 31.00 30.00 28.03 31.00 2.97 1.00 33.06	cts hours feet feet feet feet feet feet feet fee	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = 2WQV/ $Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilt $E_{ROCK}$ = Elevation of bedrock (if none found, enter the lowest elevation of the test pilt $D_{FC to UD}$ = Depth to UD from the bottom of the filter course $D_{FC to ROCK}$ = Depth to bedrock from the bottom of the filter course $D_{FC to SHWT}$ = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis)	≤ 72-hrs it) ≥ 1' ≥ 1' ≥ 1' ≥ 1'
- 31.00 30.00 28.03 31.00 2.97 1.00 33.06 33.00	crs hours feet feet feet feet feet feet feet ft	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = $2WQV/Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pl $E_{ROCK}$ = Elevation of bedrock (if none found, enter the lowest elevation of the test pl $E_{ROCK}$ = Depth to UD from the bottom of the filter course $D_{FC to UD}$ = Depth to bedrock from the bottom of the filter course $D_{FC to SHWT}$ = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice	≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'
- 31.00 30.00 28.03 31.00 2.97 1.00 33.06 33.00 NO	cts hours feet feet feet feet feet feet ft ft	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = $2WQV/Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilt $E_{ROCK}$ = Elevation of bedrock (if none found, enter the lowest elevation of the test pilt $D_{FC to UD}$ = Depth to UD from the bottom of the filter course $D_{FC to ROCK}$ = Depth to bedrock from the bottom of the filter course $D_{FC to SHWT}$ = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation $\leq$ Elevation of the top of the practice	≤ 72-hrs it) ≥ 1' ≥ 1' ≥ 1' ≥ 1' ≤ 1'
- 31.00 30.00 28.03 31.00 2.97 1.00 33.06 33.00 NO If a surface	cts hours feet feet feet feet feet feet ft ft sand filter	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = 2WQV/ $Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter EROCK = Elevation of bedrock (if none found, enter the lowest elevation of the test pilter to UD from the bottom of the filter course $D_{FC to UD}$ = Depth to UD from the bottom of the filter course $D_{FC to ROCK}$ = Depth to bedrock from the bottom of the filter course $D_{FC to SHWT}$ = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation $\leq$ Elevation of the top of the practice or underground sand filter is proposed:	≤ 72-hrs it) ≥ 1' ≥ 1' ≥ 1' ≥ 1'      + yes
- 31.00 30.00 28.03 31.00 2.97 1.00 33.06 33.00 NO If a surface YES	cts hours feet feet feet feet feet feet ft ft sand filter ac	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = 2WQV/ $Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter EROCK = Elevation of bedrock (if none found, enter the lowest elevation of the test D $F_{C to UD}$ = Depth to UD from the bottom of the filter course $D_{FC to ROCK}$ = Depth to bedrock from the bottom of the filter course $D_{FC to SHWT}$ = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation <a href="#exercise">Elevation of the top of the practice</a> or underground sand filter is proposed: Drainage Area check.	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes  < 10 ac
- 31.00 28.03 31.00 2.97 1.00 33.06 33.00 NO If a surface YES	cts hours feet feet feet feet feet feet ft ft sand filter ac cf	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = 2WQV/ $Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter course elevation of bedrock (if none found, enter the lowest elevation of the test pilter to UD from the bottom of the filter course $D_{FC to UD}$ = Depth to UD from the bottom of the filter course $D_{FC to ROCK}$ = Depth to bedrock from the bottom of the filter course $D_{FC to SHWT}$ = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation $\leq$ Elevation of the top of the practice or underground sand filter is proposed: Drainage Area check. V = Volume of storage <sup>3</sup> (attach a stage-storage table)	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <pre>&lt; 10 ac ≥ 75%WQV</pre>
- 31.00 30.00 28.03 31.00 2.97 1.00 33.06 33.00 NO If a surface YES	cts hours feet feet feet feet feet feet ft ft sand filter ac cf inches	$Q_{WQV}$ = Discharge at the E <sub>WQV</sub> (attach stage-discharge table) $T_{DRAIN}$ = Drain time = 2WQV/Q <sub>WQV</sub> $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter E $R_{OCK}$ = Elevation of bedrock (if none found, enter the lowest elevation of the test pilter to UD from the bottom of the filter course $D_{FC to UD}$ = Depth to UD from the bottom of the filter course $D_{FC to ROCK}$ = Depth to bedrock from the bottom of the filter course $D_{FC to SHWT}$ = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation $\leq$ Elevation of the top of the practice or underground sand filter is proposed: Drainage Area check. V = Volume of storage <sup>3</sup> (attach a stage-storage table) $D_{FC}$ = Filter course thickness	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> < yes <pre>&lt; 10 ac </pre> <pre>&gt; 75%WQV 18", or 24" if</pre>
- 31.00 28.03 31.00 2.97 1.00 33.06 33.00 NO If a surface YES	cts hours feet feet feet feet feet feet ft ft sand filter ac cf inches	$Q_{WQV}$ = Discharge at the $E_{WQV}$ (attach stage-discharge table) $T_{DRAIN}$ = Drain time = 2WQV/ $Q_{WQV}$ $E_{FC}$ = Elevation of the bottom of the filter course material <sup>2</sup> $E_{UD}$ = Invert elevation of the underdrain (UD), if applicable $E_{SHWT}$ = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter $E_{ROCK}$ = Elevation of bedrock (if none found, enter the lowest elevation of the test pilter $D_{FC to UD}$ = Depth to UD from the bottom of the filter course $D_{FC to ROCK}$ = Depth to bedrock from the bottom of the filter course $D_{FC to SHWT}$ = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation $\leq$ Elevation of the top of the practice or underground sand filter is proposed: Drainage Area check. V = Volume of storage <sup>3</sup> (attach a stage-storage table) $D_{FC}$ = Filter course thickness	<pre>≤ 72-hrs it) pit)         ≥ 1'         ≥ 1'         ≥ 1'         ≥ 1'         ≥ 1'         ≤ 1'         </pre> < 10 ac ≥ 75%WQV 18", or 24" if within GPA
- 31.00 28.03 31.00 2.97 1.00 33.06 33.00 NO If a surface YES Sheet	crs hours feet feet feet feet feet feet ft ft sand filter ac cf inches	$Q_{WQV} = \text{Discharge at the } E_{WQV} (attach stage-discharge table)}$ $T_{DRAIN} = \text{Drain time} = 2WQV/Q_{WQV}$ $E_{FC} = \text{Elevation of the bottom of the filter course material}^{2}$ $E_{UD} = \text{Invert elevation of the underdrain (UD), if applicable}$ $E_{SHWT} = \text{Elevation of SHWT (if none found, enter the lowest elevation of the test pilter course = 10 \text{ Pc to UD} = \text{Depth to UD} from the bottom of the filter course}$ $D_{FC to ROCK} = \text{Depth to UD from the bottom of the filter course}$ $D_{FC to ROCK} = \text{Depth to SHWT from the bottom of the filter course}$ $D_{FC to SHWT} = \text{Depth to SHWT from the bottom of the filter course}$ $Peak elevation of the 50-year storm event (infiltration can be used in analysis)$ $Elevation of the top of the practice$ $50 \text{ peak elevation } \leq \text{Elevation of the top of the practice}$ $Drainage Area check.$ $V = Volume of storage^{3} (attach a stage-storage table)$ $D_{FC} = \text{Filter course thickness}$ Note what sheet in the plan set contains the filter course specification.	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <pre>&lt; 10 ac </pre> <pre>&gt; 75%WQV 18", or 24" if within GPA </pre>

If a bioret	entio	n area i	is proposed:	
YES	ас		Drainage Area no larger than 5 ac?	← yes
494	1_cf		V = Volume of storage <sup>3</sup> (attach a stage-storage table)	<u>&gt;</u> WQV
18.0	inch	nes	D <sub>FC</sub> = Filter course thickness	within GPA
Shee	et	C-11	Note what sheet in the plan set contains the filter course specification	
4.	0 :1		Pond side slopes	<u>&gt; 3</u> :1
Shee	et	C-06	Note what sheet in the plan set contains the planting plans and surface cover	
If porous	paven	nent is	proposed:	
			Type of pavement proposed (Concrete? Asphalt? Pavers? Etc.)	
	acre	es	A <sub>SA</sub> = Surface area of the pervious pavement	
	:1		Ratio of the contributing area to the pervious surface area	≤ 5:1
	inch	nes	D <sub>FC</sub> = Filter course thickness	12", or 18" if within GPA
Shee	et		Note what sheet in the plan set contains the filter course spec.	mod. 304.1 (see spec)

1. Rate of the limiting layer (either the filter course or the underlying soil). Ksat<sub>design</sub> includes factor of safey. See Env-Wq 1504.14 for guidance on determining the infiltration rate.

2. See lines 34, 40 and 48 for required depths of filter media.

3. Volume without depending on infiltration. The volume includes the storage above the filter (but below the invert of the outlet stucture, if any), the filter media voids, and the pretreatment area. The storage above the filter media shall not include the volume above the outlet structure, if any.

Designer's Notes: The rain garden is equipped with an underdrain to promote pond drainage during heavier storm events. The pond drains via infiltration alone in less than 72 hours.

NHDES Alteration of Terrain

Last Revised: January 2019

\_

Prepared by TFMoran Inc. HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC

Ele	evation (feet)	Horizontal (sɑ-ft)	Storage (cubic-feet)	Elev	/ation (feet)	Horizontal (sɑ-ft)	Storage (cubic-feet)	
	29.58	637	0.0		32.18	637	512.1	
	29.63	637	12.7		32.23	637	518.5	
	29.68	637	25.5	;	32.28	637	524.9	
	29.73	637	38.2	;	32.33	637	531.3	
	29.78	637	51.0	:	32.38	637	537.6	
	29.83	637	63.7	:	32.43	637	544.0	
	29.88	637	76.4	:	32.48	637	550.4	
	29.93	637	89.2	;	32.53	637	572.5	
	29.98	637	101.9	;	32.58	637	607.5	
	30.03	637	114.7		32.63	637	645.3	
	30.08	637	127.4		32.68	637	686.3	
	30.13	637	140.1		32.73	637	730.3	
	30.18	037	152.9		32.18	037		1" Orifice
	30.23 20.29	637	100.0		ວ∠.໐ວ ຉຉ຺ຉຉ	627	020.0	Elevation
	30.20	637	170.4		32.00 32.03	637	002.7	Elevation
	30.33	637	203.8		32.95	637	1 002 3	
	30.43	637	216.6		33.03	637	1.028.1	
	30.48	637	229.3		33.08	637	1.028.1	
	30.53	637	242.1		33.13	637	1,028.1	
	30.58	637	254.8				,	
	30.63	637	267.5					
	30.68	637	280.3					
	30.73	637	293.0				1	
	30.78	637	305.8		<mark>√olum</mark> e	e of Storage		
	30.83	637	318.5	8	355 cf	- 361 cf = 494 cf		
	30.88	637	331.2		See B	MP Worksheet)		
Bottom	30.93	637	344.0					
Eiltor Elov	30.98	637	350.7					
	31.03 21.09	637	303.0					
	31.00	637	372.0					
	31.13	637	384 7					
	31.23	637	391.1					
	31.28	637	397.5					
	31.33	637	403.9					
	31.38	637	410.2					
	31.43	637	416.6					
	31.48	637	423.0					
	31.53	637	429.3					
	31.58	637	435.7					
	31.63	637	442.1					
	31.08	637	448.4					
	31.73	037 627	454.8					
	31.70	637	401.2					
	31.88	637	407.0					
	31.93	637	480.3					
	31.98	637	486.7					
	32.03	637	493.0					
	32.08	637	499.4					
	32.13	637	505.8					

## Stage-Area-Storage for Pond RG02: Rain Garden 02

(This Page Is Intentionally Blank)



# FILTRATION PRACTICE DESIGN CRITERIA (Env-Wq 1508.07)

## Type/Node Name:

#### Rain Garden 03 (RG-03)

Enter the type of filtration practice (e.g., bioretention system) and the node name in the drainage analysis, if applicable.

	_	Check if you reviewed the restrictions on unlined systems outlined in Env-Wq 1508.0	7(a).
0.13	ас	A = Area draining to the practice	
0.05	ас	A <sub>I</sub> = Impervious area draining to the practice	
0.36	decimal	I = Percent impervious area draining to the practice, in decimal form	
0.38	unitless	Rv = Runoff coefficient = 0.05 + (0.9 x l)	
0.05	ac-in	WQV= 1" x Rv x A	
177	cf	WQV conversion (ac-in x 43,560 sf/ac x 1ft/12")	
44	cf	25% x WQV (check calc for sediment forebay volume)	
133	cf	75% x WQV (check calc for surface sand filter volume)	
		Method of Pretreatment? (not required for clean or roof runoff)	
	cf	V <sub>SED</sub> = Sediment forebay volume, if used for pretreatment	<u>&gt;</u> 25%WQV
Calculate ti	me to drair	n if system IS NOT underdrained:	
240	sf	A <sub>SA</sub> = Surface area of the practice	
0.15	iph	Ksat <sub>DESIGN</sub> = Design infiltration rate <sup>1</sup>	
	-	If Ksat (prior to factor of safety) is < 0.50 iph, has an underdrain been provided?	
	Yes/No	(Use the calculations below)	
59.0	hours	$T_{DRAIN} = Drain time = V / (A_{SA} * I_{DESIGN})$	<u>&lt;</u> 72-hrs
Calculate ti	me to drair	n if system IS underdrained:	
	ft	E <sub>WQV</sub> = Elevation of WQV (attach stage-storage table)	
	- ofc	$\Omega_{\rm c}$ = Discharge at the $\Gamma_{\rm c}$ (attach stage discharge table)	
	CIS	$Q_{WQV} = Discharge at the E_{WQV}$ (attach stage-discharge table)	
-	hours	$T_{\text{DRAIN}}$ = Drain time = 2WQV/Q <sub>WQV</sub>	<u>&lt;</u> 72-hrs
- 28.00	hours feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2$	<u>&lt;</u> 72-hrs
- 28.00	hours feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable$	<u>&lt;</u> 72-hrs
- 28.00 26.75	hours feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test provide the test pro$	<u>≤</u> 72-hrs it)
28.00 26.75 23.08	feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test pilter E_{ROCK} = Elevation te$	≤ 72-hrs it)
- 28.00 26.75 23.08 28.00	hours feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test piece elevation of bedrock (if none found, enter the lowest elevation of the test piece elevation of the test D_{FC to UD} = Depth to UD from the bottom of the filter course$	≤ 72-hrs it) ≥ 1'
- 28.00 26.75 23.08 28.00 4.92	hours feet feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test provide the test provide the test of test o$	≤ 72-hrs it) ≥ 1' ≥ 1'
- 28.00 26.75 23.08 28.00 4.92 1.25	hours feet feet feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test place) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test place) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to SHWT from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'</pre>
- 28.00 26.75 23.08 28.00 4.92 1.25 29.99	hours feet feet feet feet feet feet feet fee	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test piece elevation of bedrock (if none found, enter the lowest elevation of the test piece elevation of bedrock (if none found, enter the lowest elevation of the test piece elevation of the bottom of the bottom of the filter course elevation of the test piece elevation of the bottom of the filter course elevation of the test piece elevation of the bottom of the bottom of the filter course elevation of the test piece elevation of the bottom of the filter course elevation of the bottom of the bottom of the filter course elevation of the SHWT from the bottom of the filter course elevation of the 50-year storm event (infiltration can be used in analysis)$	≤ 72-hrs it) ≥ 1' ≥ 1' ≥ 1' ≥ 1'
- 28.00 26.75 23.08 28.00 4.92 1.25 29.99 30.00	hours feet feet feet feet feet feet feet fee	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test place) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test place) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course E_{ROCK} = Elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'</pre>
- 28.00 26.75 23.08 28.00 4.92 1.25 29.99 30.00 YES	hours feet feet feet feet feet feet feet ft ft	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter course elevation of bedrock (if none found, enter the lowest elevation of the test pilter to UD from the bottom of the filter course elevation of the test pilter to UD from the bottom of the filter course elevation of the test pilter to SHWT is point to bedrock from the bottom of the filter course elevation of the test for the filter to UD from the bottom of the filter course elevation of the test pilter to SHWT from the bottom of the filter course elevation of the 50-year storm event (infiltration can be used in analysis) elevation of the top of the practice so peak elevation < Elevation of the top of the top of the practice so peak elevation < Elevation of the top of the top of the practice so the$	≤ 72-hrs it) ≥ 1' ≥ 1' ≥ 1' ≥ 1' > 1'
- 28.00 26.75 23.08 28.00 4.92 1.25 29.99 30.00 YES If a surface	hours feet feet feet feet feet feet ft ft sand filter	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test p) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test D) E_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation \leq Elevation of the top of the practice or underground sand filter is proposed:$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'</pre>
- 28.00 26.75 23.08 28.00 4.92 1.25 29.99 30.00 YES If a surface YES	feet feet feet feet feet feet feet ft ft sand filter ac	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test provide the test of test of the test of tes$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes  < 10 ac
- 28.00 26.75 23.08 28.00 4.92 1.25 29.99 30.00 YES If a surface YES	hours feet feet feet feet feet feet ft ft sand filter ac cf	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test p) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test p) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course D_{ext} = Elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation ≤ Elevation of the top of the practice Drainage Area check. V = Volume of storage3 (attach a stage-storage table)$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <pre>&lt; 10 ac ≥ 75%WQV</pre>
- 28.00 26.75 23.08 28.00 4.92 1.25 29.99 30.00 YES If a surface YES	hours feet feet feet feet feet feet ft ft sand filter ac cf inches	$T_{DRAIN} = Discharge at the E_{WQV} (attach stage-discharge table)$ $T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = \text{Invert elevation of the underdrain (UD), if applicable} E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test picture elevation of bedrock (if none found, enter the lowest elevation of the test picture elevation of bedrock (if none found, enter the lowest elevation of the test picture elevation of bedrock (if none found, enter the lowest elevation of the test picture elevation of bedrock (if none found, enter the lowest elevation of the test picture elevation of bedrock from the bottom of the filter course elevation of the top bedrock from the bottom of the filter course elevation of the 50-year storm event (infiltration can be used in analysis) elevation of the top of the practice for underground sand filter is proposed: Drainage Area check. V = Volume of storage3 (attach a stage-storage table) DFC = Filter course thickness$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <pre>&lt; 10 ac </pre> <pre>&gt; 75%WQV 18", or 24" if within GPA</pre>
- 28.00 26.75 23.08 28.00 4.92 1.25 29.99 30.00 YES If a surface YES Sheet	hours feet feet feet feet feet feet ft ft sand filter ac cf inches	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test p) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test p) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to ROCK} = Depth to SHWT from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice S0 peak elevation < Elevation of the top of the practice Drainage Area check. V = Volume of storage3 (attach a stage-storage table) D_{FC} = Filter course thickness Note what sheet in the plan set contains the filter course specification.$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <10 ac  > 75%WQV 18", or 24" if within GPA

If a biorete	ntion area	is proposed:	
YES	ас	Drainage Area no larger than 5 ac?	← yes
178	cf	V = Volume of storage <sup>3</sup> (attach a stage-storage table)	<u>&gt;</u> WQV
18.0	inches	D <sub>FC</sub> = Filter course thickness	18", or 24" if within GPA
Sheet	C-11	Note what sheet in the plan set contains the filter course specification	
4.0	:1	Pond side slopes	<u>&gt; 3</u> :1
Sheet	: C-06	Note what sheet in the plan set contains the planting plans and surface cover	
If porous p	avement i	s proposed:	
		Type of pavement proposed (Concrete? Asphalt? Pavers? Etc.)	
	acres	A <sub>SA</sub> = Surface area of the pervious pavement	
	:1	Ratio of the contributing area to the pervious surface area	≤ 5:1
	inches	D <sub>FC</sub> = Filter course thickness	12", or 18" if within GPA
	-		mod. 304.1 (see
Sheet		Note what sheet in the plan set contains the filter course spec.	spec)

1. Rate of the limiting layer (either the filter course or the underlying soil). Ksat<sub>design</sub> includes factor of safey. See Env-Wq 1504.14 for guidance on determining the infiltration rate.

2. See lines 34, 40 and 48 for required depths of filter media.

3. Volume without depending on infiltration. The volume includes the storage above the filter (but below the invert of the outlet stucture, if any), the filter media voids, and the pretreatment area. The storage above the filter media shall not include the volume above the outlet structure, if any.

Designer's Notes: The rain garden is equipped with an underdrain to promote pond drainage during heavier storm events. The pond drains via infiltration alone in less than 72 hours.

NHDES Alteration of Terrain

Last Revised: January 2019

Prepared by TFMoran Inc. HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC

Ele	evation	Horizontal	Storage	Elevation	Horizontal	Storage	
	(feet)	(sq-ft)	(cubic-feet)	(feet)	(sq-ft)	(cubic-feet)	
	26.58	240	0.0	29.18	240	193.0	
	26.63	240	4.8	29.23	240	195.4	
	26.68	240	9.6	29.28	240	197.8	
	26.73	240	14.4	29.33	240	200.2	
	26.78	240	19.2	29.38	240	202.6	
	26.83	240	24.0	29.43	240	205.0	
	26.88	240	28.8	29.48	240	207.4	
	26.93	240	33.6	29.53	240	215.7	
	26.98	240	38.4	29.58	240	228.9	
	27.03	240	43.2	29.63	240	243.3	
	27.08	240	48.0	29.68	240	258.9	
	27.13	240	52.8	29.73	240	275.8	
	27.18	240	57.6	29.78	240	293.9	1" Orifice
	27.23	240	62.4	29.83	240	313.4	Elevation
	27.28	240	67.Z	29.88	240	334.3	
	27.33	240	72.0	29.93	240	350.7	
	27.38	240	76.8	29.98	240	380.5	
	27.43	240	81.0	30.03	240	390.5	
	27.40	240	80.4				
	27.00	240	91.2			-	
	27.58	240	90.0	Volu	ime of Storage		
	27.03	240	100.0	212	cf = 135 cf = 178 cf		
	27.00	240	105.0	515	CI = 155 CI = 176 CI		
	21.13	240	110.4	(See	BIMP Worksheet)		
	27.70	240	110.2			-	
	27.03	240	120.0				
	27.00	240	124.0				
Bottom	27.93	240	129.0				
Filter Elev	28.03	240	137.8				
	28.08	240	140.2				
	20.00	240	140.2				
	28.18	240	145.0				
	28.23	240	140.0				
	28.28	240	149.8				
	28.33	240	152.2				
	28.38	240	154.6				
	28.43	240	157.0				
	28.48	240	159.4				
	28.53	240	161.8				
	28.58	240	164.2				
	28.63	240	166.6				
	28.68	240	169.0				
	28.73	240	171.4				
	28.78	240	173.8				
	28.83	240	176.2				
	28.88	240	178.6				
	28.93	240	181.0				
	28.98	240	183.4				
	29.03	240	185.8				
	29.08	240	188.2				
	29.13	240	190.6				

## Stage-Area-Storage for Pond RG03: Rain Garden 03

(This Page Is Intentionally Blank)



# FILTRATION PRACTICE DESIGN CRITERIA (Env-Wq 1508.07)

## Type/Node Name:

#### Rain Garden 04 (RG-04)

Enter the type of filtration practice (e.g., bioretention system) and the node name in the drainage analysis, if applicable.

		Check if you reviewed the restrictions on unlined systems outlined in Env-Wq 1508.07(a).								
0.05	ас	A = Area draining to the practice								
0.03	ас	A <sub>I</sub> = Impervious area draining to the practice								
0.51	decimal	I = Percent impervious area draining to the practice, in decimal form								
0.51	unitless	$Rv = Runoff coefficient = 0.05 + (0.9 \times I)$								
0.03	ac-in	WQV= 1" x Rv x A								
94	cf	WQV conversion (ac-in x 43,560 sf/ac x 1ft/12")								
24	cf	25% x WQV (check calc for sediment forebay volume)								
71	cf	75% x WQV (check calc for surface sand filter volume)								
		Method of Pretreatment? (not required for clean or roof runoff)								
	cf	V <sub>SED</sub> = Sediment forebay volume, if used for pretreatment	<u>&gt;</u> 25%WQV							
Calculate time to drain if system IS NOT underdrained:										
205	sf	A <sub>SA</sub> = Surface area of the practice								
1.20	iph	Ksat <sub>DESIGN</sub> = Design infiltration rate <sup>1</sup>								
	-	If Ksat (prior to factor of safety) is < 0.50 iph, has an underdrain been provided?								
	Yes/No	(Use the calculations below)								
4.6	hours	$T_{DRAIN} = Drain time = V / (A_{SA} * I_{DESIGN})$	<u>&lt;</u> 72-hrs							
Calculate ti	me to drair	n if system IS underdrained:								
	ft	E <sub>WQV</sub> = Elevation of WQV (attach stage-storage table)								
	-	$\Omega_{\rm c}$ = Discharge at the $\Gamma_{\rm c}$ (attach stage discharge table)								
	CTS	$Q_{WQV} = Discharge at the E_{WQV}$ (attach stage-discharge table)								
-	hours	$T_{\text{DRAIN}}$ = Drain time = 2WQV/Q <sub>WQV</sub>	<u>&lt;</u> 72-hrs							
- 32.00	hours feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2$	<u>&lt;</u> 72-hrs							
- 32.00	hours feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable$	<u>&lt;</u> 72-hrs							
- 32.00 30.15	hours feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test provide the test pro$	<u>≤</u> 72-hrs it)							
- 32.00 30.15 27.97	feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test pilter E_{ROCK} = Elevation te$	<b>≤ 72-hrs</b> it) pit)							
- 32.00 30.15 27.97 32.00	hours feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test piece elevation of bedrock (if none found, enter the lowest elevation of the test piece elevation of the test D_{FC to UD} = Depth to UD from the bottom of the filter course$	≤ 72-hrs it) ≥ 1'							
- 32.00 30.15 27.97 32.00 4.03	hours feet feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test provide the test provide the test of test o$	≤ 72-hrs it) ≥ 1' ≥ 1'							
- 32.00 30.15 27.97 32.00 4.03 1.85	hours feet feet feet feet feet feet feet fee	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test place) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test place) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'</pre>							
- 32.00 30.15 27.97 32.00 4.03 1.85 33.90	hours feet feet feet feet feet feet feet fee	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test piece elevation of bedrock (if none found, enter the lowest elevation of the test piece elevation of bedrock (if none found, enter the lowest elevation of the test piece elevation of the bottom of the bottom of the filter course elevation of the test piece elevation of the bottom of the filter course elevation of the test piece elevation of the bottom of the bottom of the filter course elevation of the test piece elevation of the bottom of the filter course elevation of the bottom of the bottom of the filter course elevation of the SHWT from the bottom of the filter course elevation of the 50-year storm event (infiltration can be used in analysis)$	≤ 72-hrs it) ≥ 1' ≥ 1' ≥ 1' ≥ 1'							
- 32.00 30.15 27.97 32.00 4.03 1.85 33.90 34.00	feet feet feet feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test place) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test place) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course E_{ROCK} = Elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'</pre>							
- 32.00 30.15 27.97 32.00 4.03 1.85 33.90 34.00 YES	hours feet feet feet feet feet feet feet ft ft	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test pilter course elevation of bedrock (if none found, enter the lowest elevation of the test pilter to UD from the bottom of the filter course elevation of the test pilter to UD from the bottom of the filter course elevation of the test pilter to SHWT is point to bedrock from the bottom of the filter course elevation of the test for the filter to UD from the bottom of the filter course elevation of the test pilter to SHWT from the bottom of the filter course elevation of the 50-year storm event (infiltration can be used in analysis) elevation of the top of the practice so peak elevation < Elevation of the top of the top of the practice so peak elevation < Elevation of the top of the top of the practice so the$	≤ 72-hrs it) ≥ 1' ≥ 1' ≥ 1' ≥ 1' > 1'							
- 32.00 30.15 27.97 32.00 4.03 1.85 33.90 34.00 YES If a surface	feet feet feet feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test p) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test p) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation \leq Elevation of the top of the practice or underground sand filter is proposed:$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' ≥ 1'</pre>							
- 32.00 30.15 27.97 32.00 4.03 1.85 33.90 34.00 YES If a surface YES	feet feet feet feet feet feet feet ft ft sand filter ac	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test provide the test of test of the test of test of$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes  < 10 ac							
- 32.00 30.15 27.97 32.00 4.03 1.85 33.90 34.00 YES If a surface YES	cis hours feet feet feet feet feet ft ft sand filter ac cf	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test p) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test p) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course D_{ext} = Elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation ≤ Elevation of the top of the practice Drainage Area check. V = Volume of storage3 (attach a stage-storage table)$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <pre>&lt; 10 ac ≥ 75%WQV</pre>							
- 32.00 30.15 27.97 32.00 4.03 1.85 33.90 34.00 YES If a surface YES	cis hours feet feet feet feet feet feet ft ft sand filter ac cf inches	$T_{DRAIN} = Discharge at the E_{WQV} (attach stage-discharge table)$ $T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test picture elevation of bedrock (if none found, enter the lowest elevation of the test picture elevation of bedrock (if none found, enter the lowest elevation of the test picture elevation of bedrock (if none found, enter the lowest elevation of the test picture elevation of bedrock (if none found, enter the lowest elevation of the test picture elevation of bedrock from the bottom of the filter course elevation of the top bedrock from the bottom of the filter course elevation of the SHWT from the bottom of the filter course elevation of the 50-year storm event (infiltration can be used in analysis) elevation of the top of the practice for picture elevation < Elevation of the top of the practice elevation of the top of the top of the practice elevation elevation < Elevation of the top of the practice elevation elevation elevation of the top of the top of the practice elevation elevation elevation of the top of the top of the practice elevation ele$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <pre>&lt; 10 ac </pre> <pre>&gt; 75%WQV 18", or 24" if within GPA</pre>							
- 32.00 30.15 27.97 32.00 4.03 1.85 33.90 34.00 YES If a surface YES Sheet	feet feet feet feet feet feet feet feet	$T_{DRAIN} = Drain time = 2WQV/Q_{WQV}$ $E_{FC} = Elevation of the bottom of the filter course material2 E_{UD} = Invert elevation of the underdrain (UD), if applicable E_{SHWT} = Elevation of SHWT (if none found, enter the lowest elevation of the test p) E_{ROCK} = Elevation of bedrock (if none found, enter the lowest elevation of the test p) D_{FC to UD} = Depth to UD from the bottom of the filter course D_{FC to ROCK} = Depth to bedrock from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course D_{FC to SHWT} = Depth to SHWT from the bottom of the filter course Peak elevation of the 50-year storm event (infiltration can be used in analysis) Elevation of the top of the practice 50 peak elevation < Elevation of the top of the practice Drainage Area check. V = Volume of storage3 (attach a stage-storage table) D_{FC} = Filter course thickness Note what sheet in the plan set contains the filter course specification.$	<pre>≤ 72-hrs it) pit) ≥ 1' ≥ 1' ≥ 1' </pre> ← yes <10 ac  > 75%WQV 18", or 24" if within GPA							

If a bioretention area is proposed:									
YES	ас	Drainage Area no larger than 5 ac?	← yes						
129	cf	V = Volume of storage <sup>3</sup> (attach a stage-storage table)	<u>&gt;</u> WQV						
18.0	inches	D <sub>FC</sub> = Filter course thickness	within GPA						
Sheet	C-11	Note what sheet in the plan set contains the filter course specification							
4.0	:1	Pond side slopes	<u>&gt; 3</u> :1						
Sheet	C-06	Note what sheet in the plan set contains the planting plans and surface cover							
If porous pavement is proposed:									
		Type of pavement proposed (Concrete? Asphalt? Pavers? Etc.)							
	acres	A <sub>SA</sub> = Surface area of the pervious pavement							
	:1	Ratio of the contributing area to the pervious surface area	≤ 5:1						
	inches	D <sub>FC</sub> = Filter course thickness	12", or 18" if within GPA						
	-		mod. 304.1 (see						
Sheet		Note what sheet in the plan set contains the filter course spec.	spec)						

1. Rate of the limiting layer (either the filter course or the underlying soil). Ksat<sub>design</sub> includes factor of safey. See Env-Wq 1504.14 for guidance on determining the infiltration rate.

2. See lines 34, 40 and 48 for required depths of filter media.

3. Volume without depending on infiltration. The volume includes the storage above the filter (but below the invert of the outlet stucture, if any), the filter media voids, and the pretreatment area. The storage above the filter media shall not include the volume above the outlet structure, if any.

Designer's Notes: The rain garden is equipped with an underdrain to promote pond drainage during heavier storm events. The pond drains via infiltration alone in less than 72 hours.

NHDES Alteration of Terrain

Last Revised: January 2019

Prepared by TFMoran Inc. HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solutions LLC

El	evation	Horizontal	Storage	Ele	evation	Horizontal	Storage	
	(feet)	(sq-ft)	(cubic-feet)		(feet)	(sq-ft)	(cubic-feet)	
	30.58	205	0.0		33.18	205	164.8	
	30.63	205	4.1		33.23	205	166.9	
	30.68	205	8.2		33.28	205	168.9	
	30.73	205	12.3		33.33	205	171.0	
	30.78	205	16.4		33.38	205	173.0	
	30.83	205	20.5		33.43	205	175.1	
	30.88	205	24.6		33.48	205	177.1	
	30.93	205	28.7		33.53	205	184.3	
	30.98	205	32.8		33.58	205	195.6	
	31.03	205	36.9		33.63	205	207.9	
	31.08	205	41.0		33.68	205	221.3	
	31.13	205	45.1		<u>33.73</u>	205	235.7	1" Orifice
	31.18	205	49.2		33.78	205	251.3	Elevation
	31.23	205	53.3		33.83	205	268.1	Lievation
	31.28	205	57.4		33.88	205	286.1	
	31.33	205	61.5		33.93	205	305.4	
	31.38	205	65.6		33.98	205	326.0	
	31.43	205	69.7					
	31.48	205	73.8					
	31.53	205	77.9					
	31.58	205	82.0					
	31.63	205	86.1		Volum	e of Storage		
	31 68	205	90.2		$\frac{1}{244}$ of	115 of 120 of		
	31 73	205	94 3		244 CI	-115  CI = 129  CI		
	31 78	205	98.4		(See E	BMP Worksheet)		
	31.83	205	102.5				1	
	31.88	205	106.6					
	31.93	205	110.7					
Bottom	31.98	205	114.8					
Eiltor Elov	32.03	205	117.7					
	32.08	205	119.7					
	32.13	205	121.8					
	32.18	205	123.8					
	32.23	205	125.9					
	32.28	205	127.9					
	32.33	205	130.0					
	32.38	205	132.0					
	32.43	205	134.1					
	32.48	205	136.1					
	32.53	205	138.2					
	32 58	205	140.2					
	32.63	205	142.3					
	32.68	205	144.3					
	32 73	205	146.4					
	32 78	205	148 4					
	32.83	205	150.5					
	32.88	205	152.5					
	32.93	205	154.6					
	32.98	200	156.6					
	33.03	200	158.7					
	33.08	200	160.7					
	33 13	205	162.8					
	00.10	200	102.0	1				

# Stage-Area-Storage for Pond RG04: Rain Garden 04
(This Page Is Intentionally Blank)

## **APPENDIX G – RIPRAP CALCULATIONS**

(This Page Is Intentionally Blank)

## **RIPRAP OUTLET PROTECTION**



 $d_{50} = (0.02/Tw)(Q/Do)^{(4/3)} =$  6.00 inches (or Min. 6")

<u>% by weight passing given the D<sub>50</sub> Size</u>		Size of stone (inches)			
100 85 50 15	(See Last Page of Calculations	9.00 7.80 6.00 1.80	- - -	12.00 10.80 9.00 3.00	

## **RIPRAP OUTLET PROTECTION**

-		Location:	FES-02	_	
				Design Flow = Tailwater =	Q = 0.87 cfs Tw = 0.446667 feet
				Pipe Dia.=	Do = 0.67 feet
TW>=1/2Do -> La = Length = 3.0Q/Do^(3/2) + 7Do =	3.0	feet			
W <sub>1</sub> = Width = 3Do+(0.4)(La)=	3.0	feet	(or Width of Channe	el)	
$W_2 = Width = 3Do =$	2.0	feet			

D = Depth = (1.5)(d50)= 9 inches (or Min. 9")

 $d_{50} = (0.02/Tw)(Q/Do)^{(4/3)} =$  6.00 inches (or Min. 6")

<u>% by weight passing given the <math>D_{50}</math> Size</u>		Size of stone (inches)		
100 85 50 15	(See Last Page of Calculations for 25-Year Flows)	9.00 7.80 6.00 1.80	- - -	12.00 10.80 9.00 3.00

## **RIPRAP OUTLET PROTECTION**



 $d_{50} = (0.02/Tw)(Q/Do)^{(4/3)} =$  6.00 inches (or Min. 6")

<u>% by weight passing given the <math>D_{50}</math> Size</u>		Size of stone (inches)		
100 85 50 15	(See Last Page of Calculations for 25-Year Flows)	9.00 7.80 6.00 1.80	- - -	12.00 10.80 9.00 3.00

## **RIPRAP OUTLET PROTECTION**



 $d_{50} = (0.02/Tw)(Q/Do)^{(4/3)} =$  6.00 inches (or Min. 6")

<u>% by weight passing given the <math>D_{50}</math> Size</u>		Size of stone	(inche	<u>s)</u>
100 85 50 15	(See Last Page of Calculations for 25-Year Flows)	9.00 7.80 6.00 1.80	- - -	12.00 10.80 9.00 3.00

<b>45407-120_Pre &amp; Post Development</b> Prepared by TFMoran Inc.	Type III 24-hr	Riprap Calcs - 25-Year 25-Year Rainfall=7.12" Printed 4/18/2022
HydroCAD® 10.10-7a s/n 00866 © 2021 HydroCAD Software Solution	s LLC	Page 1
Time span=0.00-24.00 hrs, dt=0.05 hr Runoff by SCS TR-20 method, UH=SCS Reach routing by Dyn-Stor-Ind method - Pond routi	s, 481 points 5, Weighted-Q ng by Dyn-Stor-	Ind method

Pond RG01: Rain Garden 01	Peak Elev=35.61' Storage=748.8 cf Inflow=0.49 cfs 0.0 af
Discarded=0.04 cfs 0.0 af	Primary=0.00 cfs 0.0 af Secondary=0.00 cfs 0.0 af Outflow=0.04 cfs 0.0 af
Pond RG02: Rain Garden 02	Peak Elev=33.04' Storage=1.028.1 cf Inflow=1.45 cfs 0.1 af
Discarded=0.01 cfs 0.0 af	Primary=0.87 cfs 0.1 af Secondary=0.67 cfs 0.0 af Outflow=1.54 cfs 0.1 af
Pond RG03: Rain Garden 03	Peak Elev=29.99' Storage=383.3 cf Inflow=0.61 cfs 0.0 af
Pond RG03: Rain Garden 03 Discarded=0.00 cfs 0.0 af	Peak Elev=29.99' Storage=383.3 cf Inflow=0.61 cfs 0.0 af Primary=0.27 cfs 0.0 af Secondary=0.34 cfs 0.0 af Outflow=0.61 cfs 0.0 af
Pond RG03: Rain Garden 03 Discarded=0.00 cfs 0.0 af Pond RG04: Rain Garden 04	Peak Elev=29.99' Storage=383.3 cf Inflow=0.61 cfs 0.0 af Primary=0.27 cfs 0.0 af Secondary=0.34 cfs 0.0 af Outflow=0.61 cfs 0.0 af Peak Elev=33.87' Storage=280.8 cf Inflow=0.20 cfs 0.0 af

(This Page Is Intentionally Blank)

# **APPENDIX H - NRCS WEB SOIL SURVEY**

(This Page Is Intentionally Blank)



United States Department of Agriculture

Natural Resources Conservation

Service

A product of the National Cooperative Soil Survey, a joint effort of the United States Department of Agriculture and other Federal agencies, State agencies including the Agricultural Experiment Stations, and local participants

# Custom Soil Resource Report for **Rockingham County, New Hampshire**

437 Lafayette Road



# Preface

Soil surveys contain information that affects land use planning in survey areas. They highlight soil limitations that affect various land uses and provide information about the properties of the soils in the survey areas. Soil surveys are designed for many different users, including farmers, ranchers, foresters, agronomists, urban planners, community officials, engineers, developers, builders, and home buyers. Also, conservationists, teachers, students, and specialists in recreation, waste disposal, and pollution control can use the surveys to help them understand, protect, or enhance the environment.

Various land use regulations of Federal, State, and local governments may impose special restrictions on land use or land treatment. Soil surveys identify soil properties that are used in making various land use or land treatment decisions. The information is intended to help the land users identify and reduce the effects of soil limitations on various land uses. The landowner or user is responsible for identifying and complying with existing laws and regulations.

Although soil survey information can be used for general farm, local, and wider area planning, onsite investigation is needed to supplement this information in some cases. Examples include soil quality assessments (http://www.nrcs.usda.gov/wps/portal/nrcs/main/soils/health/) and certain conservation and engineering applications. For more detailed information, contact your local USDA Service Center (https://offices.sc.egov.usda.gov/locator/app?agency=nrcs) or your NRCS State Soil Scientist (http://www.nrcs.usda.gov/wps/portal/nrcs/detail/soils/contactus/? cid=nrcs142p2\_053951).

Great differences in soil properties can occur within short distances. Some soils are seasonally wet or subject to flooding. Some are too unstable to be used as a foundation for buildings or roads. Clayey or wet soils are poorly suited to use as septic tank absorption fields. A high water table makes a soil poorly suited to basements or underground installations.

The National Cooperative Soil Survey is a joint effort of the United States Department of Agriculture and other Federal agencies, State agencies including the Agricultural Experiment Stations, and local agencies. The Natural Resources Conservation Service (NRCS) has leadership for the Federal part of the National Cooperative Soil Survey.

Information about soils is updated periodically. Updated information is available through the NRCS Web Soil Survey, the site for official soil survey information.

The U.S. Department of Agriculture (USDA) prohibits discrimination in all its programs and activities on the basis of race, color, national origin, age, disability, and where applicable, sex, marital status, familial status, parental status, religion, sexual orientation, genetic information, political beliefs, reprisal, or because all or a part of an individual's income is derived from any public assistance program. (Not all prohibited bases apply to all programs.) Persons with disabilities who require

alternative means for communication of program information (Braille, large print, audiotape, etc.) should contact USDA's TARGET Center at (202) 720-2600 (voice and TDD). To file a complaint of discrimination, write to USDA, Director, Office of Civil Rights, 1400 Independence Avenue, S.W., Washington, D.C. 20250-9410 or call (800) 795-3272 (voice) or (202) 720-6382 (TDD). USDA is an equal opportunity provider and employer.

# Contents

Preface	2
How Soil Surveys Are Made	5
Soil Map	
Soil Map	9
Legend	10
Map Unit Legend	11
Map Unit Descriptions	11
Rockingham County, New Hampshire	
299—Udorthents, smoothed	13
799—Urban land-Canton complex, 3 to 15 percent slopes	13
References	15

# **How Soil Surveys Are Made**

Soil surveys are made to provide information about the soils and miscellaneous areas in a specific area. They include a description of the soils and miscellaneous areas and their location on the landscape and tables that show soil properties and limitations affecting various uses. Soil scientists observed the steepness, length, and shape of the slopes; the general pattern of drainage; the kinds of crops and native plants; and the kinds of bedrock. They observed and described many soil profiles. A soil profile is the sequence of natural layers, or horizons, in a soil. The profile extends from the surface down into the unconsolidated material in which the soil formed or from the surface down to bedrock. The unconsolidated material is devoid of roots and other living organisms and has not been changed by other biological activity.

Currently, soils are mapped according to the boundaries of major land resource areas (MLRAs). MLRAs are geographically associated land resource units that share common characteristics related to physiography, geology, climate, water resources, soils, biological resources, and land uses (USDA, 2006). Soil survey areas typically consist of parts of one or more MLRA.

The soils and miscellaneous areas in a survey area occur in an orderly pattern that is related to the geology, landforms, relief, climate, and natural vegetation of the area. Each kind of soil and miscellaneous area is associated with a particular kind of landform or with a segment of the landform. By observing the soils and miscellaneous areas in the survey area and relating their position to specific segments of the landform, a soil scientist develops a concept, or model, of how they were formed. Thus, during mapping, this model enables the soil scientist to predict with a considerable degree of accuracy the kind of soil or miscellaneous area at a specific location on the landscape.

Commonly, individual soils on the landscape merge into one another as their characteristics gradually change. To construct an accurate soil map, however, soil scientists must determine the boundaries between the soils. They can observe only a limited number of soil profiles. Nevertheless, these observations, supplemented by an understanding of the soil-vegetation-landscape relationship, are sufficient to verify predictions of the kinds of soil in an area and to determine the boundaries.

Soil scientists recorded the characteristics of the soil profiles that they studied. They noted soil color, texture, size and shape of soil aggregates, kind and amount of rock fragments, distribution of plant roots, reaction, and other features that enable them to identify soils. After describing the soils in the survey area and determining their properties, the soil scientists assigned the soils to taxonomic classes (units). Taxonomic classes are concepts. Each taxonomic class has a set of soil characteristics with precisely defined limits. The classes are used as a basis for comparison to classify soils systematically. Soil taxonomy, the system of taxonomic classification used in the United States, is based mainly on the kind and character of soil properties and the arrangement of horizons within the profile. After the soil

scientists classified and named the soils in the survey area, they compared the individual soils with similar soils in the same taxonomic class in other areas so that they could confirm data and assemble additional data based on experience and research.

The objective of soil mapping is not to delineate pure map unit components; the objective is to separate the landscape into landforms or landform segments that have similar use and management requirements. Each map unit is defined by a unique combination of soil components and/or miscellaneous areas in predictable proportions. Some components may be highly contrasting to the other components of the map unit. The presence of minor components in a map unit in no way diminishes the usefulness or accuracy of the data. The delineation of such landforms and landform segments on the map provides sufficient information for the development of resource plans. If intensive use of small areas is planned, onsite investigation is needed to define and locate the soils and miscellaneous areas.

Soil scientists make many field observations in the process of producing a soil map. The frequency of observation is dependent upon several factors, including scale of mapping, intensity of mapping, design of map units, complexity of the landscape, and experience of the soil scientist. Observations are made to test and refine the soil-landscape model and predictions and to verify the classification of the soils at specific locations. Once the soil-landscape model is refined, a significantly smaller number of measurements of individual soil properties are made and recorded. These measurements may include field measurements, such as those for color, depth to bedrock, and texture, and laboratory measurements, such as those for content of sand, silt, clay, salt, and other components. Properties of each soil typically vary from one point to another across the landscape.

Observations for map unit components are aggregated to develop ranges of characteristics for the components. The aggregated values are presented. Direct measurements do not exist for every property presented for every map unit component. Values for some properties are estimated from combinations of other properties.

While a soil survey is in progress, samples of some of the soils in the area generally are collected for laboratory analyses and for engineering tests. Soil scientists interpret the data from these analyses and tests as well as the field-observed characteristics and the soil properties to determine the expected behavior of the soils under different uses. Interpretations for all of the soils are field tested through observation of the soils in different uses and under different levels of management. Some interpretations are modified to fit local conditions, and some new interpretations are developed to meet local needs. Data are assembled from other sources, such as research information, production records, and field experience of specialists. For example, data on crop yields under defined levels of management are assembled from farm records and from field or plot experiments on the same kinds of soil.

Predictions about soil behavior are based not only on soil properties but also on such variables as climate and biological activity. Soil conditions are predictable over long periods of time, but they are not predictable from year to year. For example, soil scientists can predict with a fairly high degree of accuracy that a given soil will have a high water table within certain depths in most years, but they cannot predict that a high water table will always be at a specific level in the soil on a specific date.

After soil scientists located and identified the significant natural bodies of soil in the survey area, they drew the boundaries of these bodies on aerial photographs and

identified each as a specific map unit. Aerial photographs show trees, buildings, fields, roads, and rivers, all of which help in locating boundaries accurately.

# Soil Map

The soil map section includes the soil map for the defined area of interest, a list of soil map units on the map and extent of each map unit, and cartographic symbols displayed on the map. Also presented are various metadata about data used to produce the map, and a description of each soil map unit.



	MAP LEGEND	)	MAP INFORMATION
Area of Interest (A0	) 8	Spoil Area	The soil surveys that comprise your AOI were mapped at
Area of	Interest (AOI)	Stony Spot	1.24,000.
Soils	<b>(</b> )	Very Stony Spot	Warning: Soil Map may not be valid at this scale.
Soli Ma		Wet Spot	
Soli Ma		Other	Enlargement of maps beyond the scale of mapping can cause
Soil Ma	p Unit Points	Special Line Features	line placement. The maps do not show the small areas of
Special Point Fea	atures t Water Fe	atures	contrasting soils that could have been shown at a more detailed scale
Blowed Borrow	Dit ~	Streams and Canals	
Borrow	Transpor	tation	Please rely on the bar scale on each map sheet for map
	+++	Rails	measurements.
Closed	Depression	Interstate Highways	Source of Map: Natural Resources Conservation Service
Gravel	Pit 📈 📈	US Routes	Web Soil Survey URL:
. Gravelly	y Spot 🦯	Major Roads	Coordinate System: Web Mercator (EPSG:3857)
🔇 Landfill	~	Local Roads	Maps from the Web Soil Survey are based on the Web Mercator
👗 🛛 Lava Fl	ow Backgrou	Ind	projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the
🚲 Marsh o	or swamp	Aerial Photography	Albers equal-area conic projection, should be used if more
🙊 Mine or	Quarry		accurate calculations of distance or area are required.
Miscella	aneous Water		This product is generated from the USDA-NRCS certified data as
O Perenni	ial Water		of the version date(s) listed below.
🤝 🛛 Rock O	utcrop		Soil Survey Area: Rockingham County, New Hampshire
Saline S	Spot		Survey Area Data: Version 24, Aug 31, 2021
Sandy S	Spot		Soil map units are labeled (as space allows) for map scales
Severel	y Eroded Spot		1:50,000 or larger.
Sinkhol	e		Date(c) aerial images were photographed: Dec 31, 2000— lun
🚡 Slide or	Slip		14, 2017
ø Sodic S	pot		The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor chifting of map unit boundaries may be evident

## **Map Unit Legend**

		-	
Map Unit Symbol	Map Unit Name	Acres in AOI	Percent of AOI
299	Udorthents, smoothed	2.6	12.8%
799	Urban land-Canton complex, 3 to 15 percent slopes	17.9	87.2%
Totals for Area of Interest		20.5	100.0%

## **Map Unit Descriptions**

The map units delineated on the detailed soil maps in a soil survey represent the soils or miscellaneous areas in the survey area. The map unit descriptions, along with the maps, can be used to determine the composition and properties of a unit.

A map unit delineation on a soil map represents an area dominated by one or more major kinds of soil or miscellaneous areas. A map unit is identified and named according to the taxonomic classification of the dominant soils. Within a taxonomic class there are precisely defined limits for the properties of the soils. On the landscape, however, the soils are natural phenomena, and they have the characteristic variability of all natural phenomena. Thus, the range of some observed properties may extend beyond the limits defined for a taxonomic class. Areas of soils of a single taxonomic class rarely, if ever, can be mapped without including areas of other taxonomic classes. Consequently, every map unit is made up of the soils or miscellaneous areas for which it is named and some minor components that belong to taxonomic classes other than those of the major soils.

Most minor soils have properties similar to those of the dominant soil or soils in the map unit, and thus they do not affect use and management. These are called noncontrasting, or similar, components. They may or may not be mentioned in a particular map unit description. Other minor components, however, have properties and behavioral characteristics divergent enough to affect use or to require different management. These are called contrasting, or dissimilar, components. They generally are in small areas and could not be mapped separately because of the scale used. Some small areas of strongly contrasting soils or miscellaneous areas are identified by a special symbol on the maps. If included in the database for a given area, the contrasting minor components are identified in the map unit descriptions along with some characteristics of each. A few areas of minor components may not have been observed, and consequently they are not mentioned in the descriptions, especially where the pattern was so complex that it was impractical to make enough observations to identify all the soils and miscellaneous areas on the landscape.

The presence of minor components in a map unit in no way diminishes the usefulness or accuracy of the data. The objective of mapping is not to delineate pure taxonomic classes but rather to separate the landscape into landforms or landform segments that have similar use and management requirements. The delineation of such segments on the map provides sufficient information for the development of resource plans. If intensive use of small areas is planned, however,

onsite investigation is needed to define and locate the soils and miscellaneous areas.

An identifying symbol precedes the map unit name in the map unit descriptions. Each description includes general facts about the unit and gives important soil properties and qualities.

Soils that have profiles that are almost alike make up a *soil series*. Except for differences in texture of the surface layer, all the soils of a series have major horizons that are similar in composition, thickness, and arrangement.

Soils of one series can differ in texture of the surface layer, slope, stoniness, salinity, degree of erosion, and other characteristics that affect their use. On the basis of such differences, a soil series is divided into *soil phases*. Most of the areas shown on the detailed soil maps are phases of soil series. The name of a soil phase commonly indicates a feature that affects use or management. For example, Alpha silt loam, 0 to 2 percent slopes, is a phase of the Alpha series.

Some map units are made up of two or more major soils or miscellaneous areas. These map units are complexes, associations, or undifferentiated groups.

A *complex* consists of two or more soils or miscellaneous areas in such an intricate pattern or in such small areas that they cannot be shown separately on the maps. The pattern and proportion of the soils or miscellaneous areas are somewhat similar in all areas. Alpha-Beta complex, 0 to 6 percent slopes, is an example.

An *association* is made up of two or more geographically associated soils or miscellaneous areas that are shown as one unit on the maps. Because of present or anticipated uses of the map units in the survey area, it was not considered practical or necessary to map the soils or miscellaneous areas separately. The pattern and relative proportion of the soils or miscellaneous areas are somewhat similar. Alpha-Beta association, 0 to 2 percent slopes, is an example.

An *undifferentiated group* is made up of two or more soils or miscellaneous areas that could be mapped individually but are mapped as one unit because similar interpretations can be made for use and management. The pattern and proportion of the soils or miscellaneous areas in a mapped area are not uniform. An area can be made up of only one of the major soils or miscellaneous areas, or it can be made up of all of them. Alpha and Beta soils, 0 to 2 percent slopes, is an example.

Some surveys include *miscellaneous areas*. Such areas have little or no soil material and support little or no vegetation. Rock outcrop is an example.

## **Rockingham County, New Hampshire**

#### 299-Udorthents, smoothed

#### **Map Unit Setting**

National map unit symbol: 9cmt Elevation: 0 to 840 feet Mean annual precipitation: 44 to 49 inches Mean annual air temperature: 48 degrees F Frost-free period: 155 to 165 days Farmland classification: Not prime farmland

#### **Map Unit Composition**

Udorthents and similar soils: 100 percent Estimates are based on observations, descriptions, and transects of the mapunit.

#### **Description of Udorthents**

#### **Properties and qualities**

Depth to restrictive feature: More than 80 inches Drainage class: Excessively drained Depth to water table: More than 80 inches Frequency of flooding: None Frequency of ponding: None

#### 799—Urban land-Canton complex, 3 to 15 percent slopes

#### **Map Unit Setting**

National map unit symbol: 9cq0 Elevation: 0 to 1,000 feet Mean annual precipitation: 42 to 46 inches Mean annual air temperature: 45 to 48 degrees F Frost-free period: 120 to 160 days Farmland classification: Not prime farmland

#### **Map Unit Composition**

*Urban land:* 55 percent *Canton and similar soils:* 20 percent *Minor components:* 25 percent *Estimates are based on observations, descriptions, and transects of the mapunit.* 

#### **Description of Canton**

#### Setting

Parent material: Till

#### **Typical profile**

*H1 - 0 to 5 inches:* gravelly fine sandy loam *H2 - 5 to 21 inches:* gravelly fine sandy loam *H3 - 21 to 60 inches:* loamy sand

#### **Properties and qualities**

Slope: 3 to 8 percent
Depth to restrictive feature: More than 80 inches
Drainage class: Well drained
Runoff class: Low
Capacity of the most limiting layer to transmit water (Ksat): High (2.00 to 6.00 in/hr)
Depth to water table: More than 80 inches
Frequency of flooding: None
Frequency of ponding: None
Available water supply, 0 to 60 inches: Low (about 5.3 inches)

#### Interpretive groups

Land capability classification (irrigated): None specified Land capability classification (nonirrigated): 2e Hydrologic Soil Group: A Ecological site: F144AY034CT - Well Drained Till Uplands Hydric soil rating: No

#### Minor Components

#### Udorthents

Percent of map unit: 5 percent Hydric soil rating: No

#### Squamscott and scitico

Percent of map unit: 4 percent Landform: Marine terraces Hydric soil rating: Yes

#### Walpole

Percent of map unit: 4 percent Landform: Depressions Hydric soil rating: Yes

#### Chatfield

Percent of map unit: 4 percent Hydric soil rating: No

#### Scituate and newfields

Percent of map unit: 4 percent Hydric soil rating: No

#### Boxford and eldridge

Percent of map unit: 4 percent Hydric soil rating: No

# References

American Association of State Highway and Transportation Officials (AASHTO). 2004. Standard specifications for transportation materials and methods of sampling and testing. 24th edition.

American Society for Testing and Materials (ASTM). 2005. Standard classification of soils for engineering purposes. ASTM Standard D2487-00.

Cowardin, L.M., V. Carter, F.C. Golet, and E.T. LaRoe. 1979. Classification of wetlands and deep-water habitats of the United States. U.S. Fish and Wildlife Service FWS/OBS-79/31.

Federal Register. July 13, 1994. Changes in hydric soils of the United States.

Federal Register. September 18, 2002. Hydric soils of the United States.

Hurt, G.W., and L.M. Vasilas, editors. Version 6.0, 2006. Field indicators of hydric soils in the United States.

National Research Council. 1995. Wetlands: Characteristics and boundaries.

Soil Survey Division Staff. 1993. Soil survey manual. Soil Conservation Service. U.S. Department of Agriculture Handbook 18. http://www.nrcs.usda.gov/wps/portal/ nrcs/detail/national/soils/?cid=nrcs142p2\_054262

Soil Survey Staff. 1999. Soil taxonomy: A basic system of soil classification for making and interpreting soil surveys. 2nd edition. Natural Resources Conservation Service, U.S. Department of Agriculture Handbook 436. http://www.nrcs.usda.gov/wps/portal/nrcs/detail/national/soils/?cid=nrcs142p2\_053577

Soil Survey Staff. 2010. Keys to soil taxonomy. 11th edition. U.S. Department of Agriculture, Natural Resources Conservation Service. http://www.nrcs.usda.gov/wps/portal/nrcs/detail/national/soils/?cid=nrcs142p2\_053580

Tiner, R.W., Jr. 1985. Wetlands of Delaware. U.S. Fish and Wildlife Service and Delaware Department of Natural Resources and Environmental Control, Wetlands Section.

United States Army Corps of Engineers, Environmental Laboratory. 1987. Corps of Engineers wetlands delineation manual. Waterways Experiment Station Technical Report Y-87-1.

United States Department of Agriculture, Natural Resources Conservation Service. National forestry manual. http://www.nrcs.usda.gov/wps/portal/nrcs/detail/soils/ home/?cid=nrcs142p2 053374

United States Department of Agriculture, Natural Resources Conservation Service. National range and pasture handbook. http://www.nrcs.usda.gov/wps/portal/nrcs/ detail/national/landuse/rangepasture/?cid=stelprdb1043084

United States Department of Agriculture, Natural Resources Conservation Service. National soil survey handbook, title 430-VI. http://www.nrcs.usda.gov/wps/portal/ nrcs/detail/soils/scientists/?cid=nrcs142p2\_054242

United States Department of Agriculture, Natural Resources Conservation Service. 2006. Land resource regions and major land resource areas of the United States, the Caribbean, and the Pacific Basin. U.S. Department of Agriculture Handbook 296. http://www.nrcs.usda.gov/wps/portal/nrcs/detail/national/soils/? cid=nrcs142p2\_053624

United States Department of Agriculture, Soil Conservation Service. 1961. Land capability classification. U.S. Department of Agriculture Handbook 210. http://www.nrcs.usda.gov/Internet/FSE\_DOCUMENTS/nrcs142p2\_052290.pdf

## APPENDIX I - TEST PIT LOGS & INFILTRATION CALCULATIONS

(This Page Is Intentionally Blank)

# **Test Pit Report**

For

# **Smith Field Construction**

## 437 Lafayette Road,

Portsmouth, NH

**Prepared For** 

## 437 Lafayette Road Subdivision

45407.120

PREPARED BY

TFMoran, Inc.

**48 Constitution Drive** 

Bedford, NH 03110

January 25<sup>th</sup> & February 1<sup>st</sup>, 2022

## Test Pit 1 January 25th, 2022

0-13" 10YR 5/3 Brown, Loam, Massive, Friable, Anthropogenic Fill (Asphalt, Brick)

13-20" AB 10YR 7/6 Yellow, Loam, Blocky, Friable, Gravely <5% Rock (Iron Stone)

20-55" B1 Gley 1 7N Gray, Sandy Loam, massive, pliable

55- 65" B2 10YR 5/1 Gray, Coarse Sand, Friable, Massive, > 15% Angular Rock Fragment (Iron Stone)

REDOX @ 20" 10YR 7/8 Common Distinct >15%

## Soil Series: Walpole

EST Wet: 20" Below Grade

OBS WT: 39" Below Grade (Apparent  $\rightarrow$ )

Ledge: > 65" Below Grade

## Test Pit 2 January 25<sup>th</sup>, 2022

- 0-15" A 10YR 4/3 Brown, Loam, Massive
- 15-17" 10YR 7/6 Yellow, Sandy Loam, friable, granular
- 17-27" Gley 1 7/N light gray, Sandy Loam, friable, granular
- 27-52" 10YR 6/6 Brownish Yellow, Loam, friable, massive
- 52-77" 10YR 5/1 Gray, Course Sand, Friable, Gravely, granular

REDOX @ 26" 10YR 7/8 Common Distinct

## Soil Series: Walpole

- EST Wet: 26" Below Grade
- OBS WT: 51" Below Grade (Apparent ↑)
- Ledge: 77" Below Grade

## Test Pit 3 January 25<sup>th</sup>, 2022

- 0-16" 10YR 4/3 Brown, Loam, aggregated, friable
- 16-27" 10YR 6/6 Brownish Yellow, Loam, aggregated, friable, Gravely >5%
- 27-52" 10YR 7/2 Light Gray, Loamy Sand, aggregated, Friable Gravely >15%
- 52-84" 10YR 8/1 White, Sandy Clay Loam, Platey, indurate

REDOX @: 41" 10YR 7/8 Common Distinct >15%

## Soil Series: Canton - Chatfield Complex

- EST Wet: 41" Below Grade
- OBS WT: 84" Below Grade (Apparent ↘)
- Ledge: 84" Below Grade

## Test Pit 4 January 25<sup>th</sup>, 2022

0-18" 10YR 5/4 Yellowish Brown, Loam, Friable, Aggregate

18-27" 10YR 6/6 Brownish Yellow, Sandy Loam, Gravely >5%, Friable, Aggregate

27-37" 10YR 6/2 Light Brownish Grey, Loamy Sand, > 15% Angular Rock Fragment (Iron Stone)

37-65" 10YR 7/8 Yellow, Decaying Bedrock, Angular Cobble, Iron Stone

REDOX @: 5R 3/8 Common Distinct >15%

## Soil Series: Chatfield

EST Wet: 37" Below Grade

OBS WT: 56" Below Grade (Apparent 个)

Ledge: 65" Below Grade

## Test Pit 5 January 25<sup>th</sup>, 2022

0-10" 10YR 4/3 Brown, Loamy Sand, aggregate, friable, gravely >5%

10-31"10YR 5/4 Yellowish Brown, Course Sand, Granular, Friable, gravely>15%

31-57" Gley 1 5/N Gray, Clay, Decayed Bedrock, Boulders >5%, Massive REDOX @: 31" 5R 3/8 Common Distinct >15%

## Soil Series: Chatfield – Maybid Complex

EST Wet: 31" Below Grade

OBS WT: > 57"

Ledge: 57" Below Grade

## Test Pit 6 January 25<sup>th</sup>, 2022

0-12″	10YR 4/3 Brown, Sandy Loam, Aggregate, Friable
12-16"	10YR 7/2 Light Gray, Sand, granular, friable, gravely >5%
16-28"	10YR 7/1 Light Gray, Fine Sand, Granular, Friable
28-42" heterogene	10YR 7/3 Very Pale Brown, Sandy Loam, Aggregate, friable, ous
42-47"	Gley 1 5/5G-1 Greenish Gray, Sandy Clay Loam, Platey, Indurate
47-96" homogeneo	Gley 2 8/5BG Light Greenish Gray, Clay, Massive, Indurate, ous

REDOX @42" 5R 3/8 Common Distinct >15%

## Soil Series: Canton Complex (Anthropogenic)

EST Wet: 42" Below Grade

OBS WT: 79" Below Grade (Apparent  $\rightarrow$ )

Ledge: > 96"

## Test Pit 7 January 25th, 2022

- 0-18" 10YR 4/2 Dark Grayish Brown, Sandy Loam, Friable, blocky
- 18-42" 10YR 7/4 Very pale Brown, Fine Sand, granular, friable
- 42-54" 10YR 6/6 Brownish Yellow, Course Sand, granular, friable
- 54-65" 10YR 5/8 Yellowish Brown, Sandy Loam, heterogeneous, friable
- 65-72" Gley 2 4/10B Dark Blueish Gray, Sandy Clay Loam, Platey, Indurate
- 72-102" Gley 2 7/10B Light Blueish Gray, Clay, Massive, Indurate

REDOX @ 57" 5R 3/8 Common Distinct >15%

## Soil Series: Canton Complex (Anthropogenic)

EST Wet: 57" Below Grade

OBS WT: 93" Below Grade (Apparent 个)

Ledge: >102"

## Test Pit 8 January 25<sup>th</sup>, 2022

0-14" 10YR 4/2 Dark Grayish Brown, Loamy Sand, friable, blocky

14-42" 10YR 7/4 Very pale Brown, Fine Sand, aggregate, friable, > 15% Cobble River Stone

42-50" Gley 1 5/5G\_/1 Greenish Gray, Sandy Clay Loam, Aquatard present (Iron Stone), Massive, Indurate

50-55" 10YR 6/4 Light Yellowish Brown, Sandy Clay Loam, Inclusion, heterogeneous, Massive, Indurate

55-103" Gley 2 8/5BG Light Greenish Gray, Clay, Indurate, massive

REDOX @ 42 5R 3/8 Common Distinct >15% (Aquatard (Potentially Anthropogenic))

## Soil Series: Canton Complex (Anthropogenic)

EST Wet: 42" Below Grade

## Test Pit 8 January 25th, 2022 (Cont'd)

OBS WT: 101" Below Grade (Apparent ↑)

Ledge: > 103"

## Test Pit 9 January 25th, 2022

0-9" 10YR 4/3 Brown, Loam, blocky, friable, gravely >5%

9-23" 10YR 5/6 Yellowish Brown, Loamy Sand, granular, , > 15% Angular Rock Fragment (Iron Stone)

23-54" 10YR 7/2 light Grey, Sandy Loam, Indurate, massive, heterogeneous,> 15% Angular Rock Fragment (Iron Stone)

REDOX @ 5R 4/6 Common Distinct >15%

## Soil Series: Walpole

EST Wet: 30" Below Grade

OBS WT: > 54"

Ledge: 54" Below Grade

## Test Pit 10 February 1<sup>st</sup>, 2022

0-12" 10YR 4/4 Dark Yellowish Brown, Loamy Sand, Blocky, Friable, Cobble >15%, Homogeneous Soil

12-23" 10YR 6/3 Pale Brown, Sandy Loam, aggregate, friable, Cobble >15%, Homogeneous soil

23-36"10YR 6/2 Light Brownish Grey, Course Sand, granular,Heterogeneous, Cobble >15%, Very Course particles <5%</td>

36-66" 10YR 5/4 Yellowish Brown, Loamy Sand, massive, Indurate > 25% Angular Rock Fragment (Iron Stone)

## Test Pit 10 February 1<sup>st</sup>, 2022 (Cont'd)

66-76" 10YR 5/4 Yellowish Brown, Sandy Loam, massive, Indurate, decaying ledge, > 55% Angular Rock Fragment (Iron Stone)

REDOX @ 52 – 58 10YR 5/6 Common Distinct >15%

## Soil Series: Canton – Walpole Complex

EST Wet: 52" Below Grade

OBS WT: >76"

Ledge: 76" Below Grade


F:/MSC Projects/4540/ - Lafayette Koad - Ponsinuurit4-940/ - 120 -

April 19, 2022

### TEST PIT LOG

SITE: 437 LAFAYETTE ROAD, PORTSMOUTH, NH LGGED BY: FAUL O'HANLON, TFM, INC. DATE: 1/25/2022 Test Pit #1: 0-13" 10YR 5/3 BROWN, LOAM, MASSIVE, FRIABLE, ANTTHROPOGENIC FILL (ASPHALT, BRICK) 13-20" AB 10YR 7/6 YELLOW, LOAM, BLOCKY, FRIABLE, GRAVELY <5% ROCK (IRON STONE) 20-55" B1 GLEY 1 7N GRAY, SANDY LOAM, MASSIVE, PLIABLE 55- 65" B2 10YR 5/1 GRAY, COARSE SAND, FRIABLE, MASSIVE, > 15% ANGULAR ROCK FRAGMENT (IRON STONE) REDOX © 20" 10YR 7/8 COMMON DISTINCT >15% SOIL SERIES: WALPOLE EST WET: 20" BELOW GRADE OBS WIT: 39" BELOW GRADE

Test Pit #2: 0-15"A 10YR 4/3 BROWN, LOAM, MASSIVE 15-17" 10YR 7/6 YELLOW, SANDY LOAM, FRIABLE, GRANULAR 17-27" GLEY 1 7/N LIGHT GRAY, SANDY LOAM, FRIABLE, GRANULAR 27-52" 10YR 6/6 BROWNISH YELLOW, LOAM, FRIABLE, MASSIVE 52-77" 10YR 5/1 GRAY, COURSE SAND, FRIABLE, GRAVELY, GRANULAR REDOX @ 26" 10YR 7/8 COMMON DISTINCT SOIL SERIES: WALPOLE EST WET: 26" BELOW GRADE OBS WT: 51" BELOW GRADE (APPARENT ↑) LEDGE: 77" BELOW GRADE <u>Test Pit #3:</u> 0-16" 10YR 4/3 BROWN, LOAM, AGGREGATED, FRIABLE 16-27" 10YR 6/6 BROWNISH YELLOW, LOAM, AGGREGATED, FRIABLE, GRAVELY >5% 27-52" 10YR 7/2 LIGHT GRAY, LOAMY SAND, AGGREGATED, FRIABLE GRAVELY >15% 52-84" 10YR 8/1 WHITE, SANDY CLAY LOAM, PLATEY, INDURATE REDOX @: 41" 10YR 7/8 COMMON DISTINCT >15% SOIL SERIES: CANTON - CHATFIELD COMPLEX EST WET: 41" BELOW GRADE OBS WT: 84" BELOW GRADE (APPARENT ↘) LEDGE: 84" BELOW GRADE Test Pit #4: 0-18" 10YR 5/4 YELLOWISH BROWN, LOAM, FRIABLE, AGGREGATE 18-27" 10YR 6/6 BROWNISH YELLOW, SANDY LOAM, GRAVELY >5%, FRIABLE, AGGREGATE 27-37" 10YR 6/2 LIGHT BROWNISH GREY, LOAMY SAND, > 15% ANGULAR ROCK FRAGMENT (IRON STONE) 37-65" 10YR 7/8 YELLOW, DECAYING BEDROCK, ANGULAR COBBLE, IRON STONE REDOX @: 5R 3/8 COMMON DISTINCT >15% SOIL SERIES: CHATFIELD EST WET: 37" BELOW GRADE OBS WT: 56" BELOW GRADE (APPARENT ↑) LEDGE: 65" BELOW GRADE

#### <u>Test Pit #5:</u>

- 0-10" 10YR 4/3 BROWN, LOAMY SAND, AGGREGATE, FRIABLE, GRAVELY >5%
- 10-31" 10YR 5/4 YELLOWSH BROWN, COURSE SAND, GRANULAR, FRIABLE, GRAVELY >15%
- 31-57" GLEY 1 5/N GRAY, CLAY, DECAYED BEDROCK, BOULDERS >5%, MASSIVE
- REDOX @: 31" 5R 3/8 COMMON DISTINCT >15% SOIL SERIES: CHATFIELD - MAYBID COMPLEX
- EST WET: 31" BELOW GRADE

OBS WT: > 57"

LEDGE: 57" BELOW GRADE

	TEST PIT LOG
SITE: 437 LOGGED B DATE: 1/2	LAFAYETTE ROAD, PORTSMOUTH, NH Y: PAUL O'HANLON, TFM, INC. 15/2022
Test Pi	t #6: 1978 4 /7 BROWNI SANDY LOAM ACCRECATE FRIARIE
12-16"	10YR 7/2 LIGHT GRAY, SAND, GRANULAR, FRIABLE, GRAVELY >5%
16-28″	10YR 7/1 LIGHT GRAY, FINE SAND, GRANULAR, FRIABLE
28-42"	10YR 7/3 VERY PALE BROWN, SANDY LOAM, AGGREGATE, FRIABLE, HETEROGENEOUS
42-47"	GLEY 1 5/5G-1 GREENISH GRAY, SANDY CLAY LOAM, PLATEY, INDURATE
47-96″	GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, MASSIVE, INDURATE, HOMOGENEOUS
REDOX @	42" 5R 3/8 COMMON DISTINCT >15%
FOT WET	SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC)
OBS WT:	42 BELOW GRADE (APPARENT →)
LEDGE: >	96″
Test Pi	<u>t #7:</u>
0-18"	10YR 4/2 DARK GRAYISH BROWN, SANDY LOAM, FRIABLE, BLOCKY
18-42"	10YR 7/4 VERY PALE BROWN, FINE SAND, GRANULAR, FRIABLE
42-54"	10YR 6/6 BROWNISH YELLOW, COURSE SAND, GRANULAR, FRIABLE
54-65"	10YR 5/8 YELLOWISH BROWN, SANDY LOAM, HETEROGENEOUS, FRIABLE
65-72″	GLEY 2 4/10B DARK BLUEISH GRAY, SANDY CLAY LOAM, PLATEY, INDURATE
72–102″	GLEY 2 7/10B LIGHT BLUEISH GRAY, CLAY, MASSIVE, INDURATE REDOX @ 57" 5R 3/8 COMMON DISTINCT >15%
ECT WET.	SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC)
OBS WT	93″ BELOW GRADE (APPARENT ↑)
LEDGE: >	102"
<u>Test Pi</u>	<u>t #8:</u>
0-14"	10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY
14-42"	10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE
42-50"	GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE
50-55″	10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION, HETEROGENEOUS, MASSIVE, INDURATE
55-103″	GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE, MASSIVE
REDOX @	42 5R 3/8 COMMON DISTINCT >15% (AQUATARD (POTENTIALLY ANTHROPOGENIC))
	SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC)
EST WET:	42" BELOW GRADE
OBS WT: LEDGE: >	101″ BELOW GRADE (APPARENT ↑) 103″

#### Test Pit #9: 0-9"10YR 4/3 BROWN, LOAM, BLOCKY, FRIABLE, GRAVELY >5%

- $9-23^{\prime\prime}$  10yr 5/6 Yellowsh brown, loamy sand, granular, , > 15% angular rock fragment (iron stone)
- 23-54" 10YR 7/2 LIGHT GREY, SANDY LOAM, INDURATE, MASSIVE, HETEROGENEOUS, > 15% ANGULAR ROCK FRAGMENT (IRON STONE)
- REDOX © 5R 4/6 COMMON DISTINCT >15% SOIL SERIES: WALPOLE
- SOIL SERIES: WALPC EST WET: 30" BELOW GRADE
- OBS WT: > 54" LEDGE: 54" BELOW GRADE

### SITE: 437 LAFAYETTE ROAD, PORTSMOUTH, NH LOGGED BY: PAUL O'HANLON, TFM, INC. DATE: 2/1/2022 Test Pit #10: 0-12" 10'\R 4/4 DARK YELLOWISH BROWN, LOAMY SAND, BLOCKY, FRIABLE, COBBLE 515%, HOMOGENEOUS SOIL 12-23" 10'\R 6/3 PALE BROWN, SANDY LOAM, AGGREGATE, FRIABLE, COBBLE 515%, HOMOGENEOUS SOIL 23-36" 10'\R 6/2 LIGHT BROWNISH GREY, COURSE SAND, GRANULAR, HETEROGENEOUS, COBBLE 515%, VERY COURSE SAND, GRANULAR, HETEROGENEOUS, COBBLE 515%, VERY COURSE SAND, MASSIVE, INDURATE > 25% ANGULAR ROCK FRAGMENT (IGNN STONE) 66-76" 10'\R 5/4 YELLOWISH BROWN, LOAMY SAND, MASSIVE, INDURATE, DECAYING LEDGE, > 55% ANGULAR ROCK FRAGMENT (IGNN STONE) REDX © 52 − 58 10'\R 5/6 COMMON DISTINCT >15% SOUL SERIES: CANTON – WALPOLE COMPLEX EST WET: 52" BELOW GRADE OBS WT: >76" LEDGE: 76" BELOW GRADE

TEST PIT LOG

Mar 01

#### Copyright 2022 © TFMoran, Inc. 48 Constitution Drive, Bedford, N.H. 03110

All rights reserved. These plans and materials may not be copied, duplicated, replicated or otherwise reproduced in any form whatsoever without the prior written permission of TFMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of TFMoran, Inc.

REV. DATE DESCRIPTION



April 19, 2022

Pr	oject No:	45407.:	12						Date:	1/25/20	22							
Proje	ect Name:	437 Laf	atette Road -	Portsmout	n, NH				Location:	TP-3 - Back	Yard of Lo	t 3 - Hol	e #1					
					For 5 cm	Auger			Depth to	A of Au Radius Dept Impervious Approxim	ger Hole = s of Hole = th of Auger Layer or Es ate Glover	19.6 2.5 Hole = 5HWT =	cm <sup>2</sup> cm 45.0 104.1	cm cm	41 îlover Solut	in ion	(From Grou	und Surface
Reading #	Time Interval	н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	S	A1	B1	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )	Saturated Conduction	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	26.5	-	-		-	-	-	-	-	-	-	-			
2	0.5	20	0.000753	25.5	1.0	0.008	1	20	2400	1.8072	0.711	59.1	0.000753	0.0006	1.808	0.712	1.337	0.526
3	1	20	0.000753	24.9	0.6	0.008	1	20	1440	1.08432	0.427	59.1	0.000753	0.0006	1.085	0.427	0.802	0.316
4	1.5	20	0.000753	24.2	0.7	0.008	1	20	1680	1.26504	0.498	59.1	0.000753	0.0006	1.266	0.498	0.936	0.368
5	2	20	0.000753	23.5	0.7	0.008	1	20	1680	1.26504	0.498	59.1	0.000753	0.0006	1.266	0.498	0.936	0.368
6	2.5	20	0.000753	22.8	0.7	0.008	1	20	1680	1.26504	0.498	59.1	0.000753	0.0006	1.266	0.498	0.936	0.368
7	3	20	0.000753	22.2	0.6	0.008	1	20	1440	1.08432	0.427	59.1	0.000753	0.0006	1.085	0.427	0.802	0.316
8	3.5	20	0.000753	21.7	0.5	0.008	1	20	1200	0.9036	0.356	59.1	0.000753	0.0006	0.904	0.356	0.668	0.263
			Averag	e Ksat base	d on readin	gs 2-7		-			0.470					0.470		0.347

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

A Coefficient A from CCHP Manual - Approximate for Glover Solution

- d Distinance from top of water to outflow of CCHP (D-H)
- A1 Calculated Coefficient A for Glover Solution (H>2s)
- B1 Calculated Coefficient A for Glover Solution (H<2s)
- s Distance from bottom of auger hole to impereable layer

Pr	oject No:	45407.	12						Date:	1/25/20	22							
Proje	ect Name:	437 Laf	atette Road -	Portsmout	h, NH				Location:	<u>TP-3 - Bac</u>	k Yard of Lo	t 3 - Hol	e #2					
					For 5 cm	Auger			Depth to	A of Au Radius Depi Impervious Approxim Solu	ger Hole = s of Hole = th of Auger Layer or Es ate Glover	19.6 2.5 Hole = SHWT =	cm <sup>2</sup> cm 52.0 104.1	cm cm	41 Glover Solut if s>	in ion 2H	(From Grou	und Surface
Reading #	Time Interval	н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic ivity (K <sub>sat</sub> )	S	A1	B1	Saturated Conduction	Hydraulic vity (K <sub>sat</sub> )	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	27	-	-		-	-	-	-	-	-	-	-			
2	0.5	16	0.001057	25.4	1.6	0.008	1	20	3840	4.05888	1.5980	52.1	0.001057	0.0007	4.058	1.5974	2.794	1.100
3	1	16	0.001057	24.5	0.9	0.008	1	20	2160	2.28312	0.8989	52.1	0.001057	0.0007	2.282	0.899	1.571	0.619
4	1.5	16	0.001057	23.4	1.1	0.008	1	20	2640	2.79048	1.0986	52.1	0.001057	0.0007	2.790	1.0982	1.921	0.756
5	2	16	0.001057	22.5	0.9	0.008	1	20	2160	2.28312	0.8989	52.1	0.001057	0.0007	2.282	0.899	1.571	0.619
6	2.5	16	0.001057	21.6	0.9	0.008	1	20	2160	2.28312	0.8989	52.1	0.001057	0.0007	2.282	0.899	1.571	0.619
7	3	16	0.001057	20.7	0.9	0.008	1	20	2160	2.28312	0.8989	52.1	0.001057	0.0007	2.282	0.899	1.571	0.619
8	3.5	16	0.001057	19.9	0.8	0.008	1	20	1920	2.02944	0.7990	52.1	0.001057	0.0007	2.029	0.799	1.397	0.550
			Average	Ksat based	l on reading	s 2,4-8					0.8789					0.879		0.605

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

A Coefficient A from CCHP Manual - Approximate for Glover Solution

- d Distinance from top of water to outflow of CCHP (D-H)
- A1 Calculated Coefficient A for Glover Solution (H>2s)
- B1 Calculated Coefficient A for Glover Solution (H<2s)
- s Distance from bottom of auger hole to impereable layer

Pr	oject No:	45407.	12						Date:	1/25/20	22							
Proje	ct Name:	437 Laf	fatette Road -	Portsmouth	n, NH				Location:	TP-3 - Back	Yard of Lo	t 3 - Hol	e #3					
					For 5 cm	Auger				A of Au Radius Dept Impervious Approxima Solu	ger Hole = 5 of Hole = 1:h of Auger Layer or ES 1:ate Glover tion	19.6 2.5 Hole = 5HWT =	cm <sup>2</sup> cm 46.0 104.1	cm cm	41 Glover Solut if s>	in ion 2H	(From Grou if s<	und Surface 2H
Reading #	Time Interval	н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	S	A1	B1	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	42.0	-	-		-	-	-	-	-	-	-	-			
2	0.5	19	0.000815	40.8	1.2	0.008	1	20	2880	2.3472	0.924	58.1	0.000815	0.0006	2.347	0.924	1.694	0.667
3	1	19	0.000815	39.9	0.9	0.008	1	20	2160	1.7604	0.693	58.1	0.000815	0.0006	1.760	0.693	1.271	0.500
4	1.5	19	0.000815	39.0	0.9	0.008	1	20	2160	1.7604	0.693	58.1	0.000815	0.0006	1.760	0.693	1.271	0.500
5	2	19	0.000815	38.0	1.0	0.008	1	20	2400	1.956	0.770	58.1	0.000815	0.0006	1.956	0.770	1.412	0.556
6	2.5	19	0.000815	37.2	0.8	0.008	1	20	1920	1.5648	0.616	58.1	0.000815	0.0006	1.565	0.616	1.129	0.445
7	3	19	0.000815	36.4	0.8	0.008	1	20	1920	1.5648	0.616	58.1	0.000815	0.0006	1.565	0.616	1.129	0.445
8	3.5	19	0.000815	35.6	0.8	0.008	1	20	1920	1.5648	0.616	58.1	0.000815	0.0006	1.565	0.616	1.129	0.445
											0.724					0.724		0.522

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

A Coefficient A from CCHP Manual - Approximate for Glover Solution

d Distinance from top of water to outflow of CCHP (D-H)

A1 Calculated Coefficient A for Glover Solution (H>2s)

B1 Calculated Coefficient A for Glover Solution (H<2s)

s Distance from bottom of auger hole to impereable layer

Hole #1	0.5
Hole #2	0.9
Hole #3	0.7
Average	0.7
Average	0.7

Pr	oject No:	45407.	12						Date:	4/25/20	24							
Proje	ect Name:	437 Laf	fatette Road -	Portsmout	n, NH				Location:	TP-4 Bet	ween Lots	2 and 3						
					For 5 cm	Auger			Depth to	A of Aug Radius Dept Impervious Approxima Solu	ger Hole = 6 of Hole = 1 of Auger Layer or ES ate Glover tion	19.6 2.5 Hole = 5HWT =	cm <sup>2</sup> cm <u>46.0</u> 94.0	cm cm C	37 Glover Solut if s>	in ion 2H	(From Grou if s<	und Surface 2H
Reading #	Time Interval	н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	S	A1	B1	Saturated Conductiv	Hydraulic ⁄ity (K <sub>sat</sub> )	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	33.0	-	-		-	-	-	-	-	-	-	-			
2	1	14	0.001288	32.4	0.6	0.017	1	20	720	0.92736	0.3651	48.0	0.001288	0.0009	0.928	0.365	0.613	0.241
3	2	14	0.001288	31.8	0.6	0.017	1	20	720	0.92736	0.3651	48.0	0.001288	0.0009	0.928	0.365	0.613	0.241
4	3	14	0.001288	31.3	0.5	0.017	1	20	600	0.7728	0.3043	48.0	0.001288	0.0009	0.773	0.304	0.511	0.201
5	4	14	0.001288	30.8	0.5	0.017	1	20	600	0.7728	0.3043	48.0	0.001288	0.0009	0.773	0.304	0.511	0.201
6	5	14	0.001288	30.4	0.4	0.017	1	20	480	0.61824	0.2434	48.0	0.001288	0.0009	0.618	0.243	0.409	0.161
7	6	14	0.001288	22.2	8.2	0.017	1	20	9840	12.67392	4.9897	48.0	0.001288	0.0009	12.677	4.991	8.381	3.300
			Averag	e Ksat base	d on readin	gs 1-6					0.3164					0.316		0.724

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

A Coefficient A from CCHP Manual - Approximate for Glover Solution

- d Distinance from top of water to outflow of CCHP (D-H)
- A1 Calculated Coefficient A for Glover Solution (H>2s)
- B1 Calculated Coefficient A for Glover Solution (H<2s)
- s Distance from bottom of auger hole to impereable layer

Pr	oject No:	45407.	12						Date:	1/25/20	22							
Proje	ect Name:	437 Laf	atette Road -	Portsmout	h, NH				Location:	TP-4 Bet	ween Lots	2 and 3						
					For 5 cm	Auger			Depth to	A of Au Radius Dept Impervious Approxim	ger Hole = 5 of Hole = th of Auger Layer or E ate Glover	19.6 2.5 Hole = SHWT =	cm <sup>2</sup> cm <u>38.0</u> 94.0	cm cm	<mark>37</mark> Glover Solut	in ion	(From Gro	und Surface
										Solu	ition				if s>	2H	if s<	:2H
Reading #	Time Interval	н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	s*	A1	B1	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	27.2	-	-		-	-	-	-	-	-	-	-			
2	2	15	0.001163	26.5	0.7	0.033	1	20	420	0.48846	0.1923	56.0	0.001163	0.0007	0.489	0.192	0.305	0.120
3	4	15	0.001163	26	0.5	0.033	1	20	300	0.3489	0.1374	56.0	0.001163	0.0007	0.349	0.137	0.218	0.086
4	6	15	0.001163	25.9	0.1	0.033	1	20	60	0.06978	0.0275	56.0	0.001163	0.0007	0.070	0.027	0.044	0.017
5	8	15	0.001163	25.4	0.5	0.033	1	20	300	0.3489	0.1374	56.0	0.001163	0.0007	0.349	0.137	0.218	0.086
			Averag	e Ksat base	d on readin	gs 1-3					0.1648					0.165		0.103

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

- A Coefficient A from CCHP Manual Approximate for Glover Solution
- d Distinance from top of water to outflow of CCHP (D-H)
- A1 Calculated Coefficient A for Glover Solution (H>2s)
- B1 Calculated Coefficient A for Glover Solution (H<2s)
- s Distance from bottom of auger hole to impereable layer (ESHW Depth of Auger Hole in cm)

Pr	roject No:	45407.	12						Date:	4/25/20	24							
Proje	ect Name:	437 Laf	fatette Road -	Portsmouth	n <i>,</i> NH				Location:	TP-4 Bet	ween Lots	2 and 3						
					For 5 cm	Auger				A of Au Radius Dept Impervious Approxima Solu	ger Hole = s of Hole = th of Auger Layer or Es ate Glover ition	19.6 2.5 Hole = 5HWT =	cm <sup>2</sup> cm 43.0 94.0	cm cm C	37 Glover Solut if s>	in ion 2H	(From Grou if s<	und Surface 2H
Reading #	Time Interval	Η	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic ivity (K <sub>sat</sub> )	S	A1	B1	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	37.0	-	-		-	-	-	-	-	-	-	-			
2	1	15	0.001163	36.0	1.0	0.017	1	20	1200	1.3956	0.549	51.0	0.001163	0.0008	1.396	0.550	0.931	0.367
3	2	15	0.001163	35.5	0.5	0.017	1	20	600	0.6978	0.275	51.0	0.001163	0.0008	0.698	0.275	0.466	0.183
4	3	15	0.001163	35.0	0.5	0.017	1	20	600	0.6978	0.275	51.0	0.001163	0.0008	0.698	0.275	0.466	0.183
5	4	15	0.001163	34.5	0.5	0.017	1	20	600	0.6978	0.275	51.0	0.001163	0.0008	0.698	0.275	0.466	0.183
6	5	15	0.001163	34.0	0.5	0.017	1	20	600	0.6978	0.275	51.0	0.001163	0.0008	0.698	0.275	0.466	0.183
			Averag	e Ksat base	d on readin	gs 3-6					0.275					0.275		0.183

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

A Coefficient A from CCHP Manual - Approximate for Glover Solution

d Distinance from top of water to outflow of CCHP (D-H)

A1 Calculated Coefficient A for Glover Solution (H>2s)

B1 Calculated Coefficient A for Glover Solution (H<2s)

s Distance from bottom of auger hole to impereable layer

Hole #1	0.3
Hole #2	0.2
Hole #3	0.3
Average	0.3
	_

Pr	oject No:	45407.	12						Date:	1/25/202	22							
Proje	ect Name:	437 Laf	fatette Road -	Portsmout	n, NH				Location:	<u>TP 5 - SE Co</u>	orner of Lo	<u>t 3</u>						
					For 5 cm	Auger			Depth to	A of Aug Radius Dept Impervious Approxima Solu	ger Hole = of Hole = th of Auger Layer or Es ate Glover tion	19.6 2.5 Hole = SHWT =	cm <sup>2</sup> cm <u>32.0</u> 78.7	cm cm C	31 Glover Solut if s>	in ion 2H	(From Grou if s<	Ind Surface
Reading #	Time Interval	Н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	s*	A1	B1	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	46.8	-	-		-	-	-	-	-	-	-	-			
2	2	11	0.00182817	44.5	2.3	0.033	2	105	7245	13.24512	5.2146	46.7	0.001827	0.0010	13.238	5.212	7.368	2.901
3	3	11	0.00182817	43.8	0.7	0.017	2	105	4410	8.062249	3.1741	46.7	0.001827	0.0010	8.058	3.173	4.485	1.766
4	4	11	0.00182817	43.3	0.5	0.017	2	105	3150	5.75875	2.2672	46.7	0.001827	0.0010	5.756	2.266	3.203	1.261
5	5	11	0.00182817	42.8	0.5	0.017	2	105	3150	5.75875	2.2672	46.7	0.001827	0.0010	5.756	2.266	3.203	1.261
6	6	11	0.00182817	42.2	0.6	0.017	2	105	3780	6.910499	2.7207	46.7	0.001827	0.0010	6.907	2.719	3.844	1.513
			Averag	e Ksat base	d on readin	gs 3-6					2.6073					2.606		1.450

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

A Coefficient A from CCHP Manual - Approximate for Glover Solution

- d Distinance from top of water to outflow of CCHP (D-H)
- A1 Calculated Coefficient A for Glover Solution (H>2s)
- B1 Calculated Coefficient A for Glover Solution (H<2s)
- s Distance from bottom of auger hole to impereable layer (ESHW Depth of Auger Hole in cm)

Pr	oject No:	45407.	12						Date:	1/25/20	22							
Proje	ect Name:	437 Laf	fatette Road -	Portsmout	h, NH				Location:	<u>TP 5 - SE C</u>	orner of Lo	<u>t 3</u>						
					For 5 cm	Auger			Depth to	A of Au Radius Dept Impervious Approxima Solu	ger Hole = 5 of Hole = 1:h of Auger Layer or Es ate Glover tion	19.6 2.5 Hole = SHWT =	cm <sup>2</sup> cm 37.0 78.7	cm cm C	31 Glover Solut if s>	in ion 2H	(From Grou if s<	Ind Surface
Reading #	Time Interval	Н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	S	A1	B1	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm³/hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	32.7	-	-		-	-	-	-	-	-	-	-			
2	1	16	0.001057	31.8	0.9	0.017	2	105	5670	5.99319	2.360	41.7	0.001057	0.0008	5.991	2.359	4.778	1.881
3	2	16	0.001057	31.1	0.7	0.017	2	105	4410	4.66137	1.835	41.7	0.001057	0.0008	4.660	1.835	3.716	1.463
4	3	16	0.001057	30.2	0.9	0.017	2	105	5670	5.99319	2.360	41.7	0.001057	0.0008	5.991	2.359	4.778	1.881
5	4	16	0.001057	29.4	0.8	0.017	2	105	5040	5.32728	2.097	41.7	0.001057	0.0008	5.325	2.097	4.247	1.672
6	5	16	0.001057	28.7	0.7	0.017	2	105	4410	4.66137	1.835	41.7	0.001057	0.0008	4.660	1.835	3.716	1.463
7	6	16	0.001057	28	0.7	0.017	2	105	4410	4.66137	1.835	41.7	0.001057	0.0008	4.660	1.835	3.716	1.463
			Avera	age Ksat bas	ed on read	ings					2.054					2.053		1.637

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

A Coefficient A from CCHP Manual - Approximate for Glover Solution

- d Distinance from top of water to outflow of CCHP (D-H)
- A1 Calculated Coefficient A for Glover Solution (H>2s)
- B1 Calculated Coefficient A for Glover Solution (H<2s)

s Distance from bottom of auger hole to impereable layer



Pr	oject No:	45407.	12						Date:	1/25/202	22							
Proje	ect Name:	437 Laf	fatette Road -	Portsmout	n, NH				Location:	TP-7 Bac	k of Lot 1							
					For 5 cm	Auger			Depth to	A of Aug Radius Dept Impervious Approxima Solu	ger Hole = of Hole = h of Auger Layer or ES ate Glover tion	19.6 2.5 Hole = SHWT =	cm <sup>2</sup> cm 28.0 236.2	cm cm	93 Glover Solut if s>	in ion 2H	(From Grou if s<	Ind Surface
Reading #	Time Interval	Н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	S	A1	B1	Saturated Conductiv	Hydraulic ⁄ity (K <sub>sat</sub> )	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	26.0	-	-		-	-	-	-	-	-	-	-			
2	1	12	0.0016137	24.8	1.2	0.017	2	105	7560	12.19959	4.8030	208.2	0.001613	0.0003	12.193	4.801	2.086	0.821
3	2	12	0.0016137	24.1	0.7	0.017	2	105	4410	7.11643	2.8017	208.2	0.001613	0.0003	7.113	2.800	1.217	0.479
4	3	12	0.0016137	23.3	0.8	0.017	2	105	5040	8.133062	3.2020	208.2	0.001613	0.0003	8.129	3.200	1.391	0.547
5	4	12	0.0016137	22.5	0.8	0.017	2	105	5040	8.133062	3.2020	208.2	0.001613	0.0003	8.129	3.200	1.391	0.547
6	5	12	0.0016137	21.8	0.7	0.017	2	105	4410	7.11643	2.8017	208.2	0.001613	0.0003	7.113	2.800	1.217	0.479
7	6	12	0.0016137	20.9	0.9	0.017	2	105	5670	9.149695	3.6022	208.2	0.001613	0.0003	9.145	3.600	1.564	0.616
			Averag	e Ksat base	d on readin	gs 3-7					3.1219					3.120		0.534

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

A Coefficient A from CCHP Manual - Approximate for Glover Solution

- d Distinance from top of water to outflow of CCHP (D-H)
- A1 Calculated Coefficient A for Glover Solution (H>2s)
- B1 Calculated Coefficient A for Glover Solution (H<2s)
- s Distance from bottom of auger hole to impereable layer

Pr	oject No:	45407.	12						Date:	1/25/20	22							
Proje	ct Name:	437 Laf	fatette Road -	Portsmout	h <i>,</i> NH				Location:	TP-7 Bac	k of Lot 1							
					For 5 cm	Auger			Depth to	A of Aug Radius Dept Impervious	ger Hole = 5 of Hole = 1:h of Auger Layer or ES	19.6 2.5 Hole = SHWT =	cm <sup>2</sup> cm <u>36.0</u> 236.2	cm cm	93 Slover Solut	in	(From Grou	and Surface
										Solu	tion				if s>	2H	if s<	2Н
Reading #	Time Interval	Н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	s*	A1	B1	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	Saturated Conduction	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm³/hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	15.5	-	-		-	-	-	-	-	-	-	-			
2	1	8	0.00284801	14.5	1.0	0.017	2	105	6300	17.94247	7.0640	200.2	0.002847	0.0003	17.933	7.060	2.061	0.811
3	2	8	0.00284801	13.7	0.8	0.017	2	105	5040	14.35398	5.6512	200.2	0.002847	0.0003	14.347	5.648	1.649	0.649
4	3	8	0.00284801	12.8	0.9	0.017	2	105	5670	16.14822	6.3576	200.2	0.002847	0.0003	16.140	6.354	1.855	0.730
5	4	8	0.00284801	12.2	0.6	0.017	2	105	3780	10.76548	4.2384	200.2	0.002847	0.0003	10.760	4.236	1.236	0.487
6	5	8	0.00284801	11.5	0.7	0.017	2	105	4410	12.55973	4.9448	200.2	0.002847	0.0003	12.553	4.942	1.443	0.568
7	6	8	0.00284801	10.8	0.7	0.017	2	105	4410	12.55973	4.9448	200.2	0.002847	0.0003	12.553	4.942	1.443	0.568
	Average Ksat based on readings 3-7								5.2273					5.225		0.600		

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

- A Coefficient A from CCHP Manual Approximate for Glover Solution
- d Distinance from top of water to outflow of CCHP (D-H)
- A1 Calculated Coefficient A for Glover Solution (H>2s)
- B1 Calculated Coefficient A for Glover Solution (H<2s)

s Distance from bottom of auger hole to impereable layer (ESHW - Depth of Auger Hole in cm)

Pr	Project No: 45407.12								Date:	1/25/20	22							
Proje	ect Name:	437 Lai	fatette Road -	Portsmouth	n, NH				Location:	TP-7 Bac	k of Lot 1							
					For 5 cm	Auger				A of Aug Radius Dept mpervious Approxima Solu	ger Hole = of Hole = h of Auger Layer or E ate Glover tion	19.6 2.5 Hole = SHWT =	cm <sup>2</sup> cm <u>34</u> 236.2	cm cm C	93 Glover Solut if s>	in ion 2H	(From Grou	und Surface 2H
Reading #	Time Interval	Н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	S	A1	B1	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	38.5	-	-		-	-	-	-	-	-	-	-			
2	1	8.5	0.00262191	37.9	0.6	0.017	2	105	3780	9.910837	3.902	202.2	0.002621	0.0003	9.906	3.900	1.209	0.476
3	2	8.5	0.00262191	37.1	0.8	0.017	2	105	5040	13.21445	5.203	202.2	0.002621	0.0003	13.208	5.200	1.612	0.635
4	3	8.5	0.00262191	36.4	0.7	0.017	2	105	4410	11.56264	4.552	202.2	0.002621	0.0003	11.557	4.550	1.410	0.555
5	4	8.5	0.00262191	35.7	0.7	0.017	2	105	4410	11.56264	4.552	202.2	0.002621	0.0003	11.557	4.550	1.410	0.555
6	6	8.5	0.00262191	34.5	1.2	0.033	2	105	3780	9.910837	3.902	202.2	0.002621	0.0003	9.906	3.900	1.209	0.476
			Averag	e Ksat base	d on readin	gs 3-6					4.552					4.550		0.555

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

A Coefficient A from CCHP Manual - Approximate for Glover Solution

d Distinance from top of water to outflow of CCHP (D-H)

A1 Calculated Coefficient A for Glover Solution (H>2s)

B1 Calculated Coefficient A for Glover Solution (H<2s)

s Distance from bottom of auger hole to impereable layer

Hole #1	3.1
Hole #2	5.2
Hole #3	4.6
Average	4.3

Pr	Project No: 45407.12					Date: 1/25/2022												
Proje	ct Name:	437 Lai	fatette Road -	Portsmout	n, NH				Location:	TP-10 Ba	ack of Lot 3							
For 5 cm Auger									Depth to	A of Au Radius Dept Impervious Approxima Solu	ger Hole = of Hole = th of Auger Layer or Es ate Glover tion	19.6 2.5 Hole = SHWT =	cm <sup>2</sup> cm <u>34.0</u> 159.0	cm cm	63 Glover Solut if s>	in ion 2H	(From Grou	and Surface
Reading #	Time Interval	н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	s	A1	B1	Saturated Conductiv	Hydraulic ⁄ity (K <sub>sat</sub> )	Saturated Conductiv	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	34.5	-	-		-	-	-	-	-	-	-	-			
2	1	20	0.00075386	33.3	1.2	0.017	1	20	1440	1.085555	0.4274	125.0	0.000753	0.0003	1.085	0.427	0.461	0.182
3	2	20	0.00075386	31.5	1.8	0.017	1	20	2160	1.628332	0.6411	125.0	0.000753	0.0003	1.628	0.641	0.692	0.272
4	3	20	0.00075386	30.0	1.5	0.017	1	20	1800	1.356944	0.5342	125.0	0.000753	0.0003	1.356	0.534	0.576	0.227
5	4	20	0.00075386	28.5	1.5	0.017	1	20	1800	1.356944	0.5342	125.0	0.000753	0.0003	1.356	0.534	0.576	0.227
5	5	20	0.00075386	27.0	1.5	0.017	1	20	1800	1.356944	0.5342	125.0	0.000753	0.0003	1.356	0.534	0.576	0.227
	Average Ksat based on readings 3-7										0.5609					0.561		0.238

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

- A Coefficient A from CCHP Manual Approximate for Glover Solution
- d Distinance from top of water to outflow of CCHP (D-H)
- A1 Calculated Coefficient A for Glover Solution (H>2s)
- B1 Calculated Coefficient A for Glover Solution (H<2s)
- s Distance from bottom of auger hole to impereable layer

Pr	oject No:	45407.	12						Date:	1/25/20	22							
Proje	ct Name:	437 Laf	fatette Road -	Portsmout	h <i>,</i> NH				Location:	TP-10 Ba	ack of Lot 3							
					For 5 cm	Auger			Depth to	A of Au Radius Dept Impervious Approxima	ger Hole = s of Hole = th of Auger Layer or Es ate Glover	19.6 2.5 Hole = SHWT =	cm <sup>2</sup> cm <u>46.0</u> 159.0	cm cm	<mark>63</mark> Glover Solut	in :ion	(From Grou	und Surface
										Solu	ition				if s>	•2H	if s<	:2H
Reading #	Time Interval	Н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	s*	A1	B1	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm <sup>3</sup> /hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	42	-	-		-	-	-	-	-	-	-	-			
2	0.5	26	0.00050145	37.9	4.1	0.008	1	20	9840	4.934274	1.9426	113.0	0.000501	0.0003	4.932	1.942	2.783	1.096
3	1	26	0.00050145	34.4	3.5	0.008	1	20	8400	4.212185	1.6583	113.0	0.000501	0.0003	4.210	1.657	2.376	0.935
4	1.5	26	0.00050145	31.8	2.6	0.008	1	20	6240	3.129052	1.2319	113.0	0.000501	0.0003	3.127	1.231	1.765	0.695
5	2	26	0.00050145	29.8	2.0	0.008	1	20	4800	2.406963	0.9476	113.0	0.000501	0.0003	2.406	0.947	1.358	0.535
6	2.5	26	0.00050145	28.2	1.6	0.008	1	20	3840	1.92557	0.7581	113.0	0.000501	0.0003	1.925	0.758	1.086	0.428
7	3	26	0.00050145	26.6	1.6	0.008	1	20	3840	1.92557	0.7581	113.0	0.000501	0.0003	1.925	0.758	1.086	0.428
8	3.5	26	0.00050145	25.4	1.2	0.008	1	20	2880	1.444178	0.5686	113.0	0.000501	0.0003	1.443	0.568	0.815	0.321
9	4	26	0.00050145	24.2	1.2	0.008	1	20	2880	1.444178	0.5686	113.0	0.000501	0.0003	1.443	0.568	0.815	0.321
10	4.5	26	0.00050145	23	1.2	0.008	1	20	2880	1.444178	0.5686	113.0	0.000501	0.0003	1.443	0.568	0.815	0.321
			Averag	e Ksat base	d on readin	gs 3-7					0.6444					0.644		0.363

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

- A Coefficient A from CCHP Manual Approximate for Glover Solution
- d Distinance from top of water to outflow of CCHP (D-H)
- A1 Calculated Coefficient A for Glover Solution (H>2s)
- B1 Calculated Coefficient A for Glover Solution (H<2s)

s Distance from bottom of auger hole to impereable layer (ESHW - Depth of Auger Hole in cm)

Pr	Project No: 45407.12						Date:	1/25/20	22									
Proje	ect Name:	437 Laf	atette Road -	Portsmouth	n <i>,</i> NH				Location:	TP-10 Ba	ack of Lot 3							
					For 5 cm	Auger				A of Au Radius Dept mpervious Approxim Solu	ger Hole = s of Hole = th of Auger Layer or Es ate Glover ution	19.6 2.5 Hole = SHWT =	cm <sup>2</sup> cm 32 159.0	cm cm	63 Glover Solu if s>	in tion •2H	(From Grou	und Surface
Reading #	Time Interval	н	Coefficient A	Reading	Δ	Elapsed Time	# On Azm	Conv. Factor (Area)	Outflow	Saturated Conducti	Hydraulic ivity (K <sub>sat</sub> )	S	A1	B1	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )	Saturated Conducti	Hydraulic vity (K <sub>sat</sub> )
	min	cm	l/cm	cm	cm	hrs	cm	cm <sup>3</sup>	cm³/hr	cm/hr	in/hr	cm			cm/hr	in/hr	cm/hr	in/hr
1	0	-	-	35.0	-	-		-	-	-	-	-	-	-	-			
2	0.5	14	0.001288	33.4	1.6	0.008	1	20	3840	4.94592	1.947	127.0	0.001288	0.0004	4.947	1.948	1.524	0.600
3	1	14	0.001288	32.6	0.8	0.008	1	20	1920	2.47296	0.974	127.0	0.001288	0.0004	2.474	0.974	0.762	0.300
4	1.5	14	0.001288	31.8	0.8	0.008	1	20	1920	2.47296	0.974	127.0	0.001288	0.0004	2.474	0.974	0.762	0.300
5	2	14	0.001288	31.1	0.7	0.008	1	20	1680	2.16384	0.852	127.0	0.001288	0.0004	2.164	0.852	0.667	0.263
6	2.5	14	0.001288	30.4	0.7	0.008	1	20	1680	2.16384	0.852	127.0	0.001288	0.0004	2.164	0.852	0.667	0.263
7	3	14	0.001288	29.6	0.8	0.008	1	20	1920	2.47296	0.974	127.0	0.001288	0.0004	2.474	0.974	0.762	0.300
8	3.5	14	0.001288	28.9	0.7	0.008	1	20	1680	2.16384	0.852	127.0	0.001288	0.0004	2.164	0.852	0.667	0.263
			Averag	e Ksat base	d on readin	gs 3-6					0.913					0.913		0.281

H Steady Head (amount of water in auger hole from bottom of the hole to the surface of the water

A Coefficient A from CCHP Manual - Approximate for Glover Solution

d Distinance from top of water to outflow of CCHP (D-H)

A1 Calculated Coefficient A for Glover Solution (H>2s)

B1 Calculated Coefficient A for Glover Solution (H<2s)

s Distance from bottom of auger hole to impereable layer

Hole #1	0.6
Hole #2	0.6
Hole #3	0.9
Average	0.7

# **APPENDIX J – NHDES ONE STOP DATAMAPPER**



## APPENDIX K - PRE AND POST-DEVELOPMENT DRAINAGE PLANS





	SOIL LEGE PER SITE SPECIFIC S	ND SOIL SURVEY)
SYMBOL	DESCRIPTION	HYDROLOGIC SOIL GROUP
799*	UBRAN LAND-CANTON COMPLEX 3% - 15% SLOPES	A (BASED ON FIELD INFILTRATION RATES
799*	UBRAN LAND-CANTON COMPLEX 3% - 15% SLOPES	B (BASED ON FIELD INFILTRATION RATES

April 19, 2022



PLAST	
29.33	

	SOIL LEGEND (PER SITE SPECIFIC SOIL SURVEY)												
SYMBOL	DESCRIPTION	HYDROLOGIC SOIL GROUP											
799*	UBRAN LAND-CANTON COMPLEX 3% - 15% SLOPES	A (BASED ON FIELD INFILTRATION RATES)											
799*	UBRAN LAND-CANTON COMPLEX 3% - 15% SLOPES	B (BASED ON FIELD INFILTRATION RATES)											

April 19, 2022

# APPENDIX L – OPERATION AND MAINTENANCE MANUAL

Project #45407.120

# STORMWATER MANAGEMENT SYSTEM OPERATION & MAINENANCE MANUAL

## FOR

# Proposed 3 Lot Subdivision

437 Lafayette Road Portsmouth, New Hampshire Rockingham County

Tax Map 229, Lot 1

April 19, 2022

Prepared By:



Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists

## Table of Contents

Maintenance of Property	1
Plans	1
Owner Responsibility	1-2
General Inspection and Maintenance Requirements	2
Inspection and Maintenance Checklist Requirements	3-7
Inspection and Maintenance Records	7-8
Owner's Certification	10
Attachment 1 – Inspection and Maintenance Log	
Attachment 2 – Deicing Log	
Appendix A – Stormwater Operation & Maintenance Plan	

- Appendix B UNHSC Regular Inspection and Maintenance Guidelines for Bioretention Systems
- Appendix C UNHSC Checklist for Inspection of Bioretention System
- Appendix D Control of Invasive Plants

## Maintenance of Property

TFMoran, Inc., has prepared the following Stormwater Management System Operation & Maintenance Plan for Artwill, LLC at 437 Lafayette Road, Portsmouth, New Hampshire. The intent of this plan is to provide the owner (Artwill, LLC), and future property managers/owners of the site with a list of procedures that document the inspection and maintenance requirements of the Stormwater Management System for this development. This includes all temporary and permanent stormwater and erosion control measures during construction.

## <u> Plans</u>

Refer to the Site Development Plans prepared by TFMoran, Inc. for Tax Map 229 Lot 1, Proposed 3 Lot Subdivision, 437 Lafayette Road, Portsmouth, New Hampshire, dated April 19, 2022. See Appendix A in this manual for the "Stormwater Operation and Maintenance Plan" identifying locations of stormwater practices described hereon.

## <u>Owner Responsibility</u>

The current owners, and their successors of the property, are required to submit a copy of the Operations and Maintenance Report completed on a yearly basis to the City of Portsmouth Planning Department and Public Works Department by December 31<sup>st</sup>. The future successor includes but is not limited to the individual lot owners. This report should be prepared by a qualified inspector with working knowledge of the site. The owner shall be responsible for the following inspection and maintenance program which is necessary in order to keep the Stormwater Management System functioning properly. These measures will help reduce potential environmental impacts. By following the enclosed procedures, Artwill, LLC and its successors will be able to maintain the functional design of the Stormwater Management System and maximize its ability to remove sediment and other contaminants from site-generated stormwater runoff.

The owner and future owners are the responsible party for the following record keeping activities further identified in this Operation & Maintenance Manual:

- Conduct reporting, inspection, and maintenance activities in accordance with the "Inspection and Maintenance Checklist Requirements" and if applicable "Regular Inspection and Maintenance Guidance" provided by University of New Hampshire Stormwater Center (UNHSC);
- Document each inspection and maintenance activity with the "Inspection and Maintenance Log" and if applicable "Checklist for Inspection" provided by University of New Hampshire Stormwater Center (UNHSC);
- Photograph each practice that is subject to the "Inspection and Maintenance Checklist Requirements" at each inspection of that stormwater practice;
- Document actions taken if invasive species begin to grow in the stormwater management system; and
- Document each application of deicing material applied to the site with the "Deicing Log"
All record keeping required by the Operation & Maintenance Manual shall be maintained by the responsible party and be made available to the applicable regulatory agencies (i.e. NHDES AoT Bureau, City of Portsmouth, etc.) upon request. Logs and reports required by this Operation & Maintenance Manual should be prepared by a qualified inspector with working knowledge of the site. This manual and associated records shall be transferred to any future owners. All current and future owners must comply with RSA 485-A:17, Env-Wq 1500, the permit, and all conditions contained in the permit.

The following inspection and maintenance program is necessary in order to keep the Stormwater Management System functioning properly. These measures will greatly help to reduce potential environmental impacts. By following the enclosed procedures, Artwill, LLC and its successors will be able to maintain the functional design of the Stormwater Management System and maximize its ability to remove sediment and other contaminants from site-generated stormwater runoff.

### **General Inspection and Maintenance Requirements**

*Temporary* stormwater, sediment and erosion control measures that require maintenance on the site during construction include, but are not limited to, the following:

- Stabilized construction entrance;
- Silt sock barriers;
- o Inlet protection; and
- Construction dumpster area, if used.

*Permanent* stormwater, sediment and erosion control measures that require maintenance on the site include, but are not limited, to the following:

- Litter/trash removal;
- Dumpster area maintenance;
- Pavement sweeping;
- Surface maintenance related to deicing/plowing;
- Rip-rap protection;
- Bioretention systems;
- Outlet control structures;
- Emergency spillway;
- Catch basins;
- Drip line stone trench; and
- Culvert pipes.

### Inspection and Maintenance Checklist Requirements By implementing the following procedures, current owners will be able to maintain the

By implementing the following procedures, current owners will be able to maintain the functional design of the Stormwater Management System and maximize the systems ability to remove sediment and other contaminants from site-generated stormwater runoff. The owner shall conduct inspection and maintenance activities in accordance with the following checklist:

	Frequency	Inspect	Action
Temporary Controls			
Stabilized Construction Entrance	Weekly	<ul> <li>Inspect adjacent roadway for sediment tracking</li> </ul>	<ul> <li>Sweep adjacent roadways as soon as sediment is tracked</li> </ul>
		<ul> <li>Inspect stone for sediment accumulation</li> </ul>	<ul> <li>Top dress with additional stone when necessary to prevent tracking</li> </ul>
Litter/Trash Removal	Routinely	<ul> <li>Inspect site especially construction areas</li> </ul>	<ul> <li>Remove debris and clean areas as necessary</li> </ul>
Construction Dumpster Area Maintenance (if used)	Routinely	• Dumpster Areas	<ul> <li>Remove any accumulated debris and dispose of properly</li> </ul>
Silt Sock Barrier	Weekly	<ul> <li>Inspect accumulated sediment level, rips and tears</li> </ul>	<ul> <li>Repair or replace damaged lengths</li> <li>Remove and dispose accumulated sediment once level reaches 1/3 of barrier</li> </ul>
Gravel	Spring and Fall	<ul> <li>Inspect gravel for ruts and depth</li> </ul>	<ul> <li>Replace gravel as necessary, regrade as necessary to maintain design grades, remove any accumulated gravel washed from roadway</li> </ul>

	Frequency	Inspect	Action
Permanent Controls			
Rip Rap Outlet Protection	Spring and Fall and after rainstorms exceeding 2.5 inches in 24 hrs	<ul> <li>Inspect for damage or displaced stones</li> </ul>	<ul> <li>Repair and replace stone and / or fabric immediately</li> </ul>
		<ul> <li>Inspect for torn or visible fabric</li> </ul>	<ul> <li>Remove accumulated sediment, trash and blocking materials</li> </ul>

	Frequency Inspect Action			
Permanent Controls	- <b></b>	-		
Infiltration Basin	Spring and Fall and after rainstorms exceeding 2.5	<ul> <li>Inspect level of accumulated sediment</li> </ul>	<ul> <li>Remove accumulated sediment</li> </ul>	
	inches in 24 hrs	<ul> <li>Inspect for debris</li> </ul>	<ul> <li>Remove debris from inlet and outlets</li> </ul>	
		<ul> <li>Inspect outlet structures</li> </ul>	<ul> <li>Repair as necessary</li> </ul>	
		<ul> <li>Inspect vegetative cover</li> </ul>	<ul> <li>Mow embankments and removed woody vegetation</li> </ul>	
		<ul> <li>Inspect embankments and spillways</li> </ul>	<ul> <li>Repair embankments and spillways as necessary</li> </ul>	
		<ul> <li>Inspect infiltration function within 72- hrs following a rainfall event</li> </ul>	<ul> <li>Restore infiltration by removing accumulated sediments and reconstruction of the infiltration basin if deemed necessary</li> </ul>	
Landscape (not including Bioretention Systems)	Spring	<ul> <li>Mulch: Inspect mulch areas for trash and debris and thickness of mulch</li> </ul>	<ul> <li>Remove weeds and debris. Top dress with new mulch when necessary</li> </ul>	
	Spring	<ul> <li>Trees and Shrubs: Inspect for broken, weak or diseased branches and debris</li> </ul>	<ul> <li>Prune to maintain shape to avoid splitting, remove broken, weak or diseased branches, replace as necessary</li> </ul>	
	As necessary	<ul> <li>Lawn</li> </ul>	<ul> <li>Mow as required</li> </ul>	
	Spring and Fall	<ul> <li>Inspect landscaped areas for debris and litter</li> </ul>	<ul> <li>Remove debris and litter as necessary</li> </ul>	
Bioretention System	1st few months when rainfall exceeds 2.5" in a 24 hr period	<ul> <li>Inspect drawdown time: required to drawdown in 72 hrs or the standing water covers more than 15% of the surface after 48 hrs</li> </ul>	<ul> <li>Remove the top few inches of discolored material and rake or till the remaining material as needed</li> </ul>	

	Frequency Inspect Action							
Permanent Controls								
	4 times for 1 <sup>st</sup> yr, then Spring and Fall	<ul> <li>Inspect for animal burrows and short circuits in the system</li> </ul>	<ul> <li>Repair soil erosion from and fill holes and lightly compact</li> </ul>					
		<ul> <li>Inspect inlet and outlet for debris and leaves</li> </ul>	• Remove material with rakes where possible rather than heavy construction equipment to avoid compaction of the gravel wetland surface					
		<ul> <li>Inspect the filter bed</li> </ul>	• Remove sediment as necessary. If more than 2" of filter material is removed, replace with the design filter media specified					
		<ul> <li>Inspect vegetation for distress during extended periods without rain</li> </ul>	<ul> <li>Water as necessary</li> </ul>					
	Spring and Fall	<ul> <li>Inspect Drawdown time: required to drawdown in 72 hrs or the standing water covers more than 15% of the surface after 48 hrs</li> </ul>	<ul> <li>Remove the top few inches of discolored material and rake or till the remaining material as needed</li> </ul>					
	Annually	<ul> <li>Inspect inlet and outlet for erosion</li> </ul>	<ul> <li>Repair or replace as necessary</li> </ul>					
		<ul> <li>Inspect vegetative cover</li> </ul>	<ul> <li>Reinforcement plantings should be performed if 50% cover is not established in 2 yrs.</li> </ul>					
	Additionally, refer to UNHSC (attached f Guidance" and "Ch between the UNHS	to the most currently available documents from d for reference): "Regular Inspection Maintenance checklist for Inspection". If there are discrepancies ISC documents and this Manual's checklist						
Conventional	Spring and Fall Inspect payement Shall OVERIDE.							
Pavement		for debris						

	Frequency	Action	
Permanent Controls			
Drainage (Catch Basins / Drop Inlets)	Spring and Fall	<ul> <li>Inspect for sediment</li> </ul>	<ul> <li>If sump is more than half full of sediment, remove sediment as necessary</li> </ul>
		<ul> <li>Inspect for hydrocarbons</li> </ul>	Remove and dispose     of properly
		<ul> <li>Inspect Hoods</li> </ul>	<ul> <li>Repair and replace as necessary</li> </ul>
Drip Line Stone Trench	Spring and Fall	<ul> <li>Inspect for debris and vegetation</li> </ul>	<ul> <li>Clean and remove debris and vegetation as necessary</li> </ul>
Drain Manholes and Yard Drains	Spring and Fall	<ul> <li>Inspect for accumulated sediment and debris</li> </ul>	<ul> <li>Clean any material upon inspection and deposit of properly</li> </ul>
Inlet Protection (temporary during construction)	During construction and after measurable rainfall	<ul> <li>Inspect for accumulated sediment</li> </ul>	<ul> <li>Empty sediment bag if more than ½ filled with sediment or debris. Replace bag if torn or punctured to ½" diameter or greater on the lower half of the bag</li> </ul>
Culvert Pipe	Spring and Fall	<ul> <li>Inspect for obstructions</li> </ul>	<ul> <li>Remove and dispose of debris properly, Remove upstream debris to prevent future clogging</li> <li>Repair/replace if pipe becomes crushed or deteriorated</li> </ul>
Emergency Spillway	Spring and Fall	<ul> <li>Inspect for erosion, sediment accumulation, stone loss, and presence of invasive species</li> </ul>	<ul> <li>Remove debris and accumulated sediment (sediment accumulation should not exceed 3")</li> <li>Repair eroded areas</li> <li>Remove invasive species and vegetation</li> <li>Replace stone as necessary</li> </ul>

	Frequency	Inspect	Action
Permanent Controls			
Outlet Control Structure	Annually	<ul> <li>Inspection for debris or sediment buildup</li> </ul>	<ul> <li>Remove sediment and debris as necessary</li> <li>Remove debris covering orifice or v- notch</li> </ul>
		<ul> <li>Inspect structure</li> </ul>	• Repair as necessary

## <u>Landscaping</u>

Maintenance of landscaping to follow the NOFA Standards for Organic Land Care, 6th Edition, Practices for the Design and Maintenance of Ecological Landscapes. ("NOFA Standards for Organic Land Care." NOFA Standards for Organic Land Care 6th Edition Practices for the Design and Maintenance of Ecological Landscapes, Northeast Organic Farming Association of Connecticut, Inc, 2017, http://www.organiclandcare.net/sites/default/files/nofa\_organic\_land\_care\_standards\_6thedition\_2017\_opt.pdf.)

### Inspection and Maintenance Records and Annual Report

A detailed, written record of all logs, reports, photographs required by this Operation & Maintenance Manual must be kept by the owner and future property owners or assigns and/or condominium association of the property. The property owner shall submit records to the City of Portsmouth Department of Public Works and Planning Department yearly. Addresses listed below:

Planning Director	Director of Public Works		
Portsmouth Planning Department	Department of Public Works		
1 Junkins Avenue	680 Peverly Hill Road		
Portsmouth, NH 03801	Portsmouth, NH 03801		

The attached forms are provided to assist the property manager with the inspection and maintenance of the Stormwater Management System. The "Inspection and Maintenance Log" (Attachment 1) and "Deicing Log" (Attachment 2) on the following pages are blank copies to aid in record keeping required by this Operation & Maintenance Manual.

Supplement the "Inspection and Maintenance Log" with the most currently available "Checklist for Inspections" from UNHSC (attached to this Manual for reference). Each inspection or maintenance activity shall include photographs of each practice that is subject to the "Inspection and Maintenance Checklist Requirements" at each inspection of that stormwater practice. Log actions taken if invasive species begin to grow in the stormwater management system as required per the attached "Control of Invasive Plants". For all surface maintenance related activities related to deicing/plowing, complete the "Deicing Log" to track the amount and type of deicing materials applied to the site. Snow shall be stored in designated snow storage areas which have been designed to drain on-site and receive treatment via the stormwater management system prior to infiltration or discharge.

## **Owner's Certification**

Contact Information Owner: Contact Person

Artwill, LLC Joe Caldarola PO Box 370 Portsmouth, NH 03801 (603) 674-5204 joe@smithfieldconstruction.com

I have reviewed this document and understand the responsibilities contained. I agree to perform the required maintenance on the stormwater management system.

Owner's Signature (future owner's and successors, if applicable)

Print Name

Title

Date

Any inquiries in regard to the design, function, and/or maintenance of any one of the above mentioned facilities or tasks shall be directed to the project engineer:

TFMoran, Inc., Seacoast Division 170 Commerce Way, Suite 102 Portsmouth, NH 03801 (603) 431-2222

# **ATTACHMENT 1**

Inspection and Maintenance Log

# Inspection and Maintenance Log

BMP/System	Date	Inspector	Cleaning/Repair Needed	Date of	Performed
Component	Inspected	•	(list items/comments)	Cleaning/Repair	Ву

# **ATTACHMENT 2**

Deicing Log

# **Deicing Log**

Deicing Material Used	Amount of Deicing Material Applied	Date of Application	Logged By

# APPENDIX A

Stormwater Operation & Maintenance Plan



SITE DEVELOPMENT PLANS

TAX MAP 229 LOT 1 **STORMWATER OPERATION & MAINTENANCE PLAN PROPOSED 3 LOT SUBDIVISION** 437 LAFAYETTE ROAD PORTSMOUTH, NEW HAMPSHIRE

OWNED BY & PREPARE FOR ARTWILL, LLC



APRIL 19, 2022

	T			Л	Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists	48 ( Bedf Phor Fax www	Constitution Drive ord, NH 03110 re (603) 472–4488 (603) 472–9747 .tfmoran.com	
F	45407 100	DR	JSM	FB			0.14	
E 40407-120		ск	CK JCC CADFILE		45407-120_0&M PLAN			

April 19, 2022

# **APPENDIX B**

UNHSC Regular Inspection and Maintenance Guidelines for Bioretention Systems

### Regular Inspection and Maintenance Guidance for Bioretention Systems / Tree Filters

Maintenance of bioretention systems and tree filters can typically be performed as part of standard landscaping. Regular inspection and maintenance is critical to the effective operation of bioretention systems and tree filters to insure they remain clear of leaves and debris and free draining. This page provides guidance on maintenance activities that are typically required for these systems, along with the suggested frequency for each activity. Individual systems may have more, or less frequent maintenance needs depending on a variety of factors including but not limited to: the occurrence of large storm events, overly wet or dry periods, regional hydrologic conditions, and the upstream land use.

#### ACTIVITIES

The most common maintenance activity is the removal of sediment and organic debris from the system and bypass structures. Visual inspections are routine for system maintenance. This includes looking for standing water, accumulated leaves, holes in the soil media, signs of plant distress, and debris and sediment accumulation in the system. Vegetation coverage is integral to the performance of the system, including infiltration rate and nutrient uptake. Vegetation care is important to system productivity and health.

ΑCTIVITY	FREQUENCY						
CLOGGING AND SYSTEM PERFORMANCE							
A record should be kept of the time to drain for the system completely after a storm event. The system should drain completely within 72 hours. Check to insure the filter surface remains well draining after storm events. <b>Remedy</b> : If filter bed is clogged, draining poorly, or standing water covers more than 50% of the surface 48 hours after a precipitation event, then remove top few inches of discolored material. Till, or rake remaining material as needed.	After every major storm in the first few months, then annually at minimum.						
Check inlets and outlets for leaves and debris. <b>Remedy</b> : Rake in and around the system to clear it of debris. Also, clear the inlet and overflow if obstructed. Check for animal burrows and short-circuiting in the system. <b>Remedy:</b> Soil erosion from short circuiting or animal boroughs should be repaired when they occur. The holes should be filled and lightly compacted Inspect inlets and outlets to ensure good condition and no evidence of deterioration. Check to see if high-flow bypass is functioning. <b>Remedy:</b> Repair or replace any damaged structural parts, inlets, outlets, sidewalls.	Quarterly initially, annually as a minimum thereafter.						
VEGETATION							
Check for robust vegetation coverage throughout the system and dead or dying plants. <b>Remedy:</b> Vegetation should cover > 75% of the system and should be cared for as needed.	Annually or as needed						

# **APPENDIX C**

UNHSC Checklist for Inspection of Bioretention System

## **CHECKLIST FOR INSPECTION OF BIORETENTION SYSTEM / TREE FILTERS**

Location:

Inspector:

Date:

Time:

Site Conditions:

Days Since Last Rain Event:

Inspection Items	Satisfactory (S) or Unsatisfactory (U)		Comments/Corrective Action
1. Initial Inspection After Planting			
Plants are stable, roots not exposed	S	U	
Surface is at design level, no evidence of	S	U	
preferential flow/shoving			_
Inlet and outlet/bypass are functional	S	U	
2. Debris Cleanup (1 time/year minimum, Spring/Fall)	-		
Litter, leaves, and dead vegetation removed from the system	S	U	
Prune/mow vegetation	S	U	
3. Standing Water (1 time/year and/or after large storm even	ents)		
No evidence of standing water after 24-48 hours since rainfall	S	U	
4. Vegetation Condition and Coverage			
Vegetation condition good with good coverage (typically > 75%)	S	U	
5. Other Issues			
Note any additional issues not previously covered.	S	U	
Corrective Action Needed			Due Date
1.			
2.			
3.			
Inspector Signature	Date		

# APPENDIX D

Control of Invasive Plants

# **CONTROL OF INVASIVE PLANTS**

During maintenance activities, check for the presence of invasive plants and remove in a safe manner as described on the following pages. They should be controlled as described on the following pages.

### Background:

Invasive plants are introduced, alien, or non-native plants, which have been moved by people from their native habitat to a new area. Some exotic plants are imported for human use such as landscaping, erosion control, or food crops. They also can arrive as "hitchhikers" among shipments of other plants, seeds, packing materials, or fresh produce. Some exotic plants become invasive and cause harm by:

- becoming weedy and overgrown;
- killing established shade trees;
- obstructing pipes and drainage systems;
- forming dense beds in water;
- lowering water levels in lakes, streams, and wetlands;
- destroying natural communities;
- promoting erosion on stream banks and hillsides; and
- resisting control except by hazardous chemical.



## Methods for Disposing Non-Native Invasive Plants

Prepared by the Invasives Species Outreach Group, volunteers interested in helping people control invasive plants. Assistance provided by the Piscataquog Land Conservancy and the NH Invasives Species Committee. Edited by Karen Bennett, Extension Forestry Professor and Specialist.



Tatarian honeysuckle Lonicera tatarica USDA-NRCS PLANTS Database / Britton, N.L., and A. Brown. 1913. An illustrated flora of the northern United States, Canada and the British Possessions. Vol. 3: 282.

Non-native invasive plants crowd out natives in natural and managed landscapes. They cost taxpayers billions of dollars each year from lost agricultural and forest crops, decreased biodiversity, impacts to natural resources and the environment, and the cost to control and eradicate them.

Invasive plants grow well even in less than desirable conditions such as sandy soils along roadsides, shaded wooded areas, and in wetlands. In ideal conditions, they grow and spread even faster. There are many ways to remove these nonnative invasives, but once removed, care is needed to dispose the removed plant material so the plants don't grow where disposed.

Knowing how a particular plant reproduces indicates its method of spread and helps determine

the appropriate disposal method. Most are spread by seed and are dispersed by wind, water, animals, or people. Some reproduce by vegetative means from pieces of stems or roots forming new plants. Others spread through both seed and vegetative means.

Because movement and disposal of viable plant parts is restricted (see NH Regulations), viable invasive parts can't be brought to most transfer stations in the state. Check with your transfer station to see if there is an approved, designated area for invasives disposal. This fact sheet gives recommendations for rendering plant parts nonviable.

Control of invasives is beyond the scope of this fact sheet. For information about control visit <u>www.nhinvasives.org</u> or contact your UNH Cooperative Extension office.

#### **New Hampshire Regulations**

Prohibited invasive species shall only be disposed of in a manner that renders them nonliving and nonviable. (Agr. 3802.04)

No person shall collect, transport, import, export, move, buy, sell, distribute, propagate or transplant any living and viable portion of any plant species, which includes all of their cultivars and varieties, listed in Table 3800.1 of the New Hampshire prohibited invasive species list. (Agr 3802.01)

### How and When to Dispose of Invasives?

To prevent seed from spreading remove invasive plants before seeds are set (produced). Some plants continue to grow, flower and set seed even after pulling or cutting. Seeds can remain viable in the ground for many years. If the plant has flowers or seeds, place the flowers and seeds in a heavy plastic bag "head first" at the weeding site and transport to the disposal site. The following are general descriptions of disposal methods. See the chart for recommendations by species.

**Burning:** Large woody branches and trunks can be used as firewood or burned in piles. For outside burning, a written fire permit from the local forest fire warden is required unless the ground is covered in snow. Brush larger than 5 inches in diameter can't be burned. Invasive plants with easily airborne seeds like black swallow-wort with mature seed pods (indicated by their brown color) shouldn't be burned as the seeds may disperse by the hot air created by the fire.

**Bagging (solarization):** Use this technique with softertissue plants. Use heavy black or clear plastic bags (contractor grade), making sure that no parts of the plants poke through. Allow the bags to sit in the sun for several weeks and on dark pavement for the best effect.

Tarping and Drying: Pile material on a sheet of plastic



Japanese knotweed Polygonum cuspidatum USDA-NRCS PLANTS Database / Britton, N.L., and A. Brown. 1913. An illustrated flora of the northern United States, Canada and the British Possessions. Vol. 1: 676.

and cover with a tarp, fastening the tarp to the ground and monitoring it for escapes. Let the material dry for several weeks, or until it is clearly nonviable.

Chipping: Use this method for woody plants that don't reproduce vegetatively.

**Burying:** This is risky, but can be done with watchful diligence. Lay thick plastic in a deep pit before placing the cut up plant material in the hole. Place the material away from the edge of the plastic before covering it with more heavy plastic. Eliminate as much air as possible and toss in soil to weight down the material in the pit. Note that the top of the buried material should be at least three feet underground. Japanese knotweed should be at least 5 feet underground!

**Drowning:** Fill a large barrel with water and place soft-tissue plants in the water. Check after a few weeks and look for rotted plant material (roots, stems, leaves, flowers). Well-rotted plant material may be composted. A word of caution- seeds may still be viable after using this method. Do this before seeds are set. This method isn't used often. Be prepared for an awful stink!

**Composting:** Invasive plants can take root in compost. Don't compost any invasives unless you know there is no viable (living) plant material left. Use one of the above techniques (bagging, tarping, drying, chipping, or drowning) to render the plants nonviable before composting. Closely examine the plant before composting and avoid composting seeds.

Be diligent looking for seedlings for years in areas where removal and disposal took place.

## **Suggested Disposal Methods for Non-Native Invasive Plants**

This table provides information concerning the disposal of removed invasive plant material. If the infestation is treated with herbicide and left in place, these guidelines don't apply. Don't bring invasives to a local transfer station, unless there is a designated area for their disposal, or they have been rendered non-viable. This listing includes wetland and upland plants from the New Hampshire Prohibited Invasive Species List. The disposal of aquatic plants isn't addressed.

Woody Plants	Method of Reproducing	Methods of Disposal
Norway maple (Acer platanoides) European barberry (Berberis vulgaris) Japanese barberry (Berberis thunbergii) autumn olive (Elaeagnus umbellata) burning bush (Euonymus alatus) Morrow's honeysuckle (Lonicera morrowii) Tatarian honeysuckle (Lonicera tatarica) showy bush honeysuckle (Lonicera x bella) common buckthorn (Rhamnus cathartica) glossy buckthorn (Frangula alnus)	Fruit and Seeds	<ul> <li>Prior to fruit/seed ripening</li> <li>Seedlings and small plants <ul> <li>Pull or cut and leave on site with roots exposed. No special care needed.</li> </ul> </li> <li>Larger plants <ul> <li>Use as firewood.</li> <li>Make a brush pile.</li> <li>Chip.</li> <li>Burn.</li> </ul> </li> </ul>
		<ul> <li>After fruit/seed is ripe</li> <li>Don't remove from site.</li> <li>Burn.</li> <li>Make a covered brush pile.</li> <li>Chip once all fruit has dropped from branches.</li> <li>Leave resulting chips on site and monitor.</li> </ul>
oriental bittersweet (Celastrus orbiculatus) multiflora rose (Rosa multiflora)	Fruits, Seeds, Plant Fragments	<ul> <li>Prior to fruit/seed ripening</li> <li>Seedlings and small plants</li> <li>Pull or cut and leave on site with roots exposed. No special care needed.</li> <li>Larger plants</li> <li>Make a brush pile.</li> <li>Burn.</li> </ul>
		<ul> <li>After fruit/seed is ripe Don't remove from site.</li> <li>Burn.</li> <li>Make a covered brush pile.</li> <li>Chip – only after material has fully dried (1 year) and all fruit has dropped from branches. Leave resulting chips on site and monitor.</li> </ul>

Non-Woody Plants	Method of Reproducing	Methods of Disposal
<pre>garlic mustard (Alliaria petiolata) spotted knapweed (Centaurea maculosa) • Sap of related knapweed can cause skin irritation and tumors. Wear gloves when handling. black swallow-wort (Cynanchum nigrum) • May cause skin rash. Wear gloves and long sleeves when handling. pale swallow-wort (Cynanchum rossicum) giant hogweed (Heracleum mantegazzianum) • Can cause major skin rash. Wear gloves and long sleeves when handling. dame's rocket (Hesperis matronalis) perennial pepperweed (Lepidium latifolium) purple loosestrife (Lythrum salicaria) Japanese stilt grass (Microstegium vimineum) mile-a-minute weed (Polygonum perfoliatum)</pre>	Fruits and Seeds	<ul> <li>Prior to flowering Depends on scale of infestation Small infestation <ul> <li>Pull or cut plant and leave on site with roots exposed.</li> </ul> </li> <li>Large infestation <ul> <li>Pull or cut plant and pile. (You can pile onto or cover with plastic sheeting).</li> <li>Monitor. Remove any re-sprouting material.</li> </ul> </li> <li>During and following flowering <ul> <li>Do nothing until the following year or remove flowering heads and bag and let rot.</li> </ul> </li> <li>Small infestation <ul> <li>Pull or cut plant and leave on site with roots exposed.</li> </ul> </li> <li>Large infestation <ul> <li>Pull or cut plant and leave on site with roots exposed.</li> </ul> </li> <li>Large infestation <ul> <li>Pull or cut plant and pile remaining material. (You can pile onto plastic or cover with plastic sheeting).</li> <li>Monitor. Remove any re-sprouting material.</li> </ul> </li> </ul>
common reed ( <i>Phragmites australis</i> ) Japanese knotweed ( <i>Polygonum cuspidatum</i> ) Bohemian knotweed ( <i>Polygonum x bohemicum</i> )	Fruits, Seeds, Plant Fragments Primary means of spread in these species is by plant parts. Although all care should be given to preventing the dispersal of seed during control activities, the presence of seed doesn't materially influence disposal activities.	<ul> <li>Small infestation <ul> <li>Bag all plant material and let rot.</li> <li>Never pile and use resulting material as compost.</li> <li>Burn.</li> </ul> </li> <li>Large infestation <ul> <li>Remove material to unsuitable habitat (dry, hot and sunny or dry and shaded location) and scatter or pile.</li> <li>Monitor and remove any sprouting material.</li> <li>Pile, let dry, and burn.</li> </ul> </li> </ul>

January 2010

UNH Cooperative Extension programs and policies are consistent with pertinent Federal and State laws and regulations, and prohibits discrimination in its programs, activities and employment on the basis of race, color, national origin, gender, religion, age, disability, political beliefs, sex, sexual orientation, or veteran's, marital or family status. College of Life Sciences and Agriculture, County Governments, NH Dept. of Resources and Economic Development, Division of Forests and Lands, NH Fish and Game ,and U.S. Dept. of Agriculture cooperating.
(This Page Is Intentionally Blank)

# **GENERAL INFORMATION**

OWNER MAP 229 LOT 1 ARTWILL, LLC P.O. BOX 370 PORTSMOUTH, NH 03802

APPLICANT MAP 229 LOT 1 ARTWILL, LLC P.O. BOX 370 PORTSMOUTH, NH 03802

PREPARED FOR MAP 229 LOT 1 ARTWILL, LLC P.O. BOX 370 PORTSMOUTH, NH 03802

# **RESOURCE LIST**

PLANNING/ZONING DEPARTMENT 1 JUNKINS AVE PORTSMOUTH, NH 03801 603-610-7216

BUILDING DEPARTMENT JUNKINS AVE PORTSMOUTH, NH 03801 603-610-7243 ROBERT MARSILIA, CHIEF BUILDING INSPECTOR

PUBLIC WORKS 600 PEVERLY HILL RD PORTSMOUTH, NH 03801 603-472-1530 PETER RICE, PUBLIC WORKS DIRECTOR

POLICE DEPARTMENT 3 JUNKINS AVE PORTSMOUTH, NH 03801 603-427-1510 MARK NEWPORT, CHIEF

FIRE DEPARTMENT 170 COURT ST PORTSMOUTH, NH 03801 603-427-1515 PATRICK HOWE, CHIEF

ASSOCIATED PROFESSIONALS ARCHITECT SMITHFIELD CONSTRUCTION, INC. PO BOX 370 PORTSMOUTH, NH 03802 603-674-5204



Copyright 2022 ©TFMoran, Inc. 48 Constitution Drive, Bedford, N.H. 03110

All rights reserved. These plans and materials may not be copied, duplicated, replicated or otherwise reproduced in any form whatsoeve without the prior written permission of TFMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of FMoran, Inc.



# PROPOSED 3 LOT SUBDIVISION

# **437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

# **APRIL 19, 2022** LAST REVISED: MAY 25, 2022

# VICINITY PLAN



Image:	
1 5/23/2022 UPDATE LAST REVISED DATE.	
REV DATE DESCRIPTIC	ON

DR CK

THESE PLANS ARE PERMIT DRAWINGS ONLY AND HAVE NOT BEEN DETAILED FOR CONSTRUCTION OR BIDDING.

	INDEX OF SHEETS
SHEET	SHEET TITLE
C-00	COVER
C-01	NOTES & LEGEND
S-01	EXISTING CONDITIONS PLAN
S-02	SUBDIVISION PLAN
C-02	SITE PREPARATION & DEMOLITION PLAN
C-03	SITE LAYOUT PLAN
C-04	GRADING & DRAINAGE PLAN
C-05	UTILITY PLAN
C-06	LANDSCAPE PLAN
C-07	EROSION CONTROL PLAN
C-08	EROSION CONTROL NOTES
C-09	TRUCK TURNING PLAN
C-10 - C-15	DETAILS
REFERENCE PLANS B	Y ASSOCIATED PROFESSIONALS
_	ARCHITECTURAL ELEVATION PLAN

# PERMITS/APPROVALS

	NUMBER	APPROVED	EXPIRES
CITY PLANNING BOARD SITE PLAN REVIEW	_	_	_
CITY PLANNING BOARD SUBDIVISION REVIEW	-	-	_
CITY PLANNING BOARD CONDITIONAL USE PERMIT FOR AADU	-	_	_
NHDES SEWER CONNECTION PERMIT	_	_	_





W/

CONTACT DIG SAFE 72 BUSINESS HOURS PRIOR TO CONSTRUCTION

WITH

FMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of

# **GENERAL NOTES**

- 1. THESE PLANS ARE PERMIT DRAWINGS ONLY AND HAVE NOT BEEN DETAILED FOR CONSTRUCTION OR BIDDING.
- 2. THESE PLANS WERE PREPARED UNDER THE SUPERVISION OF A LICENSED PROFESSIONAL ENGINEER. TFMORAN, INC. ASSUMES NO LIABILITY AS A RESULT OF ANY CHANGES OR NON-CONFORMANCE WITH THESE PLANS EXCEPT UPON THE WRITTEN APPROVAL OF THE ENGINEER OF RECORD.
- 3. THE SUBDIVISION PLAN SHALL BE RECORDED IN THE ROCKINGHAM COUNTY REGISTRY OF DEEDS.
- 4. ALL IMPROVEMENTS SHOWN ON THE SITE PLAN SHALL BE CONSTRUCTED AND MAINTAINED IN ACCORDANCE WITH THE PLAN BY THE PROPERTY OWNER AND ALL FUTURE PROPERTY OWNERS. NO CHANGES SHALL BE MADE TO THIS SITE PLAN WITHOUT THE EXPRESS APPROVAL OF THE CITY PLANNING BOARD.
- 5. ALL WORK SHALL CONFORM TO THE APPLICABLE REGULATIONS AND STANDARDS OF THE CITY OF PORTSMOUTH, AND SHALL BE BUILT IN A WORKMANLIKE MANNER IN ACCORDANCE WITH THE PLANS AND SPECIFICATIONS, ALL WORK TO CONFORM TO CITY OF PORTSMOUTH DEPARTMENT OF PUBLIC WORKS STANDARD SPECIFICATIONS. ALL WORK WITHIN THE RIGHT-OF-WAY OF THE CITY AND/OR STATE SHALL COMPLY WITH APPLICABLE STANDARDS. COORDINATE ALL WORK WITHIN THE RIGHT-OF-WAY WITH APPROPRIATE CITY, COUNTY, AND/OR STATE AGENCY.
- 6. THE SITE CONTRACTOR SHALL ENSURE THAT ALL WORK IS PERFORMED IN ACCORDANCE WITH APPLICABLE SECTIONS OF ENV-WQ 1500. THE SITE CONTRACTOR SHALL NOTIFY THE ENGINEER IN ADVANCE OF CONSTRUCTION OF EACH STORMWATER FACILITY TO COORDINATE REQUIRED INSPECTIONS. THE CONTRACTOR SHALL TAKE PROGRESS PHOTOS DURING CONSTRUCTION OF ALL STORMWATER DRAINAGE COMPONENTS AND SEND TO THE ENGINEER.
- 7. SEE EXISTING CONDITIONS PLAN FOR THE HORIZONTAL AND VERTICAL DATUM.
- 8. SEE EXISTING CONDITIONS PLAN FOR BENCHMARK INFORMATION. VERIFY TBM ELEVATIONS PRIOR TO CONSTRUCTION.
- 9. CONTACT EASEMENT OWNERS PRIOR TO COMMENCING ANY WORK WITHIN THE EASEMENTS.
- 10. PRIOR TO COMMENCING ANY SITE WORK, ALL LIMITS OF WORK SHALL BE CLEARLY MARKED IN THE FIELD.
- 11. SITE WORK SHALL BE CONSTRUCTED FROM A COMPLETE SET OF PLANS, NOT ALL FEATURES ARE DETAILED ON EVERY PLAN. THE ENGINEER IS TO BE NOTIFIED OF ANY CONFLICT WITHIN THIS PLAN SET.
- 12. TFMORAN, INC. ASSUMES NO LIABILITY FOR WORK PERFORMED WITHOUT AN ACCEPTABLE PROGRAM OF TESTING AND INSPECTION AS APPROVED BY THE ENGINEER OF RECORD.
- 13. TEMPORARY FENCING SHALL BE PROVIDED AND COVERED WITH A FABRIC MATERIAL TO CONTROL DUST MITIGATION.
- 14. ALL DEMOLITION SHALL INSURE MINIMUM INTERFERENCE WITH ROADS, STREETS, WALKWAYS, AND ANY OTHER ADJACENT OPERATING FACILITIES. PRIOR WRITTEN PERMISSION FROM THE OWNER/DEVELOPER AND LOCAL PERMITTING AUTHORITY IS REQUIRED IF CLOSURE/OBSTRUCTIONS TO ROADS, STREET, WALKWAYS, AND OTHERS IS DEEMED NECESSARY. CONTRACTOR TO PROVIDE ALTERNATE ROUTES AROUND CLOSURES/OBSTRUCTIONS PER LOCAL/STATE/FEDERAL REGULATIONS.
- 15. REFER TO ARCHITECTURAL PLANS FOR LAYOUT OF BUILDING FOUNDATIONS AND CONCRETE ELEMENTS WHICH ABUT THE BUILDING SUCH AS STAIRS, SIDEWALKS, LOADING DOCK RAMPS, PADS, AND COMPACTOR PADS. DO NOT USE SITE PLANS FOR LAYOUT OF FOUNDATIONS.
- 16. IN THE EVENT OF A CONFLICT BETWEEN PLANS, SPECIFICATIONS, AND DETAILS, THE ENGINEER SHALL BE NOTIFIED IMMEDIATELY FOR CLARIFICATION.
- 17. IF CONDITIONS AT THE SITE ARE DIFFERENT THAN SHOWN ON THE PLANS, THE ENGINEER SHALL BE NOTIFIED PRIOR TO PROCEEDING WITH THE AFFECTED WORK.
- 18. CONTRACTOR'S GENERAL RESPONSIBILITIES:
- A. BID AND PERFORM THE WORK IN ACCORDANCE WITH ALL LOCAL, STATE, AND NATIONAL CODES, SPECIFICATIONS, REGULATIONS, AND STANDARDS AND CONDITIONS OF ALL PROJECT-SPECIFIC PERMITS AND APPROVALS AS LISTED ON THE COVER SHEET TO THESE PLANS OR OTHERWISE REQUIRED.
- B. NOTIFY ENGINEER IN WRITING OF ANY DISCREPANCIES OF PROPOSED LAYOUT AND/OR EXISTING FEATURES.
- C. EMPLOY A LICENSED SURVEYOR TO DETERMINE ALL LINES AND GRADES AND LAYOUT OF SITE ELEMENTS AND BUILDINGS.
- D. THE CONTRACTOR SHALL BE RESPONSIBLE TO BECOME FAMILIAR WITH THE SITE AND ALL SURROUNDING CONDITIONS. THE CONTRACTOR SHALL ADVISE THE APPROPRIATE AUTHORITY OF INTENTIONS AT LEAST 48 HOURS IN ADVANCE.
- E. TAKE APPROPRIATE MEASURES TO REDUCE, TO THE FULLEST EXTENT POSSIBLE, NOISE, DUST, AND UNSIGHTLY DEBRIS. CONSTRUCTION ACTIVITIES SHALL BE CARRIED OUT BETWEEN THE HOURS OF 7:00 AM AND 9:00 PM, MONDAY THROUGH FRIDAY IN ACCORDANCE WITH THE APPLICABLE MUNICIPAL ORDINANCES AND REGULATIONS OF THE CITY OF PORTSMOUTH, NEW HAMPSHIRE.
- F. MAINTAIN EMERGENCY ACCESS TO ALL AREAS AFFECTED BY WORK AT ALL TIMES.
- G. IN ACCORDANCE WITH RSA 430:53 AND AGR 3800, THE CONTRACTOR SHALL NOT TRANSPORT INVASIVE SPECIES OFF THE PROPERTY, AND SHALL DISPOSE OF INVASIVE SPECIES ON-SITE IN A LEGAL MANNER.
- H. COORDINATE WITH ALL UTILITY COMPANIES AND CONTACT DIGSAFE (811 OR 888-344-7233) AT LEAST 72 HOURS PRIOR TO ANY EXCAVATION.
- I. PROTECT NEW AND EXISTING BURIED UTILITIES DURING INSTALLATION OF ALL SITE ELEMENTS. DAMAGED UTILITIES SHALL BE REPAIRED OR REPLACED AT NO ADDITIONAL COST TO THE OWNER.
- J. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE MEANS AND METHODS OF CONSTRUCTION AND FOR CONDITIONS AT THE SITE. THESE PLANS, PREPARED BY TFMORAN, INC., DO NOT EXTEND TO OR INCLUDE SYSTEMS PERTAINING TO THE SAFETY OF THE CONSTRUCTION CONTRACTOR OR THEIR EMPLOYEES, AGENTS, OR REPRESENTATIVES IN THE PERFORMANCE OF THE WORK. THE SEAL OF THE SURVEYOR OR ENGINEER HEREON DOES NOT EXTEND TO ANY SUCH SAFETY SYSTEMS THAT MAY NOW OR HEREAFTER BE INCORPORATED INTO THESE PLANS. THE CONSTRUCTION CONTRACTOR SHALL PREPARE OR OBTAIN THE APPROPRIATE SAFETY SYSTEMS WHICH MAY BE REQUIRED BY THE US OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA) AND/OR LOCAL REGULATIONS.
- K. WRITTEN DIMENSIONS HAVE PRECEDENCE OVER SCALED DIMENSIONS. THE CONTRACTOR SHALL USE CAUTION WHEN SCALING REPRODUCED PLANS. IN CASE OF CONFLICT BETWEEN THIS PLAN SET AND ANY OTHER DRAWING AND/OR SPECIFICATION, THE ENGINEER SHALL BE NOTIFIED IMMEDIATELY FOR CLARIFICATIONS.
- L. VERIFY LAYOUT OF PROPOSED BUILDING FOUNDATIONS WITH ARCHITECT AND THAT PROPOSED FOUNDATION MEETS PROPERTY LINE AND/OR WETLAND SETBACKS PRIOR TO COMMENCING ANY FOUNDATION CONSTRUCTION.
- M. PROVIDE AN AS-BUILT PLAN AT THE COMPLETION OF THE PROJECT TO THE PLANNING DIRECTOR AND PER CITY REGULATIONS.
- N. IF ANY DEVIATIONS FROM THE APPROVED PLANS AND SPECIFICATIONS HAVE BEEN MADE, THE SITE CONTRACTOR SHALL PROVIDE AS-BUILT DRAWINGS STAMPED BY A LICENSED SURVEYOR OR QUALIFIED ENGINEER ALONG WITH A LETTER STAMPED BY A QUALIFIED ENGINEER DESCRIBING ALL SUCH DEVIATIONS, AND BEAR ALL COSTS FOR PREPARING AND FILING ANY NEW PERMITS OR PERMIT AMENDMENTS THAT MAY BE REQUIRED.
- O. AT COMPLETION OF CONSTRUCTION, THE SITE CONTRACTOR SHALL PROVIDE A LETTER CERTIFYING THAT THE PROJECT WAS COMPLETED IN ACCORDANCE WITH THE APPROVED PLANS AND SPECIFICATIONS, AND A LETTER STAMPED BY A QUALIFIED ENGINEER THAT THEY HAVE OBSERVED ALL UNDERGROUND DETENTION SYSTEMS, INFILTRATION SYSTEMS, OR FILTERING SYSTEMS PRIOR TO BACKFILL, AND THAT SUCH SYSTEMS CONFORM TO THE APPROVED PLANS AND SPECIFICATIONS.

# **GRADING & DRAINAGE NOTES**

- 1. THE CONTRACTOR SHALL PREPARE, MAINTAIN, AND EXECUTE A S.W.P.P.P. IN ACCORDANCE WITH EPA REGULATIONS AND THE CONSTRUCTION GENERAL PERMIT.
- 2. THE CONTRACTOR SHALL COORDINATE WITH THE OWNER TO SUBMIT AN ENOI AT LEAST 14 DAYS IN ADVANCE OF ANY EARTHWORK ACTIVITIES AT THE SITE.
- 3. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO CHECK THE ACCURACY OF THE TOPOGRAPHY AND REPORT ANY DISCREPANCIES TO THE ENGINEER PRIOR TO ANY EARTHWORK BEING PERFORMED ON THE SITE. NO CLAIM FOR EXTRA WORK WILL BE CONSIDERED FOR PAYMENT AFTER EARTHWORK HAS COMMENCED.
- 4. THE CONTRACTOR SHALL REFER TO THE GEOTECHNICAL REPORT FOR INFORMATION ABOUT SOIL AND GROUNDWATER CONDITIONS. THE CONTRACTOR SHALL FOLLOW THE GEOTECHNICAL ENGINEER'S RECOMMENDED METHODS TO ADDRESS ANY SOIL AND GROUNDWATER ISSUES THAT ARE FOUND ON SITE, INCLUDING AND NOT LIMITED TO DEWATERING METHODS, PERIMETER DRAINS AND TIE INTO STORMWATER MANAGEMENT SYSTEM, ETC.
- 5. COORDINATE WITH GEOTECHNICAL/STRUCTURAL PLANS FOR SITE PREPARATION AND OTHER BUILDING INFORMATION.
- COORDINATE WITH ARCHITECTURAL PLANS FOR DETAILED GRADING AT BUILDING, AND SIZE AND LOCATION OF ALL BUILDING SERVICES.
- 7. COORDINATE WITH MECHANICAL AND PLUMBING PLANS FOR ROOF DRAIN INFORMATION.
- 8. LIMITS OF WORK ARE SHOWN AS APPROXIMATE. THE CONTRACTOR SHALL COORDINATE ALL WORK TO PROVIDE SMOOTH TRANSITIONS. THIS INCLUDES GRADING, PAVEMENT, CURBING, SIDEWALKS, AND ALIGNMENTS.
- 9. THE CONTRACTOR SHALL PROVIDE A FINISH PAVEMENT SURFACE FREE OF LOW SPOTS AND PONDING AREAS. CRITICAL AREAS INCLUDE BUILDING ENTRANCE, RAMPS, AND LOADING AREAS
- 10. THE SITE SHALL BE GRADED SO ALL FINISHED PAVEMENT HAS POSITIVE DRAINAGE AND SHALL NOT POND WATER DEEPER THAN 1/4" FOR A PERIOD OF MORE THAN 15 MINUTES AFTER FLOODING.
- 11. ALL ELEVATIONS SHOWN AT CURB ARE TO THE BOTTOM OF CURB UNLESS OTHERWISE NOTED. CURBS HAVE A 6" REVEAL UNLESS OTHERWISE NOTED.
- 12. ALL SIDEWALK AND OTHER CURB REVEALS SHALL BE 6" WITH A TOLERANCE OF PLUS OR MINUS 3/8". WHERE SIDEWALK IS TO BE FLUSH. THE PAVEMENT REVEAL SHALL BE 1/4" WITH A TOLERANCE OF 1/8".
- 13. ADJUST ALL MANHOLES, CATCH BASINS, CURB BOXES, ETC. WITHIN LIMITS OF WORK TO FINISH GRADE PRIOR TO INSTALLATION OF FINISHED PAVEMENT.
- 14. ROAD AND DRAINAGE CONSTRUCTION SHALL CONFORM TO THE DETAILS SHOWN ON THE PLANS AND SHALL MEET LOCAL STANDARDS AND THE REQUIREMENTS OF THE LATEST NHDOT STANDARD SPECIFICATIONS FOR ROADS AND BRIDGE CONSTRUCTION AND THE NHDOT STANDARD STRUCTURE DRAWINGS UNLESS OTHERWISE NOTED.
- 15. STORMWATER DRAINAGE SYSTEM SHALL BE CONSTRUCTED TO LINE AND GRADE AS SHOWN ON THE PLANS. CONSTRUCTION METHODS SHALL CONFORM TO NHDOT STANDARD SPECIFICATIONS, SECTION 603. CATCH BASINS AND DRAIN MANHOLES SHALL CONFORM TO SECTION 604. ALL CATCH BASIN GRATES SHALL BE TYPE B AND CONFORM TO NHDOT STANDARDS AND SPECIFICATIONS UNLESS OTHERWISE NOTED.
- 16. NO FILL SHALL BE PLACED IN ANY WETLAND AREA.
- 17. ALL EXCAVATIONS SHALL BE THOROUGHLY SECURED ON A DAILY BASIS BY THE CONTRACTOR AT THE COMPLETION OF CONSTRUCTION OPERATIONS IN THE IMMEDIATE AREA.
- 18. ALL DISTURBED AREAS NOT TO BE PAVED OR OTHERWISE TREATED SHALL RECEIVE 6" LOAM, SEED, FERTILIZER, AND MULCH.

19. DENSITY REQUIREMENTS: MINIMUM DENSITY\* 95%

95%

90%

LOCATION BELOW PAVED OR CONCRETE AREAS TRENCH BEDDING MATERIAL AND SAND BLANKET BACKFILL BELOW LOAM AND SEED AREAS

\*ALL PERCENTAGES OF COMPACTION SHALL BE OF THE MAXIMUM DRY DENSITY AT THE OPTIMUM MOISTURE CONTENT AS DETERMINED AND CONTROLLED IN ACCORDANCE WITH ASTM D-1557, METHOD C. FIELD DENSITY TESTS SHALL BE MADE IN ACCORDANCE WITH ASTM D-1556 OR ASTM D-6938.

			(mmm)
REV	DA TE	DESCRIP	TION

SEDIMENT OIL SEPARATOR TAPPING SLEEVE, VALVE, AND BOX

SMH

SOS

TSV

SEWER MANHOLE

UTILITY POLF

# UTILITY NOTES

1. LENGTH OF PIPE IS FOR CONVENIENCE ONLY. ACTUAL PIPE LENGTH SHALL BE DETERMINED IN THE FIELD.

2. ALL PROPOSED UTILITY WORK, INCLUDING MATERIAL, INSTALLATION, TERMINATION, EXCAVATION, BEDDING, BACKFILL, COMPACTION, TESTING, CONNECTIONS, AND CONSTRUCTION SHALL BE COORDINATED WITH AND COMPLETED IN ACCORDANCE WITH THE APPROPRIATE REQUIREMENTS, CODES, AND STANDARDS OF ALL CORRESPONDING UTILITY ENTITIES AND SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.

3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING AND DETERMINING THE LOCATION, SIZE, AND ELEVATION OF ALL EXISTING UTILITIES, SHOWN OR NOT SHOWN ON THESE PLANS, PRIOR TO THE START OF ANY CONSTRUCTION. THE ENGINEER SHALL BE NOTIFIED IN WRITING OF ANY UTILITIES FOUND INTERFERING WITH THE PROPOSED CONSTRUCTION AND APPROPRIATE REMEDIAL ACTION BE AGREED TO BY THE ENGINEER BEFORE PROCEEDING WITH THE WORK. THE CONTRACTOR SHALL BE RESPONSIBLE TO CONTACT "DIGSAFE" (811) AT LEAST 72 HOURS BEFORE DIGGING.

4. COORDINATE ALL WORK ADJACENT TO PROPOSED BUILDINGS WITH ARCHITECTURAL BUILDING DRAWINGS. CONFIRM UTILITY PENETRATIONS AND INVERT ELEVATIONS ARE COORDINATED PRIOR TO INSTALLATION.

5. THE CONTRACTOR SHALL CONTACT ALL UTILITY COMPANIES OWNING UTILITIES, EITHER OVERHEAD OR UNDERGROUND, WITHIN THE CONSTRUCTION AREA AND SHALL COORDINATE AS NECESSARY WITH THE UTILITY COMPANIES OF SAID UTILITIES. THE PROTECTION OR RELOCATION OF UTILITIES IS ULTIMATELY THE RESPONSIBILITY OF THE CONTRACTOR.

6. THE EXACT LOCATION OF NEW UTILITY CONNECTIONS SHALL BE DETERMINED BY THE CONTRACTOR IN COORDINATION WITH UTILITY COMPANY, COUNTY AGENCY, AND/OR PRIVATE UTILITY COMPANY.

7. THE CONTRACTOR SHALL PROVIDE AND INSTALL ALL MANHOLES, BOXES, FITTINGS, CONNECTORS, COVER PLATES, AND OTHER MISCELLANEOUS ITEMS NOT NECESSARILY DETAILED ON THESE DRAWINGS TO RENDER THE UTILITY INSTALLATION COMPLETE AND OPERATIONAL

8. ALL UTILITY COMPANIES REQUIRE INDIVIDUAL CONDUITS. CONTRACTOR TO COORDINATE WITH TELEPHONE, CABLE, AND ELECTRIC COMPANIES REGARDING NUMBER, SIZE, AND TYPE OF CONDUITS REQUIRED PRIOR TO INSTALLATION OF ANY CONDUIT.

- 9. SANITARY SEWER SHALL BE CONSTRUCTED TO THE STANDARDS AND SPECIFICATIONS AS SHOWN ON THESE PLANS. ALL SEWER MAINS AND FITTINGS SHALL BE PVC AND SHALL CONFORM TO ASTM F 679 (SDR 35 MINIMUM). FORCE MAINS AND FITTINGS SHALL CONFORM TO NH CODE OF ADMINISTRATIVE RULES ENV-WQ 700. ALL SEWER CONSTRUCTION SHALL BE IN ACCORDANCE WITH NH CODE OF ADMINISTRATIVE RULES ENV-WQ 700. SANITARY MANHOLES SHALL CONFORM TO NHDES WATER DIVISION WASTEWATER ENGINEERING BUREAU STANDARDS AND SPECIFICATIONS SHOWN HEREON.
- 10. ON-SITE WATER DISTRIBUTION SHALL BE TO CITY OF PORTSMOUTH STANDARDS AND SPECIFICATIONS. WATER MAINS SHALL HAVE A MINIMUM OF 5.5' COVER. WHERE WATER PIPES CROSS SEWER LINES A MINIMUM OF 18" VERTICAL SEPARATION BETWEEN THE TWO OUTSIDE PIPE WALLS SHALL BE OBSERVED. HORIZONTAL SEPARATION BETWEEN WATER AND SEWER SHALL BE 10' MINIMUM. WHERE A SANITARY LINE CROSSES A WATER LINE, SEWER LINE MUST BE CONSTRUCTED OF FORCE MAIN MATERIALS (PER ENV-WQ 704.08) FROM BUILDING OR MANHOLE TO MANHOLE, OR SUBSTITUTE RUBBER-GASKETED PRESSURE PIPE FOR THE SAME DISTANCE. WHEN SANITARY LINES PASS BELOW WATER LINES, LAY PIPE SO THAT NO JOINT IN THE SANITARY LINE WILL BE CLOSER THAN 6' HORIZONTALLY TO THE WATER LINE
- 11. THRUST BLOCKS SHALL BE PROVIDED AT ALL LOCATIONS WHERE WATER LINE CHANGES DIRECTIONS OR CONNECTS TO ANOTHER WATER LINE.
- 12. THE GENERAL CONTRACTOR IS RESPONSIBLE FOR CONDUIT AND WIRING TO ALL SIGNS AND LIGHTS. CONDUIT TO BE A MINIMUM OF 24" BELOW FINISH GRADE.
- 13. ALL PROPOSED UTILITIES SHALL BE UNDERGROUND. ALL UNDERGROUND CONDUITS SHALL HAVE NYLON PULL ROPES.
- 14. THE CONTRACTOR SHALL ARRANGE AND PAY FOR ALL INSPECTIONS. TESTING, AND RELATED SERVICES AND SUBMIT COPIES OF ACCEPTANCE TO THE OWNER, UNLESS OTHERWISE INDICATED.
- 15. PROVIDE PERMANENT PAVEMENT REPAIR FOR ALL UTILITY TRENCHES IN EXISTING ROAD OR PAVEMENT TO REMAIN. SAW CUT TRENCH, PAVEMENT, AND GRANULAR BASE THICKNESS TO MATCH EXISTING PAVEMENT. OBTAIN ALL PERMITS REQUIRED FOR TRENCHING.
- 16. UNLESS OTHERWISE SPECIFIED, ALL UNDERGROUND STRUCTURES, PIPES, CHAMBERS, ETC. SHALL BE COVERED WITH A MINIMUM OF 18" OF COMPACTED SOIL BEFORE EXPOSURE TO VEHICLE LOADS

17. THE PROPERTY WILL BE SERVICED BY THE FOLLOWING: DRAINAGE PRIVATE

DNAINAGE	
SEWER	Μl
WATER	Μl
GAS	١U
ELECTRIC	E١
TELEPHONE	СС
CABLE	CC

**IUNICIPAL** INITIL

INICIPA

VERSOURCE CONSOLIDATED COMMUNICATIONS FKA FAIRPOINT COMMUNICATIONS COMCAST

SITE DEVELOPMENT PLANS TAX MAP 229 LOT 1 **NOTES & LEGEND PROPOSED 3 LOT SUBDIVISION 437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE OWNED BY & PREPARE FOR **ARTWILL**, LLC **APRIL 19, 2022** SCALE: NTS ivil Engineers 48 Constitution Drive tructural Engineers Bedford, NH 03110 ffic Engineers Phone (603) 472-4488 ind Surveyors Fax (603) 472-9747 andscape Architects www.tfmoran.com cientists |45407-120 DR JSM FB C - 0145407-120\_NOTES DR CK



DIGSAFE
ME NH RY
A A A A A A A A A A A A A A A A A A A
To 4be CALL 811 TOLL FLENION
TOPOUND PLANT DAMAGE PRO

Ł	had to the second of	
L	4.55	Î
Ł	4 Star Sale	
Ł	021/NO.\02	1
L	58/ 844 Str	
l	N.S.	
L	S. R. J.	
Ł	COREY Va	
İ.	R COLIMELI	
l	COLVELL	
L	()	10
	I stallolig	IX /
	SIGNATURE VVV	$1^{\smile}$
-		-

1	5/25/2022	NO REVISIONS THIS SHEET
REV.	DA TE	DESCRIPTION

### TEST PIT LOG SITE: 437 LAFAYETTE ROAD, PORTSMOUTH, NH LOGGED BY: PAUL O'HANLON, TFM, INC. DATE: 1/25/2022 <u>Test Pit #1:</u> 0-13" 10YR 5/3 BROWN, LOAM, MASSIVE, FRIABLE, ANTHROPOGENIC FILL (ASPHALT, BRICK) 13–20" AB 10YR 7/6 YELLOW, LOAM, BLOCKY, FRIABLE, GRAVELY <5% ROCK (IRON STONE) 20-55" B1 GLEY 1 7N GRAY, SANDY LOAM, MASSIVE, PLIABLE 55- 65" B2 10YR 5/1 GRAY, COARSE SAND, FRIABLE, MASSIVE, > 15% ANGULAR ROCK FRAGMENT (IRON STONE) REDOX @ 20" 10YR 7/8 COMMON DISTINCT >15% SOIL SERIES: WALPOLE EST WET: 20" BELOW GRADE OBS WT: 39" BELOW GRADE (APPARENT $\rightarrow$ ) LEDGE: > 65" BELOW GRADE <u>Test Pit #2:</u> 0-15"A 10YR 4/3 BROWN, LOAM, MASSIVE 15–17" 10YR 7/6 YELLOW, SANDY LOAM, FRIABLE, GRANULAR 17–27" GLEY 1 7/N LIGHT GRAY, SANDY LOAM, FRIABLE, GRANULAR 27-52" 10YR 6/6 BROWNISH YELLOW, LOAM, FRIABLE, MASSIVE 52–77" 10YR 5/1 GRAY, COURSE SAND, FRIABLE, GRAVELY, GRANULAR REDOX @ 26" 10YR 7/8 COMMON DISTINCT SOIL SERIES: WALPOLE EST WET: 26" BELOW GRADE OBS WT: 51" BELOW GRADE (APPARENT ↑) LEDGE: 77" BELOW GRADE <u>Test Pit #3:</u> 0–16" 10YR 4/3 BROWN, LOAM, AGGREGATED, FRIABLE 16-27" 10YR 6/6 BROWNISH YELLOW, LOAM, AGGREGATED, FRIABLE, GRAVELY >5% 27-52" 10YR 7/2 LIGHT GRAY, LOAMY SAND, AGGREGATED, FRIABLE GRAVELY >15% 52-84" 10YR 8/1 WHITE, SANDY CLAY LOAM, PLATEY, INDURATE REDOX @: 41" 10YR 7/8 COMMON DISTINCT >15% SOIL SERIES: CANTON – CHATFIELD COMPLEX EST WET: 41" BELOW GRADE OBS WT: 84" BELOW GRADE (APPARENT 🛛) LEDGE: 84" BELOW GRADE <u>Test Pit #4:</u> 0-18" 10YR 5/4 YELLOWISH BROWN, LOAM, FRIABLE, AGGREGATE 18-27" 10YR 6/6 BROWNISH YELLOW, SANDY LOAM, GRAVELY >5%, FRIABLE, AGGREGATE 27-37" 10YR 6/2 LIGHT BROWNISH GREY, LOAMY SAND, > 15% ANGULAR ROCK FRAGMENT (IRON STONE) 37-65" 10YR 7/8 YELLOW, DECAYING BEDROCK, ANGULAR COBBLE, IRON STONE REDOX @: 5R 3/8 COMMON DISTINCT >15% SOIL SERIES: CHATFIELD EST WET: 37" BELOW GRADE OBS WT: 56" BELOW GRADE (APPARENT ↑) LEDGE: 65" BELOW GRADE <u>Test Pit #5:</u> 0-10" 10YR 4/3 BROWN, LOAMY SAND, AGGREGATE, FRIABLE, GRAVELY >5% 10-31" 10YR 5/4 YELLOWISH BROWN, COURSE SAND, GRANULAR, FRIABLE, GRAVELY >15% 31-57" GLEY 1 5/N GRAY, CLAY, DECAYED BEDROCK, BOULDERS >5%, MASSIVE REDOX @: 31" 5R 3/8 COMMON DISTINCT >15% SOIL SERIES: CHATFIELD – MAYBID COMPLEX EST WET: 31" BELOW GRADE OBS WT: > 57" LEDGE: 57" BELOW GRADE

Copyright 2022 © TFMoran, Inc. 48 Constitution Drive, Bedford, N.H. 03110

All rights reserved. These plans and materials may not be copied, duplicated, replicated or otherwise reproduced in any form whatsoever without the prior written permission of TFMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of TFMoran, Inc.

SITE: 137	
LOGGED BY DATE: 1/2	<pre>/: PAUL O'HANLON, TFM, INC. 5/2022</pre>
<u>Test Pit</u>	<u>#6:</u>
0—12" 12—16"	10YR 4/3 BROWN, SANDY LOAM, AGGREGATE, FRIABLE
12 10	GRAVELY >5%
16-28"	10YR 7/1 LIGHT GRAY, FINE SAND, GRANULAR, FRIABLE
28-42"	10YR 7/3 VERY PALE BROWN, SANDY LOAM, AGGREGATE, FRIABLE, HETEROGENEOUS
42-47"	GLEY 1 $5/5G-1$ GREENISH GRAY, SANDY CLAY LOAM, PLAT INDURATE
47-96"	GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, MASSIVE, INDURATE, HOMOGENEOUS
REDOX @4	42" 5R 3/8 COMMON DISTINCT >15%
	SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC)
EST WET:	42" BELOW GRADE
OBS WT:	79″ BELOW GRADE (APPARENT →)
LEDGE: >	96″
Test Pit	· #7·
0–18″	10YR 4/2 DARK GRAYISH BROWN, SANDY LOAM, FRIABLE, BLOCKY
18-42"	10YR 7/4 VERY PALE BROWN, FINE SAND, GRANULAR, FRIA
42-54"	10YR 6/6 BROWNISH YELLOW, COURSE SAND, GRANULAR, FRIABLE
54-65"	10YR 5/8 YELLOWISH BROWN, SANDY LOAM, HETEROGENEOU FRIABLE
65-72"	GLEY 2 4/10B DARK BLUEISH GRAY, SANDY CLAY LOAM, PLATEY, INDURATE
72–102"	GLEY 2 7/10B LIGHT BLUEISH GRAY, CLAY, MASSIVE, INDUF REDOX © 57" 5R 3/8 COMMON DISTINCT >15%
FST WET	57" DELOW CRADE
1	
ORS WITH	J/ BELOW GRADE
OBS WT: LEDGE: >	93″ BELOW GRADE (APPARENT 个) 102″
OBS WT: LEDGE: > <u>Test Pit</u>	93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u>
OBS WT: LEDGE: > <u>Test Pit</u> 0-14"	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10yr 4/2 Dark grayish brown, loamy sand, friable, BLOCKY
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42"	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50"	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55"	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE 10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION. HETEROGENEOUS, MASSIVE, INDURATE
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55" 55-103"	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE 10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION, HETEROGENEOUS, MASSIVE, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE, MASSIVE
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55" 55-103" REDOX @	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE 10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION, HETEROGENEOUS, MASSIVE, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE, MASSIVE 42 5R 3/8 COMMON DISTINCT >15% (AQUATARD (POTENTIALLY ANTHROPOGENIC))
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55" 55-103" REDOX @	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE 10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION, HETEROGENEOUS, MASSIVE, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE, MASSIVE 42 5R 3/8 COMMON DISTINCT >15% (AQUATARD (POTENTIALLY ANTHROPOGENIC)) SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC) 42" DELOW CRADE
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55" 55-103" REDOX @ EST WET: OBS WT	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE 10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION, HETEROGENEOUS, MASSIVE, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE, MASSIVE 42 5R 3/8 COMMON DISTINCT >15% (AQUATARD (POTENTIALLY ANTHROPOGENIC)) SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC) 42" BELOW GRADE 101" PELOW CRADE (APPARENT ♠)
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55" 55-103" REDOX @ EST WET: OBS WT: LEDGE: >	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE 10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION, HETEROGENEOUS, MASSIVE, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE, MASSIVE 42 5R 3/8 COMMON DISTINCT >15% (AQUATARD (POTENTIALLY ANTHROPOGENIC)) SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC) 42" BELOW GRADE 101" BELOW GRADE (APPARENT ↑) 103"
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55" 55-103" REDOX @ EST WET: OBS WT: LEDGE: > Test Pit	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE 10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION, HETEROGENEOUS, MASSIVE, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE, MASSIVE 42 5R 3/8 COMMON DISTINCT >15% (AQUATARD (POTENTIALLY ANTHROPOGENIC)) SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC) 42" BELOW GRADE 101" BELOW GRADE (APPARENT ↑) 103"
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55" 55-103" REDOX @ EST WET: OBS WT: LEDGE: > <u>Test Pit</u> 0-9"10YR	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE 10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION, HETEROGENEOUS, MASSIVE, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE, MASSIVE 42 5R 3/8 COMMON DISTINCT >15% (AQUATARD (POTENTIALLY ANTHROPOGENIC)) SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC) 42" BELOW GRADE 101" BELOW GRADE (APPARENT ↑) 103" <u>#9:</u> 2 4/3 BROWN, LOAM, BLOCKY, FRIABLE, GRAVELY >5%
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55" 55-103" REDOX @ EST WET: OBS WT: LEDGE: > <u>Test Pit</u> 0-9"10YR 9-23"	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102"
OBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55" 55-103" REDOX @ EST WET: OBS WT: LEDGE: > <u>Test Pit</u> 0-9"10YR 9-23" 23-54"	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE 10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION, HETEROGENEOUS, MASSIVE, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE, MASSIVE 42 5R 3/8 COMMON DISTINCT >15% (AQUATARD (POTENTIALLY ANTHROPOGENIC)) SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC) 42" BELOW GRADE 101" BELOW GRADE (APPARENT ↑) 103" <u>#9:</u> 4/3 BROWN, LOAM, BLOCKY, FRIABLE, GRAVELY >5% 10YR 5/6 YELLOWISH BROWN, LOAMY SAND, GRANULAR, , 15% ANGULAR ROCK FRAGMENT (IRON STONE) 10YR 7/2 LIGHT GREY, SANDY LOAM, INDURATE, MASSIVE, HETEROGENEOUS, > 15% ANGULAR ROCK FRAGMENT (IRON STONE)
OBS WT:         LEDGE:         14-42"         42-50"         50-55"         55-103"         REDOX @         EST WET:         OBS WT:         LEDGE:         >         12-50"         50-55"         55-103"         REDOX @         EST WET:         OBS WT:         LEDGE:         23-54"         REDOX @	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102"
OBS WT:         LEDGE:         Test Pit $0-14"$ $14-42"$ $42-50"$ $50-55"$ $55-103"$ REDOX @         EST WET:         OBS WT:         LEDGE:         > $70-55"$ $70-55"$ $70-55"$ $70-55"$ $90-55"$ $70-55"$ $90-23"$ $23-54"$ REDOX @         EST WET:         OBS WT:         LEDGE: $70-9"10YR$ $9-23"$ $23-54"$ REDOX @         EST WET:         OBS WET:	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102" <u>#8:</u> 10YR 4/2 DARK GRAYISH BROWN, LOAMY SAND, FRIABLE, BLOCKY 10YR 7/4 VERY PALE BROWN, FINE SAND, AGGREGATE, FRIABLE, > 15% COBBLE RIVER STONE GLEY 1 5/5G_/1 GREENISH GRAY, SANDY CLAY LOAM, AQUATARD PRESENT (IRON STONE), MASSIVE, INDURATE 10YR 6/4 LIGHT YELLOWISH BROWN, SANDY CLAY LOAM, INCLUSION, HETEROGENEOUS, MASSIVE, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE GLEY 2 8/5BG LIGHT GREENISH GRAY, CLAY, INDURATE, MASSIVE 42 5R 3/8 COMMON DISTINCT >15% (AQUATARD (POTENTIALLY ANTHROPOGENIC)) SOIL SERIES: CANTON COMPLEX (ANTHROPOGENIC) 42" BELOW GRADE 101" BELOW GRADE (APPARENT ↑) 103" <u>#9:</u> 4/3 BROWN, LOAM, BLOCKY, FRIABLE, GRAVELY >5% 10YR 5/6 YELLOWISH BROWN, LOAMY SAND, GRANULAR, , 15% ANGULAR ROCK FRAGMENT (IRON STONE) 10YR 7/2 LIGHT GREY, SANDY LOAM, INDURATE, MASSIVE, HETEROGENEOUS, > 15% ANGULAR ROCK FRAGMENT (IRON STONE) 5R 4/6 COMMON DISTINCT >15% SOIL SERIES: WALPOLE 30" BELOW GRADE
DBS WT: LEDGE: > <u>Test Pit</u> 0-14" 14-42" 42-50" 50-55" 55-103" REDOX @ EST WET: DBS WT: LEDGE: > <u>Test Pit</u> 0-9"10YR 9-23" 23-54" REDOX @ EST WET: OBS WT: LEDGE: 5.	93" BELOW GRADE 93" BELOW GRADE (APPARENT ↑) 102"

### TEST PIT LOG SITE: 437 LAFAYETTE ROAD, PORTSMOUTH, NH LOGGED BY: PAUL O'HANLON, TFM, INC. DATE: 2/1/2022 <u>Test Pit #10:</u> 0-12" 10YR 4/4 DARK YELLOWISH BROWN, LOAMY SAND, BLOCKY, FRIABLE, COBBLE >15%, HOMOGENEOUS SOIL 12-23" 10YR 6/3 PALE BROWN, SANDY LOAM, AGGREGATE, FRIABLE, COBBLE >15%, HOMOGENEOUS SOIL 23-36" 10YR 6/2 LIGHT BROWNISH GREY, COURSE SAND, GRANULAR, HETEROGENEOUS, COBBLE >15%, VERY COURSE PARTICLES <5% 36-66" 10YR 5/4 YELLOWISH BROWN, LOAMY SAND, MASSIVE,

(IRON STONE)

EST WET: 52" BELOW GRADE

LEDGE: 76" BELOW GRADE

OBS WT: >76"

1	5/25/2022	NO REVISIONS THIS SHEET
REV.	DA TE	DESCRIPTION

INDURATE > 25% ANGULAR ROCK FRAGMENT (IRON STONE) 66-76" 10YR 5/4 YELLOWISH BROWN, SANDY LOAM, MASSIVE, INDURATE, DECAYING LEDGE, > 55% ANGULAR ROCK FRAGMENT

REDOX @ 52 - 58 10YR 5/6 COMMON DISTINCT >15% SOIL SERIES: CANTON – WALPOLE COMPLEX







DR CK

45407-120

DR MVP FB 583 CK JCC CADFILE

S-03



# NOTES

1. SEE NOTES ON SHEET C-01.



- 3. THE CONTRACTOR SHALL MAINTAIN EMERGENCY ACCESS TO ALL AREAS AFFECTED BY WORK AT ALL
- 4. THE CONTRACTOR SHALL VERIFY ALL SURVEY INFORMATION IN THE FIELD AND REPORT ANY DISCREPANCIES TO THE ENGINEER PRIOR TO THE START OF CONSTRUCTION.
- 5. EXISTING UTILITY SERVICES TO BE DISCONTINUED ARE TO BE CAPPED AS REQUIRED BY THE RESPECTIVE UTILITY COMPANIES. 6. CONSTRUCTION DEBRIS AND INVASIVE SPECIES SHALL BE REMOVED FROM SITE AND DISPOSED OF IN A
- LEGAL MANNER. 7. PRIOR TO THE START OF WORK, THE CONTRACTOR SHALL PLACE ORANGE CONSTRUCTION FENCING AROUND EACH TREE TO BE RETAINED THROUGHOUT CONSTRUCTION. NO STOCKPILES OF MATERIAL ARE PERMITTED WITHIN THE DRIP LINE OF THE TREES TO BE SAVED.
- 8. CONTACT THE LANDSCAPE ARCHITECT IMMEDIATELY IF ANY TREES ARE DAMAGED DURING CONSTRUCTION.

# **CONSTRUCTION SEQUENCE NOTES**

TO MINIMIZE EROSION AND SEDIMENTATION DUE TO CONSTRUCTION, CONSTRUCTION SHALL FOLLOW THIS GENERAL CONSTRUCTION SEQUENCE.

MODIFICATIONS TO THE SEQUENCE NECESSARY DUE TO THE CONTRACTOR'S SCHEDULE SHALL INCLUDE APPROPRIATE TEMPORARY AND PERMANENT EROSION AND SEDIMENTATION CONTROL MEASURES.

THE CONTRACTOR SHALL SCHEDULE WORK SUCH THAT ANY CONSTRUCTION AREA IS STABILIZED WITHIN 45 DAYS OF INITIAL DISTURBANCE EXCEPT AS NOTED BELOW. NO MORE THAN 5 ACRES OF DISTURBED LAND SHALL BE UNSTABILIZED AT ANY ONE TIME.

THE PROJECT SHALL BE MANAGED SO THAT IT MEETS THE REQUIREMENTS AND INTENT OF RSA 430:53 AND CHAPTER ARG 3800 RELATIVE TO INVASIVE SPECIES.

DO NOT TRAFFIC EXPOSED SOIL SURFACE OF INFILTRATION SYSTEMS WITH CONSTRUCTION EQUIPMENT. IF FEASIBLE, PERFORM EXCAVATIONS WITH EQUIPMENT POSITIONED OUTSIDE THE LIMITS OF THE INFILTRATION COMPONENTS OF THE SYSTEM.

DO NOT DISCHARGE SEDIMENT-LADEN WATERS FROM CONSTRUCTION ACTIVITIES (RUNOFF, WATER FROM EXCAVATIONS) TO STORMWATER BMP'S. STORMWATER RUNOFF MUST BE DIRECTED TO TEMPORARY PRACTICES UNTIL STORMWATER BMP'S ARE STABILIZED.

DO NOT PLACE STORMWATER BMP'S INTO SERVICE UNTIL THE CONTRIBUTING AREAS HAVE BEEN FULLY STABILIZED.

AFTER THE INFILTRATION SYSTEM IS EXCAVATED TO THE FINAL DESIGN ELEVATION, THE FLOOR SHOULD BE DEEPLY TILLED WITH A ROTARY TILLER OR DISC HARROW TO RESTORE THE INFILTRATION RATES, FOLLOWED BY A PASS WITH A LEVELING DRAG.

- NOTIFY EASEMENT OWNERS PRIOR TO COMMENCEMENT OF WORK. 2. INSTALL ALL PERIMETER EROSION PROTECTION MEASURES AS INDICATED ON THE PLANS PRIOR TO THE
- COMMENCEMENT OF CONSTRUCTION. STORMWATER TREATMENT PONDS AND SWALES SHALL BE INSTALLED BEFORE ROUGH GRADING THE SIT
- 4. DURING CONSTRUCTION EVERY EFFORT SHALL BE MADE TO MANAGE SURFACE RUNOFF QUALITY. 5. DAILY, OR AS REQUIRED, CONSTRUCT TEMPORARY BERMS, DRAINS, DITCHES, SILT BARRIERS, SEDIMENT TRAPS, ETC. MULCH AND SEED AS REQUIRED. (TEMPORARY SEED MIXTURE OF WINTER RYE APPLIED A
- A RATE OF 2.5 LBS/1000 SF SHALL BE USED). 6. CONDUCT MAJOR EARTHWORK, INCLUDING CLEARING AND GRUBBING, WITHIN THE LIMITS OF WORK. ALL CUT AND FILL SLOPES SHALL BE SEEDED WITHIN 72 HOURS AFTER GRADING.
- 7. ALL STRIPPED TOPSOIL AND OTHER EARTH MATERIALS SHALL BE STOCKPILED OUTSIDE THE IMMEDIATE WORK AND WETLAND AREAS. A SILT BARRIER SHALL BE CONSTRUCTED AROUND THESE PILES IN A MANNER TO PROVIDE ACCESS AND AVOID SEDIMENT OUTSIDE OF THE WORK AREA. 8. CONSTRUCT BUILDING PAD AND COMMENCE NEW BUILDING CONSTRUCTION.
- 9. CONSTRUCT TEMPORARY CULVERTS AND DIVERSIONS AS REQUIRED.
- 10. BEGIN PERMANENT AND TEMPORARY INSTALLATION OF SEED AND MULCH 11. PERFORM EARTHWORK NECESSARY TO ESTABLISH ROUGH GRADING AROUND PARKING FIELDS AND ACCESS DRIVES. MANAGE EXPOSED SOIL SURFACES TO AVOID TRANSPORTING SEDIMENTS INTO WETLANDS. PARKING LOTS SHALL BE STABILIZED WITHIN 72 HOURS OF ACHIEVING FINISHED GRADE. 12. INSTALL SUBSURFACE UTILITIES (WATER, SEWER, GAS, ELECTRIC, COMMUNICATIONS, DRAINAGE,
- DRAINAGE FACILITIES, ETC.).
- 13. CONSTRUCT PROPOSED ROADWAY, RAIN GARDENS, GRAVEL WETLANDS AND DRAINAGE SWALES. ALL DITCHES, SWALES, AND GRAVEL WETLANDS SHALL BE FULLY STABILIZED PRIOR TO DIRECTING FLOW TO THEM
- 14. COMPLETE BUILDING AND ALL OFF-SITE IMPROVEMENTS. 15. COMPLETE SEEDING AND MULCHING. SEED TO BE APPLIED WITH BROADCAST SPREADER OR BY
- HYDRO-SEEDING, THEN ROLLED, RAKED, OR DRAGGED TO ASSURE SEED/SOIL CONTACT. 16. REMOVE TEMPORARY EROSION CONTROL MEASURES AFTER SEEDED AREAS HAVE BECOME FIRMLY
- ESTABLISHED AND SITE IMPROVEMENTS ARE COMPLETE. 17. DURING THE COURSE OF THE WORK AND UPON COMPLETION, THE CONTRACTOR SHALL REMOVE ALL SEDIMENT DEPOSITS, EITHER ON OR OFF SITE, INCLUDING CATCH BASINS, AND SUMPS, DRAIN PIPES
- AND DITCHES, CURB LINES, ALONG SILT BARRIERS, ETC. RESULTING FROM SOIL AND/OR CONSTRUCTION OPERATIONS 18. SEE WINTER CONSTRUCTION SEQUENCE FOR WORK CONDUCTED AFTER OCTOBER 15TH.





# PROPOSED 3 LOT SUBDIVISION **437 LAFAYETTE ROAD**

PORTSMOUTH, NEW HAMPSHIRE OWNED BY & PREPARE FOR

**ARTWILL, LLC** 



**APRIL 19, 2022** 



Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects

45407-120 CK JCC CADFILE 45407-120\_SITE PREP

C-02

| 48 Constitution Drive

Bedford, NH 03110

Fax (603) 472-9747

www.tfmoran.com

Phone (603) 472-4488



# SITE DATA

OWNER OF RECORD OF MAP 229 LOT 1: HARLON P. WILLIS REVOCABLE TRUST & JEAN P. WILLIS REVOCABLE TRUST 437 LAFAYETTE ROAD, PORTSMOUTH, NH 03801

DEED REFERENCE TO PARCEL IS BK.#3537 PG.#1327

AREA OF PARCEL =  $65,365\pm$  S.F. OR  $1.5006\pm$  ACRES

SINGLE RESIDENCE B (SRB) EXISTING USE: 1 LOT, SINGLE FAMILY DWÉLLING UNIT

PROPOSED USE: 3 LOTS, 3 SINGLE FAMILY DWELLING UNITS

THE PURPOSE OF THIS PLAN IS TO DEPICT TWO PROPOSED SINGLE FAMILY DWELLING UNIT WITH ACCESS ALONG ARTWELL AVENUE. ASSOCIATED IMPROVEMENTS NOT SHOWN ON THIS PLAN INCLUDE AND ARE NOT LIMITED TO GRADING, STORMWATER MANAGEMENT SYSTEMS, UTILITIES, LIGHTING, AND LANDSCAPING.

DIMENSIONAL	REQUIREMENTS	(CURRENT	ZONING)	
		•		

AX DIVISION LOOR 22	MINIMUM LOT DIMENSIONS.	REQUIRED:	PROVIDED: <u>LOT 1</u> :	<u>LOT 2</u> :	<u>LOT 3</u> :
50 48	LOT AREA LOT FRONTAGE DEPTH	15,000 S.F. 30 FT 100 FT	18,434 S.F. 129.6 FT 105.6 FT	16,606 S.F. 102.0 FT 142.4 FT	30,325 S.F. 107.0 FT 179.7 FT
	FRONT SIDE REAR	30 FT 10 FT 30 FT	49.5 FT 30.5 FT 54.8 FT	30.3 FT 11.8 FT 64.0 FT	77.6 FT 12.6 FT 72.9 FT
:	MAXIMUM STRUCTURE DIMENSIONS: SLOPED ROOF ROOF APPURTENANCE HEIGHT BUILDING LOT COVERAGE	35 FT 8 FT 20% (MAX)	35 FT >8 FT 11.2%	27.5± FT >8 FT 14.9%	35 FT >8 FT 15.1%
	MINIMUM SETBACKS/BUFFER: BUILDING FRONT BUILDING SIDE BUILDING REAR	30 FT 10 FT 30 FT	30 FT 10 FT 30 FT	30 FT 10 FT 30 FT	30 FT 10 FT 30 FT
	MINIMUM OPEN SPACE	40%	61.4%	60.6%	66.5%
P	ARKING REQUIREMENTS				
	PARKING SPACES 1.3 SPACES/UNIT	2 SPACES*	2 SPACES	2 SPACES	3 SPACES

\*LOT 3 CONTAINS (2) UNITS AND REQUIRES 3 SPACES

- 1. SEE NOTES ON SHEET C-01.
- 2. ALL DIMENSIONS ARE TO THE FACE OF CURB UNLESS NOTED OTHERWISE.
- 3. LIGHTING, SIGNAGE, LANDSCAPING, AND SCREENING SHALL MEET THE REQUIREMENTS OF THE CITY ZONING ORDINANCE AND SITE PLAN REGULATIONS.
- 4. SNOW SHALL NOT BE STOCKPILED IN STORMWATER BMP'S, WETLAND BUFFERS, OR WETLANDS. SEE SNOW STORAGE LOCATIONS. IN THE EVENT THAT THE SNOW STORAGE AREAS PROVIDED ON THE SITE ARE COMPLETELY UTILIZED, EXCESS SNOW SHALL BE TRANSPORTED OFF SITE FOR DISPOSAL IN ACCORDANCE WITH NHDES REGULATION. IF SNOW IS STORED WITHIN PARKING AREA, KEEP CATCH
- 5. ALL CONDITIONS ON THIS PLAN SHALL REMAIN IN EFFECT IN PERPETUITY PURSUANT TO REQUIREMENTS OF THE SITE PLAN REVIEW REGULATIONS.
- 6. THIS SITE PLAN SHALL BE RECORDED IN THE ROCKINGHAM COUNTY REGISTRY OF DEEDS.
- 7. ALL IMPROVEMENTS SHOWN ON THIS SITE PLAN SHALL BE CONSTRUCTED AND MAINTAINED IN ACCORDANCE WITH THE PLAN BY THE PROPERTY OWNER AND ALL FUTURE PROPERTY OWNERS. NO CHANGES SHALL BE MADE TO THIS SITE PLAN WITHOUT THE EXPRESS APPROVAL OF THE PORTSMOUTH PLANNING DIRECTOR.

C C.	

SIGN LEGEND						
חו	) SIGN		NCHES)	DESIGN (COLORING, TEXT SIZE,	NO. OF	
	OIGIN	WIDTH	HEIGHT	SPACING, SHAPE, RETROFLECTIVITY, ETC.)	SIGNS	
R8–1	N O PARKING ON PAVEMENT	18	     24 	   REFER TO THE 2009 MANUAL   ON UNIFORM TRAFFIC   CONTROL DEVICES (MUTCD)   FOR STREETS AND HIGHWAYS 	2	

1. HANDICAP PARKING SIGNS SHALL BE IN ACCORDANCE WITH CITY OF PORTSMOUTH STANDARDS AND ADA REGULATIONS.

# SITE DEVELOPMENT PLANS

TAX MAP 229 LOT 1 SITE LAYOUT PLAN

# PROPOSED 3 LOT SUBDIVISION **437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

OWNED BY & PREPARE FOR

**ARTWILL, LLC** 



APRIL 19, 2022

C-03

Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects icientists

45407-120 DR JSM FB CK JCC CADFILE 45407-120\_SITE LAYOUT

Phone (603) 472-4488 Fax (603) 472-9747 www.tfmoran.com

| 48 Constitution Drive

Bedford, NH 03110



24	
/O TAX DIVISION ET FLOOR 22 * 84150 #0248	

SYMBOL DESCRIPTION		DESCRIPTION	HYDROLOGIC SOIL GROUP
	799*	UBRAN LAND-CANTON COMPLEX 3% – 15% SLOPES	A (BASED ON FIELD INFILTRATION RATES)
	799*	UBRAN LAND–CANTON COMPLEX 3% – 15% SLOPES	B (BASED ON FIELD INFILTRATION RATES)



SEE UTILTIY NOTES ON SHEET C-01. . CONTRACTOR SHALL COORDINATE WITH CITY OF PORTSMOUTH DPW PRIOR TO CONSTRUCTING SEWER MANHOLE CONNECTION.



TAX MAP 229 LOT 1 UTILITY PLAN

# PROPOSED 3 LOT SUBDIVISION **437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

OWNED BY & PREPARE FOR **ARTWILL, LLC** 

1"=40' (11"X17") SCALE: 1"=20' (22"X34")

**APRIL 19, 2022** 

Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists

45407-120\_UTILITY

C-05

| 48 Constitution Drive

Bedford, NH 03110

Fax (603) 472-9747

www.tfmoran.com

Phone (603) 472-4488



# LANDSCAPE LEGEND

	•			
SYMBOL	QTY	BOTANICAL NAME COMMON NAME	SIZE	REMARKS
$\bigotimes$	3	CLETHRA ALNIFOLIA 'HUMMINGBIRD' HUMMINGBIRD SUMMERSWEET	2 GAL.	CONT.
	9	FORSYTHIA 'LYNWOOD GOLD' LYNWOOD GOLD FORSYTHIA	5' TO 6'	B&B
	4	HYDRANGEA ARBORESCENS 'INCREDIBALL' INCREDIBALL SMOOTH HYDRANGEA	3 GAL.	CONT.
	5	JUNIPERUS VIRGINIANA 'GREY OWL' GREY OWL EASTERN RED CEDAR	3 GAL.	CONT.
	19	THUJA O. 'TECHNY' MISSION ARBORVITAE	5' TO 6'	B&B

LANDSCAPE NOTES

- 1. CONTRACTOR WILL LOCATE, VERIFY AND MARK ALL EXISTING AND NEWLY INSTALLED UNDERGROUND UTILITIES PRIOR TO ANY LAWNWORK OR PLANTING. ANY CONFLICTS WHICH MIGHT OCCUR BETWEEN PLANTING AND UTILITIES WILL IMMEDIATELY BE REPORTED TO THE LANDSCAPE ARCHITECT OR OWNERS' REPRESENTATIVE, SO THAT ALTERNATE PLANTING LOCATIONS CAN BE DETERMINED.
- 2. CONTRACTOR WILL FURNISH AND PLANT ALL PLANTS IN QUANTITIES AS SHOWN ON THIS PLAN. IN CASES OF DISCREPANCY BETWEEN PLAN AND LIST CLARIFY WITH LANDSCAPE ARCHITECT PRIOR TO PLACING PURCHASE ORDER AND AGAIN PRIOR TO PLANTING.
- 3. SEE PLANTING DETAILS AND IF INCLUDED, SPECIFICATIONS FOR ADDITIONAL INFORMATION.
- 4. NO SUBSTITUTION OF PLANT MATERIALS WILL BE ALLOWED WITHOUT PRIOR WRITTEN APPROVAL OF THE LANDSCAPE ARCHITECT OR OWNER'S REPRESENTATIVE.
- 5. IT IS THE CONTRACTOR'S RESPONSIBILITY TO MAKE THE APPROPRIATE ARRANGEMENTS TO PROVIDE ALL PLANTS AND MATERIALS TO ACCOMMODATE PLANTING WITHIN THE TIME ALLOWED BY THE CONSTRUCTION SCHEDULE.
- 6. PLANTING SHALL BE COMPLETED FROM APRIL 15TH THROUGH OCTOBER 15TH UNLESS OTHERWISE NOTED IN SPECIFICATIONS. THERE WILL BE NO PLANTING DURING JULY AND AUGUST UNLESS SPECIAL PROVISIONS ARE MADE FOR DROUGHT BY PROVIDING ADDITIONAL WATERING.
- 7. ALL PLANTS WILL BE NURSERY GROWN.
- 8. PLANTS WILL BE IN ACCORDANCE, AT A MINIMUM, WITH CURRENT EDITION OF "AMERICAN STANDARDS FOR NURSERY STOCK" AS PUBLISHED BY THE AMERICAN HORTICULTURE INDUSTRY ASSOCIATION.
- 9. TREES WILL BE PRUNED IN ACCORDANCE WITH THE LATEST EDITION OF ANSI A300 PART 1, "TREE, SHRUB AND OTHER WOODY PLANT MAINTENANCE STANDARD PRACTICES".
- 10. PLANTS MATERIAL IS SUBJECT TO APPROVAL / REJECTION BY THE LANDSCAPE ARCHITECT AT THE SITE AND AT THE NURSERY.
- 11. ALL PLANTS WILL BE MOVED WITH ROOT SYSTEMS AS SOLID UNITS AND WITH BALLS OF EARTH FIRMLY WRAPPED WITH BURLAP. NO PLANT WILL BE ACCEPTED WHEN BALL OF EARTH SURROUNDING ITS ROOTS HAS BEEN BADLY CRACKED OR BROKEN BEFORE PLANTING. ALL PLANTS THAT CANNOT BE PLANTED AT ONCE WILL BE HEELED-IN BY SETTING IN THE GROUND AND COVERING THE BALLS WITH SOIL AND THEN WATERING. DURING TRANSPORT, ALL PLANT MATERIALS WILL BE WRAPPED WITH WIND PROOF COVERING.
- 12. NEWLY PLANTED MATERIAL WILL BEAR THE SAME RELATIONSHIP TO FINISHED GRADE AS TO THE ORIGINAL GRADE OF THE PLANT PRIOR TO DIGGING.
- 13. PROPOSED TREES OVERHANGING SIDEWALKS, ROADS OR PARKING WILL BEGIN BRANCHING NATURALLY (NOT PRUNED) AT 6' HEIGHT.
- 14. MULCH FOR PLANTED AREAS (NOT INCLUDING RAIN GARDENS) WILL BE AGED SHREDDED PINE BARK, PARTIALLY DECOMPOSED, DARK BROWN IN COLOR AND FREE OF WOOD CHIPS UNLESS OTHERWISE SHOWN.
- 15. PLANT MATERIAL WILL BE LOCATED OUTSIDE BUILDING DRIPLINES AND ROOF VALLEY POINTS OF CONCENTRATION TO PREVENT DAMAGE TO PLANTS. CLARIFY DISCREPANCIES WITH LANDSCAPE ARCHITECT PRIOR TO INSTALLATION.
- 16. ALL DISTURBED AREAS NOT TO BE PAVED OR OTHERWISE TREATED, WILL RECEIVE SIX (6) INCH LOAM AND SEED AT THE DIRECTION OF THE LANDSCAPE ARCHITECT OR OWNER'S REPRESENTATIVE.
- 17. TREE STAKES AND WRAP WILL REMAIN IN PLACE FOR NO LESS THAN 6 MONTHS AND NO MORE THAN 1 YEAR. CONTRACTOR WILL REMOVE.
- 18. ALL PLANT GROUPINGS WILL BE IN MULCH BEDS UNLESS OTHERWISE SPECIFIED OR NOTED ON PLANS. WHERE MULCHED PLANT BED ABUTS LAWN, PROVIDE TURF CUT EDGE.
- 19. ALL PLANT BEDS WILL INTERSECT WITH PAVEMENT AT 90 DEGREES UNLESS OTHERWISE NOTED ON PLANS.
- 20. ALL PLANT BED EDGES WILL BE SMOOTH AND CONSISTENT IN LAYOUT OF RADII AND TANGENTS. IRREGULAR, WAVY EDGES WILL NOT BE ACCEPTED.

/.	SITE DEVELOPME         TAX MAP 229         LANDSCAPE P         PROPOSED 3 LOT SU         437 LAFAYETTE         PORTSMOUTH, NEW F         OWNED BY & PREP         ARTWILL, LL	INT PLANS
	1"=40' (11"X17") SCALE: 1"=20' (22"X34")	APRIL 19, 2022
	Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists	48 Constitution Drive Bedford, NH 03110 Phone (603) 472-4488 Fax (603) 472-9747 www.tfmoran.com
	F JSM FB	0.00



### SOIL CHARACTERISTICS

THE SOIL IN THE VICINITY OF THE SITE CONSIST OF URBAN LAND-CANTON COMPLEX, THE MAJORITY OF THE SOIL IS HSG TYPE A AND TYPE B.

### DISTURBED AREA

THE TOTAL AREA TO BE DISTURBED IS APPROXIMATELY 46,875 SQUARE FEET (1.076 ACRES). CONSTRUCTION SHALL BE PHASED TO LIMIT DISTURBED AREAS TO LESS THAN 5 ACRES.

CRITICAL NOTE: THIS DRAWING IS PROVIDED FOR GENERAL GUIDANCE. ALL SPECIAL EROSION CONTROL MEASURES MUST BE EXECUTED IN ACCORDANCE WITH APPLICABLE CURRENT STATE AND LOCAL REGULATIONS, APPROVED SWPPP, AND PERMIT REQUIREMENTS.

SEQUENCE OF MAJOR ACTIVITIES

- 1. INSTALL PERIMETER CONTROLS, STABILIZED CONSTRUCTION ENTRANCE, AND TEMPORARY EROSION CONTROL MEASURES PER APPROVED SITE DEVELOPMENT PLANS, PERMITS, OR SWPPP IF REQUIRED, PRIOR TO EARTH MOVING OPERATIONS.
- DEMOLISH EXISTING SITE WORK DESIGNATED FOR REMOVAL. INSTALL STORMWATER TREATMENT PONDS AND SWALES BEFORE ROUGH GRADING THE SITE.
- COMPLETE MAJOR GRADING OF SITE.
- CONSTRUCT BUILDING PAD, STORMWATER SYSTEM, AND SITE UTILITIES. CONSTRUCT PARKING LOT.
- 7. WHEN ALL CONSTRUCTION ACTIVITY IS COMPLETE AND SITE IS STABILIZED, REMOVE ALL INLET PROTECTION, SILT BARRIERS, AND SEDIMENT THAT HAS BEEN TRAPPED BY THESE DEVICES. 8. CONSULT APPLICABLE REGULATIONS, PERMITS, CONDITIONS, AND APPROVED SWPPP FOR CONDITIONS RELATED TO NOTICE OF TERMINATION, IF REQUIRED.

<u>EROSION AND SEDIMENT CONTROLS AND STABILIZATION PRACTICES</u>

STABILIZATION SHALL BE INITIATED ON ALL LOAM STOCKPILES AND DISTURBED AREAS WHERE CONSTRUCTION ACTIVITY U. WILL NOT OCCUR FOR MORE THAN TWENTY ONE (21) CALENDAR DAYS BY THE FOURTEENTH (14TH) DAY AFTER CONSTRUCTION ACTIVITY HAS PERMANENTLY OR TEMPORARILY CEASED IN THAT AREA. ALL DISTURBED AREAS SHALL BE STABILIZED WITHIN 45 DAYS OF INITIAL DISTURBANCE. AN AREA SHALL BE CONSIDERED STABLE IF ONE OF THE FOLLOWING HAS OCCURRED.

- 1. BASE COURSE GRAVELS, WHICH MEET THE REQUIREMENTS OF NHDOT STANDARD FOR ROAD AND BRIDGE CONSTRUCTION, 2016, ITEM 304.2, HAVE BEEN INSTALLED IN AREAS TO BE PAVED;
- 2. A MINIMUM OF 85% VEGETATED GROWTH HAS BEEN ESTABLISHED; 3. A MINIMUM OF 3" OF NON-EROSIVE MATERIAL SUCH AS STONE OR RIPRAP HAS BEEN INSTALLED; OR
- 4. EROSION CONTROL BLANKETS HAVE BEEN PROPERLY INSTALLED. DURING CONSTRUCTION, RUNOFF WILL BE DIVERTED AROUND THE SITE WITH EARTH DIKES, PIPING OR STABILIZED

CHANNELS WHERE POSSIBLE. SHEET RUNOFF FROM THE SITE WILL BE FILTERED THROUGH SILT BARRIERS. ALL STORM DRAIN INLETS SHALL BE PROVIDED WITH BARRIER FILTERS. STONE RIPRAP SHALL BE PROVIDED AT THE OUTLETS OF DRAINAGE PIPES WHERE EROSIVE VELOCITIES ARE ENCOUNTERED.

### OFF SITE VEHICLE TRACKING

STABILIZED CONSTRUCTION ENTRANCES SHALL BE INSTALLED.

INSTALLATION, MAINTENANCE, AND INSPECTION OF EROSION AND SEDIMENT CONTROLS

### A. <u>GENERAL</u>

- THESE ARE THE GENERAL INSPECTION AND MAINTENANCE PRACTICES THAT WILL BE USED TO IMPLEMENT THE PLAN.
- 1. STABILIZATION OF ALL SWALES, DITCHES, AND PONDS IS REQUIRED PRIOR TO DIRECTING FLOW TO THEM.
- 2. THE SMALLEST PRACTICAL PORTION OF THE SITE WILL BE DENUDED AT ONE TIME. (5 AC MAX)
- 3. ALL CONTROL MEASURES WILL BE INSPECTED IN ACCORDANCE WITH APPLICABLE REGULATIONS, PERMITS, AND CONDITIONS AND[a] FOR PROJECTS REQUIRING A NPDES EPA CGP AND DISCHARGING TO A NON-SENSITIVE WATERBODY, AT LEAST EVERY 7 DAYS OR EVERY 14 DAYS AND AFTER A 0.25 INCHES RAIN EVENT OR GREATER.
- 4. ALL MEASURES WILL BE MAINTAINED IN GOOD WORKING ORDER. IF A REPAIR IS NECESSARY, IT WILL BE INITIATED WITHIN 24 HOURS OF REPORT.
- 5. BUILT UP SEDIMENT WILL BE REMOVED FROM SILT BARRIER WHEN IT HAS REACHED ONE THIRD THE HEIGHT OF THE BARRIER.
- 6. ALL DIVERSION DIKES WILL BE INSPECTED AND ANY BREACHES PROMPTLY REPAIRED.
- 7. TEMPORARY SEEDING AND PLANTING WILL BE INSPECTED FOR BARE SPOTS, WASHOUTS, AND UNHEALTHY GROWTH.
- 8. A MAINTENANCE INSPECTION REPORT WILL BE MADE AFTER EACH INSPECTION.
- 9. IF INSPECTIONS ARE REQUIRED OR THE PROJECT IS SUBJECT TO A NPDES EPA CGP. THE CONTRACTOR'S SITE SUPERINTENDENT WILL BE RESPONSIBLE FOR INSPECTIONS, MAINTENANCE, AND REPAIR ACTIVITIES, AND FILLING OUT THE INSPECTION AND MAINTENANCE REPORT.

### FILTERS / BARRIERS

1.	SIL	T SOCKS				THE WEED ( LAWS. FOR OF DISTURB
	Α.	KNOTTED MESH NETTING I 3/8" MATERIAL, FILLED W	MATERIAL SHALL BE /ITH COMPOST CONF(	DELIVERED TO SITE IN A 5 MIL CONTINUOUS, TUBULAR, HDPE DRMING TO THE FOLLOWING REQUIREMENTS:		A. FOLLOW B. FERTILIZ
		<u>PHYSICAL_PROPERTY</u> PH	<u>TEST</u> TMECC 04.11-A	<u>REQUIREMENTS</u> 5.0 TO 8.0		<u>MULCHING A</u> WINTER RYE
		PARTICLE SIZE	TMECC 02.02-B	2" SIEVE AND MIN. 60% GREATER THAN THE 🗿 SIEVE		OATS (SPRI MULCH
		MOISTURE CONTENT		STND TESTING < 60%	Ε.	CATCH BASIN
		MATERIAL SHALL BE REL	ATIVELY FREE OF IN	IERT OR FOREIGN MAN-MADE MATERIALS		1. INLET BASK
		MATERIAL SHALL BE WEI FREE FROM ANY REFUSE	ED FREE AND DERIVI E, CONTAMINANTS OF	ED FROM A WELL-DECOMPOSED SOURCE OF ORGANIC MATTER, R OTHER MATERIALS TOXIC TO PLANT GROWTH.		A. INLET P PLACE /
	В.	SEDIMENT COLLECTED AT THE EXPOSED HEIGHT OF	THE BASE OF THE THE SILT SOCK.	SILT SOCK SHALL BE REMOVED ONCE IT HAS REACHED 1/3 OF		B. MOLD 6 FILTER F
	C.	SILT BARRIER SHALL BE I UPSLOPE AREAS HAS BEE	REMOVED WHEN THE EN PERMANENTLY SI	Y HAVE SERVED THEIR USEFUL PURPOSE, BUT NOT BEFORE THE ABILIZED.		C. THE FIL POLYETH
2.	SE	QUENCE OF INSTALLATION				GR
	SEI AR	DIMENT BARRIERS SHALL B EA ABOVE THEM.	E INSTALLED PRIOR	TO ANY SOIL DISTURBANCE OF THE CONTRIBUTING DRAINAGE		D. THE FAE
3.	ΜA	INTENANCE				
	Α.	SILT BARRIERS SHALL BE DURING PROLONGED RAINI SEDIMENTATION BELOW T	INSPECTED WEEKLY FALL. THEY SHALL E	AND IMMEDIATELY AFTER EACH RAINFALL AND AT LEAST DAILY BE REPAIRED IF THERE ARE ANY SIGNS OF EROSION OR REPAIRS SHALL BE MADE IMMEDIATELY IF THERE ARE SIGNS OF		E. THE INL EXTENDE PARTICL
		UNDERCUTTING AT THE CI THEM, SEDIMENT BARRIER	ENTER OR THE EDGE S SHALL BE REPLAC	TS, OR IMPOUNDING OF LARGE VOLUMES OF WATER BEHIND ED WITH A TEMPORARY CHECK DAM.		F. SEDIMEN BECOME
	Β.	SHOULD THE FABRIC DEC LIFE AND THE BARRIER S	OMPOSE OR BECOME TILL IS NECESSARY,	INEFFECTIVE PRIOR TO THE END OF THE EXPECTED USABLE THE FABRIC SHALL BE REPLACED PROMPTLY.	F.	WINTER CONS
	C.	SEDIMENT DEPOSITS SHOU DEPOSITS REACH APPROX	JLD BE REMOVED AF (IMATELY ONE THIRD	TER EACH STORM EVENT. THEY MUST BE REMOVED WHEN $(1/3)$ THE HEIGHT OF THE BARRIER.		1. ALL PROPOS GROWTH BY AND INSTAL
	D.	ANY SEDIMENT DEPOSITS DRESSED TO CONFIRM WI	REMAINING IN PLACE TH THE EXISTING GR	E AFTER THE SILT BARRIER IS NO LONGER REQUIRED SHALL BE ADE, PREPARED AND SEEDED.		4 TONS OF CONTROL BI GROUND AN
 ght nstit	2022 ution	2 ©TFMoran, Inc. Drive, Bedford, N.H. 03110		DIG SAFE		

All rights reserved. These plans and materials may not be copied, duplicated, replicated or otherwise reproduced in any form whatsoeve without the prior written permission of TFMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of CONTACT DIG SAFE 72 BUSINES

- C. <u>MULCHING</u>
- 1. TIMING
  - TWO (2) TYPES OF STANDARDS WHICH SHALL BE USED TO ASSURE THIS:

A. APPLY MULCH PRIOR TO ANY STORM EVENT. THIS IS APPLICABLE WHEN WORKING WITHIN 100' OF WETLANDS. IT WILL BE NECESSARY TO CLOSELY MONITOR WEATHER PREDICTIONS, USUALLY BY CONTACTING THE NATIONAL WEATHER SERVICE, TO HAVE ADEQUATE WARNING OF SIGNIFICANT STORMS.

B. REQUIRED MULCHING WITHIN A SPECIFIED TIME PERIOD. AS INDICATED IN THE SEQUENCE OF MAJOR ACTIVITIES, SILT BARRIERS SHALL BE INSTALLED PRIOR TO COMMENCING ANY CLEARING OR GRADING OF THE SITE. STRUCTURAL CONTROLS SHALL BE INSTALLED CONCURRENTLY WITH THE APPLICABLE THE TIME PERIOD CAN RANGE FROM 14 TO 21 DAYS OF INACTIVITY ON AN AREA, WHERE THE LENGTH OF TIME ACTIVITY. AREAS WHERE CONSTRUCTION ACTIVITY TEMPORARILY CEASES FOR MORE THAN TWENTY ONE (21) DAYS WILL BE VARIES WITH SITE CONDITIONS. PROFESSIONAL JUDGMENT SHALL BE USED TO EVALUATE THE INTERACTION OF STABILIZED WITH A TEMPORARY SEED AND MULCH WITHIN FOURTEEN (14) DAYS OF THE LAST DISTURBANCE. ONCE SITE CONDITIONS (SOIL ERODIBILITY, SEASON OF YEAR, EXTENT OF DISTURBANCE, PROXIMITY TO SENSITIVE CONSTRUCTION ACTIVITY CEASES PERMANENTLY IN AN AREA, SILT BARRIERS AND ANY EARTH/DIKES WILL BE REMOVED RESOURCES, ETC.) AND THE POTENTIAL IMPACT OF EROSION ON ADJACENT AREAS TO CHOOSE AN APPROPRIATE ONCE PERMANENT MEASURES ARE ESTABLISHED. TIME RESTRICTION.

- 2. GUIDELINES FOR WINTER MULCH APPLICATION.
- 3. MAINTENANCE

IMMEDIATELY APPLIED.

- VEGETATIVE PRACTICE
- SITE SUBCONTRACTOR.
- OFF SITE. THE LOAM SHALL BE RAKED SMOOTH AND EVEN.

- PAVEMENT, OR MULCH SHALL BE LOAMED AND SEEDED.

- TECHNIQUES FROM THE EROSION AND SEDIMENT CONTROL HANDBOOK.
- GRASS SHALL BE RESEEDED, AND ALL NOXIOUS WEEDS REMOVED.
- CUTTING, AS SPECIFIED HEREIN AFTER UNDER MAINTENANCE AND PROTECTION.
- BED AREAS:

ABOVE SLOPE, LOAM DEPTH AND GRADING REQUIREMENTS. ZER SHALL BE SPREAD AND WORKED INTO THE SURFACE AT A RATE OF 500 POUNDS PER ACRE.

(FALL SEEDING) ING SEEDING)

- I INLET PROTECTION KET STRUCTURE

  - FABRIC TO WIRE SUPPORT
    - JLLEN BURST STRENGTH: MIN. 60PSI (ASTM D774)
  - PERMEABILITY OF 120 GPM.

  - ES CLOGGED.
- TRUCTION SEQUENCE

Copyright 20

48 Constitut

FMoran, Inc.

IN ORDER FOR MULCH TO BE EFFECTIVE, IT MUST BE IN PLACE PRIOR TO MAJOR STORM EVENTS. THERE ARE

WHEN MULCH IS APPLIED TO PROVIDE PROTECTION OVER WINTER (PAST THE GROWING SEASON) IT SHALL BE AT A RATE OF 6,000 POUNDS OF HAY OR STRAW PER ACRE. A TACKIFIER MAY BE ADDED TO THE MULCH.

ALL MULCHES MUST BE INSPECTED PERIODICALLY, IN PARTICULAR AFTER RAINSTORMS, TO CHECK FOR RILL EROSION. IF LESS THAN 90% OF THE SOIL SURFACE IS COVERED BY MULCH, ADDITIONAL MULCH SHALL BE

1. AFTER ROUGH GRADING OF THE SUBGRADE HAS BEEN COMPLETED AND APPROVED, THE SUB GRADE SURFACE SHALL BE SCARIFIED TO A DEPTH OF 4". THEN, FURNISH AND INSTALL A LAYER OF LOAM PROVIDING A ROLLED THICKNESS AS SPECIFIED IN THESE PLANS. ANY DEPRESSIONS WHICH MAY OCCUR DURING ROLLING SHALL BE FILLED WITH ADDITIONAL LOAM, REGRADED AND REROLLED UNTIL THE SURFACE IS TRUE TO THE FINISHED LINES 3. SANITARY WASTE AND GRADES. ALL LOAM NECESSARY TO COMPLETE THE WORK UNDER THIS SECTION SHALL BE SUPPLIED BY THE

2. ALL LARGE STIFF CLODS, LUMPS, BRUSH, ROOTS, DEBRIS, GLASS, STUMPS, LITTER, AND OTHER FOREIGN MATERIAL, AS WELL AS STONES OVER 1" IN DIAMETER, SHALL BE REMOVED FROM THE LOAM AND DISPOSED OF SPILL PREVENTION

3. THE LOAM SHALL BE PREPARED TO RECEIVE SEED BY REMOVING STONES, FOREIGN OBJECTS AND GRADING TO ELIMINATE WATER POCKETS AND IRREGULARITIES PRIOR TO PLACING SEED. FINISH GRADING SHALL RESULT IN STRAIGHT UNIFORM GRADES AND SMOOTH, EVEN SURFACES WITHOUT IRREGULARITIES TO LOW POINTS.

4. SHAPE THE AREAS TO THE LINES AND GRADES REQUIRED. THE SITE SUBCONTRACTOR'S ATTENTION IS DIRECTED TO THE SCHEDULING OF LOAMING AND SEEDING OF GRADED AREAS TO PERMIT SUFFICIENT TIME FOR THE STABILIZATION OF THESE AREAS. IT SHALL BE THE SITE SUBCONTRACTOR'S RESPONSIBILITY TO MAINTAIN THE AREAS DURING THE CONSTRUCTION PERIOD AND REGRADE, LOAM AND RESEED ANY DAMAGED AREAS.

5. ALL AREAS DISTURBED BY CONSTRUCTION WITHIN THE PROPERTY LINES AND NOT COVERED BY STRUCTURES,

6. LIMESTONE SHALL BE THOROUGHLY INCORPORATED INTO THE LOAM LAYER AT A RATE OF 2 TONS PER ACRE IN ORDER TO PROVIDE A PH VALUE OF 5.5 TO 6.5.

7. FERTILIZER SHALL BE SPREAD ON THE TOP LAYER OF LOAM AND WORKED INTO THE SURFACE. FERTILIZER APPLICATION RATE SHALL BE 500 POUNDS PER ACRE OF 10-20-20 FERTILIZER.

8. SOIL CONDITIONERS AND FERTILIZER SHALL BE APPLIED AT THE RECOMMENDED RATES AND SHALL BE THOROUGHLY WORKED INTO THE LOAM. LOAM SHALL BE RAKED UNTIL THE SURFACE IS FINELY PULVERIZED SMOOTH AND EVEN, AND THEN COMPACTED TO AN EVEN SURFACE CONFORMING TO THE REQUIRED LINES AND GRADES WITH APPROVED ROLLERS WEIGHING BETWEEN 4 1/2 POUNDS AND 5 1/2 POUNDS PER INCH OF WIDTH.

9. SEED SHALL BE SOWN AT THE RATE SHOWN BELOW. SOWING SHALL BE DONE ON A CALM, DRY DAY, PREFERABLY BY MACHINE, BUT IF BY HAND, ONLY BY EXPERIENCED WORKMEN. IMMEDIATELY BEFORE SEEDING THE SOIL SHALL BE LIGHTLY RAKED. ONE HALF THE SEED SHALL BE SOWN IN ONE DIRECTION AND THE OTHER HALF AT RIGHT ANGLES TO THE ORIGINAL DIRECTION. IT SHALL BE LIGHTLY RAKED INTO THE SOIL TO A DEPTH NOT OVER 1/4" AND ROLLED WITH A HAND ROLLER WEIGHING NOT OVER 100 POUNDS PER LINEAR FOOT OF

10. HAY MULCH SHALL BE APPLIED IMMEDIATELY AFTER SEEDING AT A RATE OF 1.5 TO 2 TONS PER ACRE. MULCH THAT BLOWS OR WASHES AWAY SHALL BE REPLACED IMMEDIATELY AND ANCHORED USING APPROPRIATE

11. THE SURFACE SHALL BE WATERED AND KEPT MOIST WITH A FINE SPRAY AS REQUIRED, WITHOUT WASHING AWAY THE SOIL, UNTIL THE GRASS IS WELL ESTABLISHED. ANY AREAS WHICH ARE NOT SATISFACTORILY COVERED WITH

12. THE SITE SUBCONTRACTOR SHALL PROTECT AND MAINTAIN THE SEEDED AREAS UNTIL ACCEPTED, INCLUDING

13. UNLESS OTHERWISE APPROVED, SEEDING SHALL BE DONE DURING THE APPROXIMATE PERIODS OF EARLY SPRING TO SEPTEMBER 30, WHEN SOIL CONDITIONS AND WEATHER ARE SUITABLE FOR SUCH WORK. IN NO CASE SHALL CONTENT EXCEED 1 PERCENT BY WEIGHT. ALL SEED SHALL COMPLY WITH STATE AND FEDERAL SEED TEMPORARY PLANTINGS AFTER SEPTEMBER 30, TO EARLY SPRING AND FOR TEMPORARY PROTECTION

> AND SEEDING SHALL BE APPLIED AT THE FOLLOWING RATES: 2.5 LBS/1,000 SF 2.0 LBS/1,000 SF

> > 1.5 TONS/ACRE

PROTECTION SHALL BE INSTALLED IMMEDIATELY PRIOR TO DISTURBING PAVEMENT AND SHALL REMAIN IN AND MAINTAINED UNTIL PAVEMENT BINDER COURSE IS COMPLETE.

3X6, 42 LB. WIRE SUPPORT AROUND INLET FRAME AND GRATE AND EXTEND 6" BEYOND SIDES. SECURE

TER FABRIC SHALL BE A GEOTEXTILE FABRIC; POLYESTER, POLYPROPYLENE, STABILIZED NYLON, HYLENE OR POLYVINYLIDENE CHLORIDE MEETING THE FOLLOWING SPECIFICATIONS:

RAB STRENGTH: 45 LB. MINIMUM IN ANY PRINCIPAL DIRECTION (ASTM D1682)

BRIC SHALL HAVE AN OPENING NO GREATER THAN A NUMBER 20 U.S. STANDARD SIEVE AND A

LET PROTECTION SHALL BE INSPECTED WITHIN 24 HOURS AFTER EACH RAINFALL OR DAILY DURING ED PERIODS OF PRECIPITATION. REPAIRS SHALL BE MADE IMMEDIATELY, AS NECESSARY, TO PREVENT LES FROM REACHING THE DRAINAGE SYSTEM AND/OR CAUSING SURFACE FLOODING.

NT DEPOSITS SHALL BE REMOVED AFTER EACH STORM EVENT, OR MORE OFTEN IF THE FABRIC

SED POST-DEVELOPMENT LANDSCAPED AREAS WHICH DO NOT EXHIBIT A MINIMUM OF 85% VEGETATIVE OCTOBER 15TH, OR WHICH ARE DISTURBED AFTER OCTOBER 15TH, SHALL BE STABILIZED BY SEEDING LLING EROSION CONTROL BLANKETS ON SLOPES GREATER THAN 3:1 AND SEEDING AND PLACING 3 TO MULCH PER ACRE, SECURED WITH ANCHORED NETTING, ELSEWHERE. THE PLACEMENT OF EROSION BLANKETS OR MULCH AND NETTING SHALL NOT OCCUR OVER ACCUMULATED SNOW OR ON FROZEN ND SHALL BE COMPLETED IN ADVANCE OF THAW OR SPRING MELT EVENT.

- 2. ALL DITCHES OR SWALES WHICH DO NOT EXHIBIT A MINIMUM OF 85% VEGETATIVE GROWTH BY OCTOBER 15TH, OR WHICH ARE DISTURBED AFTER OCTOBER 15TH, SHALL BE STABILIZED WITH STONE OR EROSION CONTROL BLANKETS APPROPRIATE FOR THE DESIGN FLOW CONDITIONS.
- 3. AFTER OCTOBER 15TH, INCOMPLETE PARKING AREAS WHERE ACTIVE CONSTRUCTION HAS STOPPED FOR THE WINTER ALL TRAVEL SURFACES SHALL BE PROTECTED WITH A MINIMUM OF 3" OF CRUSHED GRAVEL PER NHDOT ITEM 304.3, OR IF CONSTRUCTION IS TO CONTINUE THROUGH THE WINTER SEASON BE CLEARED OF ANY ACCUMULATED SNOWFALL AFTER EACH STORM EVENT.

TIMING OF CONTROLS/MEASURES

FOR SINGLE/DUPLEX FAMILY SUBDIVISIONS, WHEN LOT DEVELOPMENT IS NOT PART OF THE PERMIT, THEN LOT DISTURBANCE, OTHER THAN THAT SHOWN ON THE APPROVED PLANS, SHALL NOT COMMENCE UNTIL AFTER THE ROADWAY HAS THE BASE COURSE TO DESIGN ELEVATION AND THE ASSOCIATED DRAINAGE IS COMPLETE AND STABLE.

WASTE DISPOSAL

- 1. WASTE MATERIALS ALL WASTE MATERIALS WILL BE COLLECTED AND STORED IN SECURELY LIDDED RECEPTACLES. ALL TRASH AND ALL WASTE MATERIALS WILL BE COLLECTED AND STOKED IN SCONLET LIDDED RECEIPTOLES. ALL AND STOKED RECEIPTOLES. AND STOKED RECEIPTOLES. AND STOKED RECEIPTOLES. ALL AND STOKED RECEIPTOLES. AND STOKED RECEIPTOLES. ALL AND STOKED RECEIPTOLES. ALL AND STOKED RECEIPTOLES. ALL AND STOKED RECEIPTOLES. ALL AND STOKED RECEIPTOLES. AND STOKED REC BE BURIED ON SITE. ALL PERSONNEL WILL BE INSTRUCTED REGARDING THE CORRECT PROCEDURE FOR WASTE DISPOSAL BY THE SUPERINTENDENT.
- THE CONTRACTOR SHALL BE RESPONSIBLE TO CONTROL DUST THROUGHOUT THE CONSTRUCTION PERIOD. DUST CONTROL METHODS SHALL INCLUDE, BUT NOT LIMITED TO SPRINKLING WATER ON EXPOSED AREAS, COVERING LOADED DUMP 2. HAZARDOUS WASTE TRUCKS LEAVING THE SITE, AND TEMPORARY MULCHING. DUST CONTROL MEASURES SHALL BE UTILIZED SO AS TO ALL HAZARDOUS WASTE MATERIALS WILL BE DISPOSED OF IN THE MANNER SPECIFIED BY LOCAL OR STATE REGULATION PREVENT THE MIGRATION OF DUST FROM THE SITE TO ABUTTING AREAS. OR BY THE MANUFACTURER. SITE PERSONNEL WILL BE INSTRUCTED IN THESE PRACTICES BY THE SUPERINTENDENT.
- ALL SANITARY WASTE WILL BE COLLECTED FROM THE PORTABLE UNITS A MINIMUM OF ONCE PER WEEK BY A LICENSED SANITARY WASTE MANAGEMENT CONTRACTOR.

MATERIAL MANAGEMENT PRACTICES THE FOLLOWING ARE THE MATERIAL MANAGEMENT PRACTICES THAT WILL BE USED TO REDUCE THE RISK OF SPILLS OR OTHER ACCIDENTAL EXPOSURE OF MATERIALS AND SUBSTANCES DURING CONSTRUCTION TO STORMWATER RUNOFF:

GOOD HOUSEKEEPING THE FOLLOWING GOOD HOUSEKEEPING PRACTICES WILL BE FOLLOWED ON SITE DURING THE CONSTRUCTION PROJECT

- A. AN EFFORT WILL BE MADE TO STORE ONLY SUFFICIENT AMOUNTS OF PRODUCTS TO DO THE JOB.
- B. ALL MATERIALS STORED ON SITE WILL BE STORED IN A NEAT, ORDERLY MANNER IN THEIR PROPER (ORIGINAL IF POSSIBLE) CONTAINERS AND, IF POSSIBLE, UNDER A ROOF OR OTHER ENCLOSURE.
- C. MANUFACTURER'S RECOMMENDATIONS FOR PROPER USE AND DISPOSAL WILL BE FOLLOWED.
- D. THE SITE SUPERINTENDENT WILL INSPECT DAILY TO ENSURE PROPER USE AND DISPOSAL OF MATERIALS.
- E. SUBSTANCES WILL NOT BE MIXED WITH ONE ANOTHER UNLESS RECOMMENDED BY THE MANUFACTURER.
- F. WHENEVER POSSIBLE ALL OF A PRODUCT WILL BE USED UP BEFORE DISPOSING OF THE CONTAINER.

HAZARDOUS PRODUCTS: THE FOLLOWING PRACTICES WILL BE USED TO REDUCE THE RISKS ASSOCIATED WITH HAZARDOUS MATERIALS:

- A. PRODUCTS WILL BE KEPT IN THEIR ORIGINAL CONTAINERS UNLESS THEY ARE NOT RESEALABLE
- B. ORIGINAL LABELS AND MATERIAL SAFETY DATA WILL BE RETAINED FOR IMPORTANT PRODUCT
- C. SURPLUS PRODUCT THAT MUST BE DISPOSED OF WILL BE DISCARDED ACCORDING TO THE MANUFACTURER'S RECOMMENDED METHODS OF DISPOSAL.

PRODUCT SPECIFICATION PRACTICES THE FOLLOWING PRODUCT SPECIFIC PRACTICES WILL BE FOLLOWED ON SITE:

PETROLEUM PRODUCTS:

INFORMATION.

ALL ON SITE VEHICLES WILL BE MONITORED FOR LEAKS AND RECEIVE REGULAR PREVENTIVE MAINTENANCE TO REDUCE LEAKAGE. PETROLEUM PRODUCTS WILL BE STORED IN TIGHTLY SEALED CONTAINERS WHICH ARE CLEARLY LABELED. ANY ASPHALT BASED SUBSTANCES USED ON SITE WILL BE APPLIED ACCORDING TO THE MANUFACTURER'S RECOMMENDATIONS.

FERTILIZERS USED WILL BE APPLIED ONLY IN THE MINIMUM AMOUNTS DIRECTED BY THE SPECIFICATIONS. ONCE APPLIED FERTILIZER WILL BE WORKED INTO THE SOIL TO LIMIT EXPOSURE TO STORMWATER. STORAGE WILL BE IN A COVERED SHED OR ENCLOSED TRAILERS. THE CONTENTS OF ANY PARTIALLY USED BAGS OF FERTILIZER WILL BE TRANSFERRED TO A SEALABLE PLASTIC BIN TO AVOID SPILLS.

PAINTS: ALL CONTAINERS WILL BE TIGHTLY SEALED AND STORED WHEN NOT REQUIRED FOR USE. EXCESS PAINT WILL NOT BE DISCHARGED TO THE STORM SEWER SYSTEM BUT WILL BE DISPOSED OF PROPERLY ACCORDING TO MANUFACTURER'S INSTRUCTIONS OR STATE AND LOCAL REGULATIONS.

CONCRETE TRUCKS: CONCRETE TRUCKS WILL DISCHARGE AND WASH OUT SURPLUS CONCRETE OR DRUM WASH WATER IN A CONTAINED AREA DESIGNATED ON SITE.

REV	DA TE	DESCRIPTION

SPILL CONTROL PRACTICES

IN ADDITION TO GOOD HOUSEKEEPING AND MATERIAL MANAGEMENT PRACTICES DISCUSSED IN THE PREVIOUS SECTION THE FOLLOWING PRACTICES WILL BE FOLLOWED FOR SPILL PREVENTION AND CLEANUP:

- A. MANUFACTURER'S RECOMMENDED METHODS FOR SPILL CLEANUP WILL BE CLEARLY POSTED AND SITE PERSONNEL WILL BE MADE AWARE OF THE PROCEDURES AND THE LOCATION OF THE INFORMATION AND CLEANUP SUPPLIES.
- B. MATERIALS AND EQUIPMENT NECESSARY FOR SPILL CLEANUP WILL BE KEPT IN THE MATERIAL STORAGE AREA ON SITE. EQUIPMENT AND MATERIALS WILL INCLUDE BUT NOT BE LIMITED TO BROOMS, DUSTPANS, MOPS, RAGS, GLOVES, GOGGLES, KITTY LITTER, SAND, SAWDUST, AND PLASTIC OR METAL TRASH CONTAINERS SPECIFICALLY FOR THIS PURPOSE.
- C. ALL SPILLS WILL BE CLEANED UP IMMEDIATELY AFTER DISCOVERY.
- D. THE SPILL AREA WILL BE KEPT WELL VENTILATED AND PERSONNEL WILL WEAR APPROPRIATE PROTECTIVE CLOTHING TO PREVENT INJURY FROM CONTACT WITH A HAZARDOUS SUBSTANCE.
- E. SPILLS OF TOXIC OR HAZARDOUS MATERIAL WILL BE REPORTED TO THE APPROPRIATE STATE OR LOCAL GOVERNMENT AGENCY, REGARDLESS OF THE SIZE.
- F. THE SPILL PREVENTION PLAN WILL BE ADJUSTED TO INCLUDE MEASURES TO PREVENT THIS TYPE OF SPILL FROM RECURRING AND HOW TO CLEANUP THE SPILL IF IT RECURS. A DESCRIPTION OF THE SPILL, ITS CAUSE, AND THE CLEANUP MEASURES WILL BE INCLUDED.
- G. THE SITE SUPERINTENDENT RESPONSIBLE FOR DAY-TO-DAY SITE OPERATIONS WILL BE THE SPILL PREVENTION AND CLEANUP COORDINATOR.







# TAX MAP 229 LOT 1 TRUCK TURNING PLAN PROPOSED 3 LOT SUBDIVISION **437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

OWNED BY & PREPARE FOR **ARTWILL, LLC** 



**APRIL 19, 2022** 

Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists

C-09

| 48 Constitution Drive

Bedford, NH 03110

Phone (603) 472-4488

Fax (603) 472-9747

www.tfmoran.com



### NOTES

- 1. FILTER CLOTH WILL BE PLACED OVER THE ENTIRE AREA PRIOR TO PLACING OF STONE SURFACE.
- 2. WATER ALL SURFACE WATER FLOWING OR DIVERTED TOWARD CONSTRUCTION ENTRANCES SHALL BE PIPED ACROSS THE ENTRANCE. IF PIPING IS IMPRACTICAL, A MOUNTABLE BERM WITH 5:1 SLOPES WILL BE PERMITTED.
- 3. MAINTENANCE THE ENTRANCE SHALL BE MAINTAINED IN A CONDITION WHICH WILL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHTS-OF-WAY. THIS MAY REQUIRE PERIODIC TOP DRESSING WITH ADDITIONAL STONE AS CONDITIONS DEMAND AND REPAIR AND/OR CLEANOUT OF ANY MEASURES USED TO TRAP SEDIMENT. ALL SEDIMENT SPILLED, DROPPED, WASHED OR TRACKED ONTO PUBLIC RIGHTS-OF-WAY MUST BE REMOVED IMMEDIATELY.
- 4. WASHING WHEELS SHALL BE CLEANED TO REMOVE SEDIMENT PRIOR TO ENTRANCE ONTO PUBLIC RIGHTS-OF-WAY. WHEN WASHING IS REQUIRED, IT SHALL BE DONE ON AN AREA STABILIZED WITH STONE AND WHICH DRAINS INTO AN APPROVED SEDIMENT TRAPPING DEVICE.

STABILIZED CONSTRUCTION

**ENTRANCE** 

NOT TO SCALE

5. PERIODIC INSPECTION AND NEEDED MAINTENANCE SHALL BE PROVIDED AFTER EACH RAIN STORM EVENT.







### <u>NOTES</u>

- 1. POUR THRUST BLOCKS AGAINST UNDISTURBED MATERIAL WHERE TRENCH WALL HAS BEEN DISTURBED. EXCAVATE LOOSE MATERIAL AND EXTEND THRUST BLOCK TO UNDISTURBED MATERIAL. NO PIPE JOINTS SHALL BE COVERED WITH CONCRETE.
- 2. ON BENDS AND TEES, EXTEND THRUST BLOCKS FULL LENGTH OF FITTING.
- 3. PLACE BOARD IN FRONT OF ALL PLUGS BEFORE POURING THRUST BLOCKS.
- 4. WHERE MECHANICAL JOINT PIPE IS USED, MECHANICAL JOINT PLUG WITH RETAINER GLAND MAY BE SUBSTITUTED FOR END BLOCKINGS.
- 5. INSTALLATION AND STANDARD DIMENSIONAL REQUIREMENTS SHALL BE IN ACCORDANCE WITH THE CITY/TOWN ESTABLISHED RULES AND PROCEDURES.

BLO	CKING BEAF	RING ON	I UNDIS	TURBED	) MATER	RIAL
RI	EACTION		F	PIPE SIZ	Έ	
	TYPE	4"	6"	8"	10"	12"
A B C D E	90° 180° 45° 22-1/2° 11-1/4°	0.89 0.65 0.48 0.25 0.13	2.19 1.55 1.19 0.60 0.30	3.82 2.78 2.12 1.06 0.54	11.14 8.38 6.02 3.08 1.54	17.24 12.00 9.32 4.74 2.38
	A BLO RI A B C D E	SQUARE FEET           BLOCKING BEAF           REACTION           TYPE           A 90°           B 180°           C 45°           D 22-1/2°           E 11-1/4°	SQUARE FEET OF CON           BLOCKING BEARING ON           TYPE           4"           A 90°           B 180°           C 45°           D 22-1/2°           E 11-1/4°           O.13	SQUARE FEET OF CONCRETE           BLOCKING BEARING ON UNDIS           REACTION         F           TYPE         4"         6"           A 90°         0.89         2.19           B 180°         0.65         1.55           C 45°         0.48         1.19           D 22-1/2°         0.25         0.60           E 11-1/4°         0.13         0.30	SQUARE FEET OF CONCRETE THROS           BLOCKING BEARING ON UNDISTURBED           REACTION TYPE         PIPE SIZ           A 90°         0.89         2.19         3.82           B 180°         0.65         1.55         2.78           C 45°         0.48         1.19         2.12           D 22-1/2°         0.25         0.60         1.06           E 11-1/4°         0.13         0.30         0.54	SQUARE FEET OF CONCRETE THROST           BLOCKING BEARING ON UNDISTURBED MATER           REACTION TYPE         PIPE SIZE           4"         6"         8"         10"           A 90°         0.89         2.19         3.82         11.14           B 180°         0.65         1.55         2.78         8.38           C 45°         0.48         1.19         2.12         6.02           D 22-1/2°         0.25         0.60         1.06         3.08           E 11-1/4°         0.13         0.30         0.54         1.54

COULDE FEFT OF CONODETE TUDUCT



# **THRUST BLOCKS** NOT TO SCALE

Copyright 2022 ©TFMoran, Inc. 48 Constitution Drive, Bedford, N.H. 03110

All rights reserved. These plans and materials may not be copied, duplicated, replicated or otherwise reproduced in any form whatsoever without the prior written permission of TFMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of FMoran, Inc. CONTACT DIG SAFE 72 BUSINESS HOURS PRIOR TO CONSTRUCTION





All rights reserved. These plans and materials may not be copied, duplicated, replicated or otherwise reproduced in any form whatsoever without the prior written permission of TFMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of FMoran, Inc.



- HAUNCH OF THE PIPE AND SAND BEDDING 6" ABOVE THE CROWN. IF THE TOP OF THE PIPE IS LESS THAN 30" FROM FINISH GRADE, BED PIPE COMPLETELY IN STONE UP TO 6" ABOVE PIPE CROWN. UNDERDRAIN TO HAVE 4"
- TAMPERS, VIBRATORY COMPACTORS OR OTHER APPROVED MEANS. BACKFILL BENEATH PAVED SURFACES SHALL BE
- SHALL EXCLUDE DEBRIS: PIECES OF PAVEMENT: ORGANIC MATTER: TOP SOIL: ALL WET OR SOFT MUCK, PEAT, OR

- GEOTEXTILE FABRIC, AND RIP RAP SHALL BE THE PLANS.
- RAP SHALL CONFORM TO THE SPECIFIED GRADATION.
- THE ROCK RIP RAP. DAMAGED AREAS IN THE FABRIC SHALL BE REPAIRED BY PLACING A PIECE OF FABRIC OVER THE DAMAGED AREA OR BY COMPLETE REPLACEMENT OF THE FABRIC. ALL PIECES OF FABRIC SHALL BE A MINIMUM OF 12".
- 4. STONE FOR THE RIP RAP MAY BE PLACED BY THE STONE SIZES.



![](_page_231_Figure_23.jpeg)

PAINT: CASTINGS ARE FURNISHED WITH A BLACK PAINT

![](_page_231_Figure_28.jpeg)

![](_page_231_Figure_29.jpeg)

![](_page_232_Figure_0.jpeg)

# PRESSURE SEWER **TESTING NOTES**

- 1. PIPE AND JOINT MATERIALS: MATERIAL
  - BACKFILL REQUIREMENTS.

  - AGAINST CORROSION, SUCH AS WITH CATHODIC PROTECTION.
- HEAD OR AT LEAST 100 PSI.
- 3. DAMAGED PIPE SHALL BE REJECTED AND REMOVED FROM THE JOB SITE.
- SEWER WYE OR AT THE FOUNDATION WALL, APPROPRIATE MANUFACTURED ADAPTERS SHALL BE USED.
- THOROUGHLY TAMPED BY HAND OR WITH APPROPRIATE MECHANICAL DEVICES.
- THE TRENCH.
- SHALL NOT BE PERMITTED.
- A VAULT TO FACILITATE MAINTENANCE.
- 10. WATER SERVICE SHALL NOT BE LAID IN SAME TRENCH AS SEWER SERVICE.
- PLACING BEDDING MATERIAL AND SETTING OF THE BASE OR POURING CONCRETE.

![](_page_232_Figure_16.jpeg)

WHERE ORDERED BY THE ENGINEER TO STABILIZE THE TRENCH BASE, SCREENED GRAVEL OR CRUSHED STONE 1/2 INCH TO 1 1/2 INCH SHALL BE USED. 12. LOCATION: THE LOCATION OF THE TEE OR WYE SHALL BE RECORDED AND FILED IN THE MUNICIPAL RECORDS. 13. INTERNAL STEPS IN MANHOLES ARE PROHIBITED PER PORTSMOUTH DPW STANDARDS.

![](_page_232_Figure_18.jpeg)

11. BEDDING: SCREENED GRAVEL AND/OR CRUSHED STONE FREE FROM CLAY, LOAM, ORGANIC MATERIAL AND MEETING ASTM C33/C33M STONE SIZE 67 AND FREE FROM CLAY, LOAM AND ORGANNIC MATTER. THE EXCAVATION SHALL BE PROPERLY DEWATERED WHILE

9. PRESSURE SEWERAGE SHALL HAVE AN ISOLATION VALVE OR CURB STOP VALVE INSTALLED AT THE PROPERTY LINE / LIMITED COMMON AREA. IF A CHECK VALVE IS USED AT THE PROPERTY LINE, THE VALVE SHALL BE INSTALLED WITHIN

7. THE CENTERLINE OF ALL BUILDING CONNECTIONS SHALL ENTER THE TOP HALF OF THE SEWER. 8. ILLEGAL CONNECTIONS: NOTHING BUT SANITARY WASTE FLOW FROM TOILETS, SINKS, LAUNDRY ETC. SHALL BE PERMITTED. ROOF LEADERS, FOOTING DRAINS, SUMP PUMPS OR OTHER SIMILAR CONNECTIONS CARRYING RAIN WATER, DRAINAGE OR GROUND WATER

SPECIFIED IN NOTE 11. BEDDING AND RE-FILL FOR DEPTH OF 12 INCHES ABOVE THE TOP OF THE PIPE SHALL BE CAREFULLY AND 6. PIPE JOINTS MUST BE MADE UNDER DRY CONDITIONS. IF WATER IS PRESENT, ALL NECESSARY STEPS SHALL BE TAKEN TO DEWATER

4. JOINTS SHALL BE DEPENDENT UPON A NEOPRENE OR ELASTOMERIC GASKET FOR WATER-TIGHTNESS. ALL JOINTS SHALL BE PROPERLY MATCHED WITH THE PIPE MATERIALS USED. WHERE DIFFERING MATERIALS ARE TO BE CONNECTED, AS AT THE STREET 5. SEWER SERVICE INSTALLATION: THE PIPE SHALL BE HANDLED, PLACED AND JOINTED IN ACCORDANCE WITH INSTALLATION GUIDES OF THE APPROPRIATE MANUFACTURER. IT SHALL BE CAREFULLY BEDDED ON A 6 INCH LAYER OF CRUSHED STONE AND/OR GRAVEL AS

2. TESTING: THE COMPLETED SEWER SERVICE SHALL BE SUBJECTED TO A THIRD PARTY LEAKAGE TEST ANY OF THE FOLLOWING MANNERS: (PRIOR TO BACKFILLING) PRESSURE SEWERS SHALL BE TESTED IN ACCORDANCE WITH SECTION 5 OF THE AWWA C600, "INSTALLATION OF CAST IRON WATER MAINS AND THEIR APPURTENANCES" STANDARD IN EFFECT WHEN THE TEST IS CONDUCTED AT A PRESSURE EQUAL TO THE GREATER OF 150 PERCENT OF THE DESIGN OPERATING TOTAL DYNAMIC

DAMAGE TO AN IRON PIPE, OR OTHERWISE REDUCE THE TYPICAL LIFE EXPECTANCY OF THE PIPE, SUCH AS MAY OCCUR WITH CERTAIN SOIL TYPES, LOW PH LEVELS, OR WATER CONDITIONS, THE PIPE SHALL BE PROTECTED

D. HDPE PIPE USED FOR PRESSURE SEWERS SHALL BE CERTIFIED BY ITS MANUFACTURER AS CONFORMING TO THE ASTM D3035 STANDARD IN EFFECT WHEN THE PIPE IS MANUFACTURED. E. IF DI PIPE IS USED IN AN ENVIRONMENT THAT COULD CAUSE CORROSION OR OTHER DETERIORATION OF OR

C. PVC PIPE USED PRESSURE SEWERS SHALL BE CERTIFIED BY ITS MANUFACTURER AS CONFORMING TO THE ASTM D2241 OR ASTM D1785 STANDARDS IN EFFECT WHEN THE PIPE IS MANUFACTURED.

B. PRESSURE SEWERS SHALL BE TREATED AS GRAVITY SEWERS FOR PURPOSES OF FOUNDATION BEDDING AND

A. PRESSURE SEWERS SHALL BE CONSTRUCTED OF DUCTILE IRON (DI), HIGH DENSITY POLYETHYLENE (HDPE), OR PVC

![](_page_232_Figure_33.jpeg)

# **PROPOSED 3 LOT SUBDIVISION 437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

OWNED BY & PREPARE FOR **ARTWILL**, LLC

SCALE: AS SHOWN

**APRIL 19, 2022** 

![](_page_232_Picture_39.jpeg)

		SERVIC SUMI DE FOM		TES				
1. 2.	PIPE AND JOINT MATERIA A. PLASTIC SEWER PI	ALS: PE			_	<u></u>		N/////
	1. PIPE AND FIT ASTM STANDARDS	GENERIC PIPE	SIZES APPROVED	andards:				
	D3034 F679 F789 F794 D2680	*PVC (SOLID WALL) PVC (SOLID WALL) PVC (SOLID WALL) PVC (RIBBED WALL) *ABS (COMPOSITES WALL)	8" THROUGH 1 18" THROUGH 2 4" THROUGH 1 8" THROUGH 3 8" THROUGH 1	15" (SDR 35) 27" (T-1 & T-2) 18" (T-1 TO T-3) 36" 15"			SUITABLE	COMPACT 1'LAYEF
	*PVC: PC *ABS: AC	OLY VINYL CHLORIDE CRYLONITRILE-BUTADIENE-STYREN	Ξ				*	
	2. JOINTS SEALS ELASTOMERIC BELL AND SI	S FOR PVC PIPE SHALL BE OIL F C MATERIAL CONFORMING TO ASTM PIGOT TYPE.	RESISTANT COMPRESS 1 D-3212 AND SHAL	SION RINGS OF LL BE PUSH-ON,				
	ABS TRUSS COMPOUNDIN	PIPE AND FITTINGS SHALL CONFO NG SHALL BE TO ASTM D-1788 (	ORM TO ASTM D-268 (CLASS 322).	30, POLYMER			- SAND BLANKET	12" MIN
	JOINTS FOR ACCORDANCE	ABS TRUSS PIPE SHALL BE CHE E WITH ASTM D-2680, FORMING A	MICAL WELDED COUP A CHEMICAL WELDED	PLINGS TYPE SC IN JOINT.				
	B. DUCTILE-IRON PIPI 1. DUCTILE IRON STANDARDS (	E, FITTINGS AND JOINTS. PIPE AND FITTINGS SHALL CONFO OF THE LINITED STATES OF AMER	DRM TO THE FOLLOW	/ING LITLITE				
	A21.50 T A21.51 E	THICKNESS DESIGN OF DUCTILE IF DUCTILE IRON CASTINGS. DUCTILE IRON PIPE, CENTRIFUGALI	RON PIPE AND WITH	ASTM A-536 Molds or			BEDDING	• • • • • • • • • • • • • • • • • • •
	2. JOINTS SHALL SHALL CONF( 421-11-F	SAND-LINED MOLDS FOR WATER BE OF THE MECHANICAL OR PUS ORM TO: RUBBER GASKETS JOINTS FOR CA	OR OTHER LIQUIDS. SH-ON TYPE. JOINTS	S AND GASKETS		BEDDING TO BE TH	IOROUGHLY COMPACTED	<u>♀_</u> <u></u> <u>12" MIN∳(Le</u> (SEE NOTE 10)
3.	DAMAGED PIPE SHALL B	BE REJECTED AND REMOVED FROM	1 THE JOB SITE.		TR	ENCH	CROSS	-SECT
4.	JOINTS SHALL BE DEPEI TIGHTNESS. ALL JOINT DIFFERING MATERIALS FOUNDATION WALL, AI	NDENT UPON A NEOPRENE OR EI IS SHALL BE PROPERLY MATCHED ARE TO BE CONNECTED, AS AT PPROPRIATE MANUFACTURED ADAF	LASTOMERIC GASKET ) WITH THE PIPE MA' THE STREET SEWER PTERS SHALL BE USI	FOR WATER— ITERIALS USED. WHERE WYE OR AT THE ED.				
5.	TEES AND WYES: WHERE APPROPRIATE CONNEC BOLTED, CLAMPED OR OPENING IN THE SEW STUFFING CLOTH OR THE CONNECTION, AN	E A TEE OR WYE IS NOT AVAILAB CTION SHALL BE MADE, FOLLOWIN R EPOXY—CEMENTED SADDLE TAPF (ER. THE PRACTICE OF BREAKING OTHER SUCH MATERIAL AROUND ND ANY OTHER SIMILAR CRUDE PF	LE IN THE EXISTING G MANUFACTURERS' PED INTO A SMOOTHI AN OPENING WITH A THE JOINT, OR APPI RACTICES OR INEPT	STREET SEWER, AN INSTRUCTIONS USING A LY DRILLED OR SAWN A SLEDGE HAMMER, LYING MORTAR TO HOLD OR HASTY IMPROVISATION:	S		2 LAYERS (4" THICI	K) OF 2" x 2' x 8'
	WILL NOT BE PERMIT UP TO AND INCLUDIN	TED. THE CONNECTION SHALL BE NG 15" DIAMETER.	CONCRETE ENCASED	D AS SHOWN IN THE DET.	AIL	1	RIGID STYROFOAM THAN LAYERS (2" THICK) OF	INSULATION IF LESS 5 FEET OF COVER - 2" x 2' x 8' RIGID
6.	SEWER SERVICE INSTALL ACCORDANCE WITH IN CAREFULLY BEDDED C NOTE 10. BEDDING AI CAREFULLY AND THOR	ATION: THE PIPE SHALL BE HANE STALLATION GUIDES OF THE APPF DN A 6 INCH LAYER OF CRUSHED ND RE—FILL FOR DEPTH OF 12 I ROUGHLY TAMPED BY HAND OR W	DLED, PLACED AND J ROPRIATE MANUFACTU D STONE AND/OR GF NCHES ABOVE THE T ITH APPROPRIATE ME	JOINTED IN JRER. IT SHALL BE RAVEL AS SPECIFIED IN TOP OF THE PIPE SHALL ECHANICAL DEVICES.	BE		STYROFOAM INSULATION FEET BUT LESS THAN	IF GREATER THAN 5 I 6 FEET OF COVER -
	THE PIPE SHALL BE I CONNECTION TO THE JOINTS MUST BE MAD SHALL BE TAKEN TO	LAID AT A CONTINUOUS AND CON FOUNDATION AT A GRADE OF NO DE UNDER DRY CONDITIONS. IF W. DEWATER THE TRENCH.	ISTANT GRADE FROM T LESS THAN 1/4" ATER IS PRESENT, A	THE STREET SEWER INCH PER FOOT. PIPE ILL NECESSARY STEPS			UNDISTURBED	SOIL
7.	TESTING: THE COMPLETE ANY OF THE FOLLOWING	ED SEWER SERVICE SHALL BE SU G MANNERS: (PRIOR TO BACKFILLI	BJECTED TO A THIRE NG)	D PARTY LEAKAGE TEST IN	N			ţ
	A. AN OBSERVATION T INFLATABLE BLADDE TEE. AFTER INFLATI HEIGHT OF 5 FEET	TEE SHALL BE INSTALLED AS SHO ER OR PLUG SHALL BE INSERTED ION, WATER SHALL BE INTRODUCE ABOVE THE LEVEL OF THE PLUC	WN AND WHEN REAL JUST UPSTREAM FR D INTO THE SYSTEM G.	DY FOR TESTING, AN ROM THE OPENING IN THE I ABOVE THE PLUG TO A	Ξ			<b>▲</b>
	B. THE PIPE SHALL E NEARLY AS POSSI SHALL BE PERMIT BE MADE THROUG	BE LEFT EXPOSED AND LIBERALLY BELE, WET TRENCH CONDITIONS O TED TO RISE IN THE TRENCH OV SH THE CLEANOUT WITH A FLASHL	' HOSED WITH WATEF R, IF TRENCH IS WE ER THE PIPE. INSPE IGHT.	R, TO SIMULATE, AS LT, THE GROUND WATER LCTIONS FOR LEAKS SHALI	L			NOTES
	C. DRY FLUORESCENE IS DRY, THE PIPE WATER SHALL BE SHALL BE MADE I	E DYE SHALL BE SPRINKLED INTO SHALL BE LIBERALLY HOSED WI PERMITTED TO RISE IN THE TREM IN THE FIRST DOWN-STREAM MA	) THE TRENCH OVER TH WATER, OR IF TH NCH OVER THE PIPE. ANHOLE.	THE PIPE. IF THE TRENC IE TRENCH IS WET, GROU . OBSERVATION FOR LEAK	CH IND (S			1. GAPS BETWEEN 2' x 2' PIECE
	LEAKAGE OBSERVED II ACCEPTANCE AND THE WATER TIGHTNESS	N ANY ONE OF THE ABOVE ALTER E PIPE SHALL BE DUG-UP IF NE	RNATE TESTS SHALL CESSARY AND RE-LA	BE CAUSE FOR NON– AID SO AS TO ASSURE			SEWEF	R TRE
8.	ILLEGAL CONNECTIONS: I ETC. SHALL BE PERI CONNECTIONS CARRY	NOTHING BUT SANITARY WASTE FL MITTED. ROOF LEADERS, FOOTING YING RAIN WATER, DRAINAGE OR (	LOW FROM TOILETS, DRAINS, SUMP PUM GROUND WATER SHAI	SINKS, LAUNDRY IPS OR OTHER SIMILAR LL NOT BE PERMITTED.		_		
9.	WATER SERVICE SHALL I	NOT BE LAID IN SAME TRENCH A	S SEWER SERVICE.					
10.	AND MEETING ASTM C 100% PASSIN	NAVEL AND/OK CRUSHED STONE F 233-67. NG 1 INCH SCREEN	NEE FRUM CLAY, LO	Jam, URGANIG MATERIAL				
	90%-100% PASSI 20%-55% PASSI 0%-10% PASSI	NG 3/4 INCH SCREEN NG 3/8 INCH SCREEN ING #4 SIEVE				STREET	► R	THIS PORT
	U%-5% PASSI WHERE ORDERED BY TH STONE 1/2 INCH TO 1	ING #& SIEVE IE ENGINEER TO STABILIZE THE TI 1/2 INCH SHALL BE USED	RENCH BASE, SCREE	NED GRAVEL OR CRUSHE	D		S COUNT WEMENT	
11.	LOCATION: THE LOCATION RECORDS. IN ADDITION	N OF THE TEE OR WYE SHALL BE N, A FERROUS METAL ROD OR P F TYPICAL "CHIMNEY" DETAIL TO	E RECORDED AND FI IPE SHALL BE PLACE	ILED IN THE MUNICIPAL ED OVER THE TEE OR WY IE BURIED PIPE WITH A D	Έ )IP		– cros: /Er – PA	
12.	CHIMNEYS: IF VERTICAL	DROP INTO SEWER IS GREATER T	THAN 4 FEET, A CHII	MNEY SHALL BE	٥٢		M COVER IMUM COV	
	MANUFACTURER MAY	BE USED IF APPROVED BY THE E	ENGINEER.	LOOMMENDED BI THE PH		FF	6' MINIMU	- OBSERVATION TE
					WYE OR T	ES 4 & 5)		
						-		
					$\mathcal{Y}$	<u>Sewer</u>	<u>SERVICE: MIN</u>	IIMUM SLOPE
					STREET SI	EWER		
Co	pyright 2022 ©TFMoran,	, Inc.		DIG SAFE				
48 All du	Constitution Drive, Bed rights reserved. These plicated, replicated or o	ford, N.H. 03110 e plans and materials may not b therwise reproduced in anv form	pe copied, whatsoever				SEW	'ER SE
wit Th	hout the prior written p is plan is not effective Moran, Inc.	unless signed by a duly authori:	zed officer of	ACT DIG Sale 72 Dillouree				
I I ''	*							

COMPACT IN

1'LAYERS

12" MIN.

1/2 OD

S" MIN (FARTH)

![](_page_233_Figure_3.jpeg)

# **GENERAL NOTES**

1.	IT IS THE INTENTION THAT THE MANHOLE, INCLUDING ALL COMPONENT PARTS, HAVE ADEQUATE SPACE, STRENGTH AND LEAKPROOF QUALITIES CONSIDERED NECESSARY FOR THE INTENDED SERVICE. SPACE REQUIREMENTS AND CONFIGURATIONS, SHALL BE AS SHOWN ON THE DRAWING. MANHOLES SHALL BE AN ASSEMBLY OF PRECAST SECTIONS, WITH STEEL REINFORCEMENT, WITH ADEQUATE JOINTING, OR CONCRETE CAST MONOLITHICALLY IN PLACE WITH REINFORCEMENT. IN ANY APPROVED MANHOLE, THE COMPLETE STRUCTURE SHALL BE OF SUCH MATERIAL AND QUALITY AS TO WITHSTAND LOADS OF 8 TONS (H-20 LOADING) WITHOUT FAILURE AND PREVENT LEAKAGE IN EXCESS OF ONE GALLON PER DAY PER VERTICAL FOOT OF MANHOLE, CONTINUOUSLY FOR THE LIFE OF THE STRUCTURE. A PERIOD GENERALLY IN EXCESS OF 25 YEARS IS TO BE UNDERSTOOD IN BOTH CASES.	INSIDE FACE OF MAN FORMED OPENING — FILL WITH MORTAR —
2.	BARRELS, CONE SECTIONS AND CONCRETE GRADE RINGS SHALL BE PRECAST REINFORCED CONCRETE AND SHALL CONFORM ENV-WQ 704.12 & 704.13.	
3. 4	PRECAST CONCRETE BARREL SECTIONS, CONES AND BASES SHALL CONFORM TO ASTM C478-06.	
г. Е	CROWN OF THE INCOMING PIPE.	
э. 6.	ALL PRECAST SECTIONS AND BASES SHALL HAVE THE DATE OF MANUFACTURE AND THE NAME OR	INSIDE FACE OF MAN
7.	TRADEMARK OF THE MANUFACTURER IMPRESSED OR INDELIBLY MARKED ON THE INSIDE WALL.	FILL WITH MORTAR -
8	DAMP-PROOFING COATING.	
0.	REINFORCED CONCRETE SLAB COVER MAY BE USED HAVING AN ECCENTRIC ENTRANCE OPENING AND CAPABLE OF SUPPORTING H-20 LOADS.	
9.	HORIZONTAL JOINTS BETWEEN SECTIONS OF PRECAST CONCRETE BARRELS SHALL BE OF AN OVERLAPPING TYPE, SEALED FOR WATERTIGHTNESS USING A DOUBLE ROW OF AN ELASTOMERIC OR MASTIC-LIKE SEALANT. APPROVED ELASTOMERIC SEALANTS ARE: - SIKAFLEX-12-SL	
10.	<ul> <li>SONNEBORN BUILING PRODUCTS-SONOLASTIC SL-1</li> <li>THE MINIMUM INTERNAL DIAMETER OF MANHOLES SHALL BE 48 INCHES. FOR SEWERS LARGER THAN</li> </ul>	
10.	24-INCH DIAMETER. MANHOLE DIAMETERS SHALL BE INCREASED SO AS TO PROVIDE AT LEAST 12-INCHES OF SHELF ON EACH SIDE OF THE SEWER.	INSIDE FACE OF MA
11.	LEAKAGE TEST SHALL BE PERFORMED IN ACCORDANCE TO ENV-WQ 704.17.	POURED OR HAL
	(a) ALL MANHOLES SHALL BE TESTED FOR LEAKAGE USING A VACUUM TEST IN ACCORDANCE WITH THE ASTM C1244 STARNDARD IN EFFECT WHEN THE TESTING IS PERFORMED.	WATERPLUG, EMBE Approved Equa Formed o
	(b) THE MANHOLE VACUUM TEST SHALL CONFORM TO THE FOLLOWING:	TONMED
	<ol> <li>THE INITIAL VACUUM GUAGE TEST PRESSURE SHALL BE 10 INCHES Hg.</li> <li>THE MINIMUM ACCEPTABLE TEST HOLD TIME FOR 1-INCH Hg PRESSURE DROP TO 9 INCHES SHALL BE:</li> </ol>	
	A. NOT LESS THAN 2 MINUTES FOR MANHOLES LESS THAN 10 FEET DEEP.	
	B. NOT LESS THAN 2.5 MINUTES FOR MANHOLES 10 TO 15 FEET DEEP.	
	(c) THE MANHOLE SHALL BE REPAIRED AND RETESTED IF THE TEST HOLD TIMES FAIL TO ACHIEVE THE	
	(d) INVERTS AND SHELVES SHALL NOT BE INSTALLED UNTIL AFTER SUCCESSFUL TESTING IS COMPLETE.	FORMED OPENING -
	(e) FOLLOWING COMPLETION OF THE LEAKAGE TEST, THE FRAME AND COVER SHALL BE PLACED ON TOP OF THE MANHOLE OR SOME OTHER MEANS USED TO PREVENT ACCIDENTAL ENTRY BY UNAUTHORIZED PERSONS, CHILDREN OR ANIMALS, UNTIL THE CONTRACTOR IS READY TO MAKE FINAL ADJUSTMENT TO CRADE	
12.	BRICK MASONRY FOR SHELF, INVERT AND GRADE ADJUSTMENT SHALL COMPLY WITH ASTM C32-05, CLAY OR SHALE, FOR GRADE SS HARD BRICK.	
13.	MORTAR SHALL BE COMPOSED OF PORTLAND CEMENT AND SAND WITH OR WITHOUT HYDRATED LIME ADDITION. PROPORTIONS IN MORTAR OF PARTS BY VOLUMES SHALL BE: (a) 4.5 PARTS SAND AND 1.5 PARTS CEMENT; OR (b) 4.5 PARTS SAND, 1 PART CEMENT AND 0.5 PART HYDRATED LIME	INSIDE FACE OF MAN
	CEMENT SHALL BE TYPE II PORTLAND CEMENT CONFORMING TO ASTM C150-05. HYDRATED LIME SHALL BE	
	PURPOSES". SAND SHALL CONSIST OF INERT NATURAL SAND CONFORMING TO ASTM C33-03 "STANDARD SPECIFICATIONS FOR CONCRETE, FINE AGGREGATES".	FILL WITH MORTAR —
14.	INVERTS AND SHELVES: MANHOLES SHALL HAVE A BRICK PAVED OR PRECAST CONCRETE SHELF AND INVERT, CONSTRUCTED TO CONFORM TO THE SIZE OF THE PIPE AND FLOW. AT CHANGES IN DIRECTIONS, THE INVERTS SHALL BE LAID OUT IN CURVES OF THE LONGEST RADIUS POSSIBLE TANGENT TO THE CENTER LINE OF THE SEWER PIPES. SHELVES SHALL BE CONSTRUCTED TO THE ELEVATION OF THE HIGHEST PIPE CROWN AND SLOPE TO DRAIN TOWARD THE FLOWING THROUGH CHANNEL. UNDERLAYMENT OF INVERT AND SHELF SHALL CONSIST OF BRICK MASONRY.	STAINLESS STEEL — INTERNAL CLAMP
15.	FRAMES AND COVERS: FRAMES AND COVERS: SEWER MANHOLE FRAMES AND COVERS SHALL BE CITY OF PORTSMOUTH STANDARD, AND SHALL BE PURCHASED AND PICKED UP AT PORTSMOUTH DEPARTMENT OF PUBLIC WORKS WATER DEPARTMENT. THEY SHALL BE OF HEAVY DUTY DESIGN, CLASS 30, CONFORMING TO ASTM A48/48M AND PROVIDE A 30-INCH CLEAR OPENING. THE CASTING SHALL BE OF EVEN GRAINED CAST IRON, SMOOTH, AND FREE FROM SCALE, LUMPS, BLISTERS, SAND HOLES AND DEFECTS. CONTACT SURFACES OF COVERS AND FRAMES SHALL BE MACHINED AT THE FOUNDRY TO PREVENT ROCKING OF COVERS IN ANY ORIENTATION.	
16.	BEDDING: PRECAST BASES SHALL BE PLACED ON A 6-INCH LAYER OF COMPACTED BEDDING MATERIAL THAT CONFORMS TO ASTM C33-03 NO. 67 STONE AND FREE FROM CLAY, LOAM AND ORGANNIC MATTER. THE EXCAVATION SHALL BE PROPERLY DEWATERED WHILE PLACING BEDDING MATERIAL AND SETTING OF THE BASE OR POURING CONCRETE. WATER-STOPS SHALL BE USED AT THE HORIZONTAL JOINT OF THE CAST-IN-PLACE MANHOLES.	_  (
	100% PASSING 1" SCREEN 90–100% PASSING 3/4" SCREEN 20–55% PASSING 3/8" SCREEN 0–10% PASSING #4 SIEVE 0–5% PASSING #8 SIEVE	
17.	FLEXIBLE JOINT: A FLEXIBLE JOINT SHALL BE PROVIDED WIDHIN THE FOLLOWING DISTANCES FROM ANY	INS
10	INCHES FOR PVC PIPE LARGER THAN 15" DIAMETER.	FIL
18.	NO FLEXIBLE JOINT SHALL BE REQUIRED FOR DUCTILE IRON PIPE OR PVC PIPE UP THROUGH TS-INCH DIAMETER.	
19. 20	INTERNAL STEPS ARE PROHIBITED PER CITY OF PORTSMOUTH DPW STANDARDS.	
20.	PIPE TO MANHOLE JOINTS SHALL BE ONLY AS FOLLOWS:	
	A. ELASTOMERIC, RUBBER SLEEVE WITH WATERTIGHT JOINTS AT THE MANHOLE OPENING AND PIPE SURFACES.	
	B. CAST INTO WALL OR SECUREED WITH STAINLESS STEEL CLAMPS.	
	C. ELASTOMERIC SEALING RING CAST IN THE MANHOLE OPENING WITH THE SEAL FORMED ON THE SURFACE OF THE PIPE BY COMPRESSION OF THE RING.	
	D. NON-SHRINK GROUTED JOINTS WHERE WATERTIGHT BONDING TO THE MANHOLE AND PIPE CAN BE OBTAINED.	
22.	THE INVERT OF THE INCOMING PIPE SHALL BE NO MORE THAN 6 INCHES ABOVE THE OUTGOING PIPE UNLESS A DROP ENTRY IS USED.	
Cc 48	opyright 2022 ©TFMoran, Inc. 8 Constitution Drive, Bedford, N.H. 03110	
All du wit	rights reserved. These plans and materials may not be copied, plicated, replicated or otherwise reproduced in any form whatsoever thout the prior written permission of TFMoran, Inc.	
Th TF	is plan is not effective unless signed by a duly authorized officer of Moran, Inc.	

![](_page_234_Figure_2.jpeg)

![](_page_234_Figure_3.jpeg)

![](_page_234_Figure_5.jpeg)

# LANDSCAPE GUARANTEE AND MAINTENANCE NOTES

- 1. CONTRACTOR WILL BE RESPONSIBLE FOR ALL MEANS, METHODS AND TECHNIQUES OF WATERING.
- 2. CONTRACTOR WILL BEGIN WATERING IMMEDIATELY AFTER PLANTING. ALL PLANTS WILL BE THOROUGHLY WATERED TWICE DURING THE FIRST 24 HOUR PERIOD AFTER PLANTING. ALL PLANTS WILL BE WATERED WEEKLY, OR MORE OFTEN, IF NECESSARY DURING THE FIRST GROWING SEASON BUT NOT LESS THAN ONE YEAR.
- 3. WATER ALL LAWNS AS REQUIRED. DO NOT LET NEWLY PLANTED LAWNS DRY OUT DURING THE FIRST FOUR WEEKS MINIMUM.
- 4. ALL NEW LAWNS WILL BE MAINTAINED AND MOWED A MINIMUM THREE (3) TIMES BEFORE REQUESTING REVIEW BY LANDSCAPE ARCHITECT OR OWNER'S REPRESENTATIVE FOR ACCEPTANCE. MAINTENANCE AND MOWING WILL CONTINUE UNTIL ACCEPTED BY LANDSCAPE ARCHITECT OR OWNERS' REPRESENTATIVE IS ISSUED IN WRITING.
- 5. THE CONTRACTOR WILL MAINTAIN AND GUARANTEE ALL PLANTINGS TO BE IN GOOD HEALTHY, FLOURISHING AND ACCEPTABLE CONDITION FOR A PERIOD OF ONE (1) YEAR BEGINNING AT THE DATE OF ACCEPTANCE BY THE LANDSCAPE ARCHITECT OR OWNER'S REPRESENTATIVE. ALL GRASSES, TREES AND SHRUBS THAT, IN THE OPINION OF THE LANDSCAPE ARCHITECT OR OWNER'S REPRESENTATIVE SHOWING LESS THAN 80% HEALTHY GROWTH AT THE END OF ONE (1) YEAR PERIOD WILL BE IMMEDIATELY REPLACED BY THE CONTRACTOR.
- 7. ALL DAY LILIES WILL BE DEADHEADED AND CUT BACK EVERY FALL. ALL ORNAMENTAL GRASSES WILL BE CUT BACK EVERY FALL OR EARLY SPRING.
- B. DECIDUOUS PLANT MATERIAL INSTALLED AFTER SEPTEMBER 30 AND BEFORE APRIL 15 WILL NOT BE REVIEWED THAT SEASON FOR ACCEPTANCE DUE TO STAGE OF LEAF PHYSIOLOGY. THIS PLANT MATERIAL WILL NOT BE REVIEWED UNTIL FOLLOWING GROWING SEASON. GUARANTEE PERIOD WILL BEGIN ONLY AFTER ACCEPTANCE BY LANDSCAPE ARCHITECT OR OWNERS' REPRESENTATIVE.
- 9. EVERGREEN PLANT MATERIAL INSTALLED AFTER OCTOBER 30 AND BEFORE APRIL 15 WILL NOT BE REVIEWED THAT SEASON FOR ACCEPTANCE DUE TO END OF GROWTH SEASON. THIS PLANT MATERIAL WILL NOT BE REVIEWED UNTIL FOLLOWING GROWING SEASON. GUARANTEE PERIOD WILL BEGIN ONLY AFTER ACCEPTANCE BY LANDSCAPE ARCHITECT OR OWNERS' REPRESENTATIVE.

# HYDROSEEDING NOTES

- 1. HYDROSEEDING MAY BE USED AS AN ALTERNATE METHOD OF SEEDING. THE APPLICATION OF LIMESTONE AS NECESSARY, FERTILIZER AND GRASS SEED MAY BE ACCOMPLISHED IN ONE OPERATION BY THE USE OF A SPRAYING MACHINE APPROVED BY THE LANDSCAPE ARCHITECT OR CIVIL ENGINEER. THE MATERIALS SHALL BE MIXED WITH WATER IN THE MACHINE AND SHALL CONFORM TO RELATIVE REQUIREMENTS OF SECTION 644 OF NH. STANDARD SPECIFICATIONS FOR ROAD AND BRIDGE CONSTRUCTION.
- 2. (FOR MASSACHUSETTS PROJECTS PLUG IN SECTION 765.65 OF MASS. DPW CURRENT STANDARD SPECIFICATIONS FOR HIGHWAYS AND BRIDGES).

# **INVASIVE PLANT NOTES**

1. EXISTING NON-NATIVE, INVASIVE PLANT SPECIES WILL BE IDENTIFIED, REMOVED, DESTROYED AND LEGALLY DISPOSED OF OFF-SITE IN ACCORDANCE WITH THE LATEST UNIVERSITY OF NEW HAMPSHIRE COOPERATIVE EXTENSION METHODS OF DISPOSING NON-NATIVE INVASIVE PLANTS. SEE "MANAGE AND CONTROL INVASIVES" AND PROPERLY DISPOSE OF INVASIVE PLANTS".

# **PRICING & CONSTRUCTION DOCUMENT NOTES**

- 1. CONTRACTOR WILL PRICE PLANT MATERIAL IN QUANTITIES SUFFICIENT TO COMPLETE PLANTINGS GRAPHICALLY SHOWN ON THESE DRAWINGS OR IN PLANT LIST, WHICHEVER IS GREATER. IN CASES OF DISCREPANCY BETWEEN PLAN AND LIST CLARIFY WITH LANDSCAPE ARCHITECT PRIOR TO PLACING PURCHASE ORDER AND AGAIN PRIOR TO PLANTING.
- 2. CONTRACTOR WILL VERIFY PRIOR TO PRICING IF SITE SOILS ARE VERY POORLY DRAINING OR IF LEDGE IS PRESENT. IF CONTRACTOR ENCOUNTERS VERY POORLY DRAINING SOILS (BATH TUB EFFECT) OR LEDGE THAT IMPACTS PROPOSED PLANTING PLAN, NOTIFY LANDSCAPE ARCHITECT OR OWNERS' REPRESENTATIVE FOR DIRECTION PRIOR TO PRICING AND AGAIN PRIOR TO PERFORMING ANY WORK.
- 3. PARKING AREA PLANTED ISLANDS WILL HAVE MINIMUM OF 1'-0" TOPSOIL PLACED TO THE TOP OF CURB ELEVATION. REMOVE ALL CONSTRUCTION DEBRIS BEFORE PLACING TOPSOIL.
- 4. EXISTING TREES SHOWN ON THE PLAN WILL REMAIN UNDISTURBED. ALL EXISTING TREES SHOWN TO REMAIN WILL BE PROTECTED WITH A 4-FOOT SNOW FENCE PLACED AT THE DRIP LINE OF THE BRANCHES OR AT 8 FEET MINIMUM FROM THE TREE TRUNK.
- 5. CONTRACTOR WILL STAKE OR PLACE ON GROUND ALL PROPOSED PLANT MATERIALS PER PLAN. CONTACT LANDSCAPE ARCHITECT FOR REVIEW AND APPROVAL PRIOR TO INSTALLATION.
- 6. COORDINATE WITH LANDSCAPE ARCHITECT'S CONTRACTED NUMBER OF SITE VISITS WHEN PLANNING FOR INSPECTION. NOTIFY LANDSCAPE ARCHITECT 72 HOURS MINIMUM IN ADVANCE OF REQUESTED SITE VISIT.
- 7. CONTRACTOR WILL DEVELOP A WRITTEN WATERING SCHEDULE AND WILL SUBMIT WATERING SCHEDULE TO OWNERS' REPRESENTATIVE. CONTRACTOR WILL WATER ALL NEW PLANTS INCLUDING LAWNS THAT ARE NOT "IRRIGATED" VIA A PERMANENT IRRIGATION SYSTEM FOR THE FIRST 12 MONTHS.

# PORTSMOUTH NOTES

- 1. THE PROPERTY OWNER AND ALL FUTURE PROPERTY OWNER'S WILL BE RESPONSIBLE FOR THE MAINTENANCE AND OF ALL REQUIRED SCREENING AND LANDSCAPE MATERIALS INDICATED ON THESE PLAN(S).
- 2. ALL REQUIRED PLANT MATERIAL WILL BE TENDED TO AND KEPT FREE OF REFUSE AND DEBRIS.
- 3. ALL REQUIRED FENCES AND WALLS WILL BE MAINTAINED IN GOOD REPAIR.
- THE PROPERTY OWNER WILL BE RESPONSIBLE TO REMOVE AND REPLACE DEAD OR DISEASED PLANT MATERIALS IMMEDIATELY WITH THE SAME TYPE, SIZE AND QUANTITY OF PLANT MATERIALS AS ORIGINALLY INSTALLED, UNLESS ALTERNATIVE PLANTINGS ARE REQUESTED, JUSTIFIED AND APPROVED BY THE PLANNING BOARD OR PLANNING DIRECTOR.
- 5. ALL IMPROVEMENTS SHOWN ON THIS PLAN WILL BE CONSTRUCTED AND MAINTAINED IN ACCORDANCE WITH THIS PLAN BY THE PROPERTY OWNER AND ALL FUTURE PROPERTY OWNERS. NO CHANGES WILL BE MADE TO THIS PLAN WITHOUT THE WRITTEN APPROVAL OF THE PORTSMOUTH PLANNING BOARD OR PLANNING DIRECTOR.
- 7. THE LANDSCAPE PLAN WILL BE RECORDED IN THE ROCKINGHAM COUNTY REGISTRY OF DEEDS.
- 8. MAINTENANCE OF LANDSCAPING TO FOLLOW THE NOFA STANDARDS FOR ORGANIC LAND CARE 6TH EDITION PRACTICES FOR THE DESIGN AND MAINTENANCE OF ECOLOGICAL LANDSCAPES. ("NOFA STANDARDS FOR ORGANIC LAND CARE." NOFA STANDARDS FOR ORGANIC LAND CARE 6TH EDITION PRACTICES FOR THE DESIGN AND MAINTENANCE OF ECOLOGICAL LANDSCAPES, NORTHEAST ORGANIC FARMING ASSOCIATION OF CONNECTICUT, INC, 2017, HTTP://WWW.ORGANICLANDCARE.NET/SITES/DEFAULT/FILES/NOFA\_ORGANIC\_LAND\_CARE\_STANDARDS\_6THEDITION\_2017\_OPT.PDF.)

### SEEDING NOTES

- 1. SLOPES UP TO AND INCLUDING 3:1 GRADE, SEED WILL BE NEW ENGLAND EROSION CONTROL & RESTORATION MIX PER NEW ENGLAND WETLANDS PLANTS INC., AMHERST, MA.
- 2. SLOPES STEEPER THAN 3:1 GRADE, SEED WILL BE NEW ENGLAND EROSION CONTROL & RESTORATION MIX PER NEW ENGLAND WETLANDS PLANTS INC., AMHERST, MA. SEE CIVIL FOR ADDITIONAL EROSION CONTROL MEASURES.
- 3. GENERAL SEED WILL BE NHDOT SPECIFICATION SECTION 644, TABLE 644-1-PARK SEED TYPE 15, INCLUDING NOTES TO TABLE 1, 2 & 3.

Copyright 2022 ©TFMoran, Inc. 48 Constitution Drive, Bedford, N.H. 03110

All rights reserved. These plans and materials may not be copied, duplicated, replicated or otherwise reproduced in any form whatsoever without the prior written permission of TFMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of FMoran, Inc.

![](_page_235_Picture_37.jpeg)

![](_page_235_Figure_39.jpeg)

# SHRUB PLANTING

![](_page_235_Figure_41.jpeg)

![](_page_235_Figure_42.jpeg)

NOTES:

1. A 10 FOOT MINIMUM EDGE TO EDGE HORIZONTAL SEPARATION SHALL BE PROVIDED BETWEEN ALL WATER AND SANITARY SEWER LINES. AN 18" MINIMUM OUTSIDE TO OUTSIDE VERTICAL SEPARATION SHALL BE PROVIDED AT ALL WATER AND SANITARY SEWER CROSSINGS.

2. PROTECTION OF WATER SUPPLIES:

A. THERE SHALL BE NO PHYSICAL CONNECTION BETWEEN A PUBLIC OR PRIVATE POTABLE WATER SUPPLY SYSTEM AND A SEWER OR SEWER APPURTENANCE WHICH WOULD PERMIT THE PASSAGE OF SEWAGE OR POLLUTED WATER INTO THE POTABLE SUPPLY. NO WATER PIPE SHALL PASS THROUGH OR COME IN CONTACT WITH ANY PART OF A SEWER OR SEWER MANHOLE

B. NO SEWER SHALL BE LOCATED WITHIN THE WELL PROTECTED RADII ESTABLISHED IN ENV-WS 300 FOR ANY PUBLIC WATER SUPPLY WELLS OR WITHIN 100 FEET OF ANY PRIVATE WATER SUPPLY WELL.

C. SEWERS SHALL BE LOCATED AT LEAST 10 FEET HORIZONTALLY FROM ANY EXISTING OR PROPOSED WATER MAIN.

D. A DEVIATION FROM THE SEPARATION REQUIREMENTS OF (B) OR (C) ABOVE SHALL BE ALLOWED WHERE NECESSARY TO AVOID CONFLICT WITH SUBSURFACE STRUCTURES, UTILITY CHAMBERS, AND BUILDING FOUNDATIONS, PROVIDED THAT THE SEWER IS CONSTRUCTED IN ACCORDANCE WITH THE FORCE MAIN CONSTRUCTION REQUIREMENTS SPECIFIED IN ENV-WQ 704.06.

E. WHENEVER SEWERS MUST CROSS WATER MAINS, THE SEWER SHALL BE CONSTRUCTED AS FOLLOWS:

a. VERTICAL SEPARATION OF THE SEWER AND WATER MAIN SHALL BE NOT LESS THAN 18 INCHES, WITH WATER ABOVE SEWER AND

b. SEWER PIPE JOINTS SHALL BE LOCATED AT LEAST 6 FEET HORIZONTALLY FROM THE WATER MAIN.

# WATER & SEWER CROSSING

NOT TO SCALE

![](_page_235_Figure_56.jpeg)

# SITE DEVELOPMENT PLANS

TAX MAP 229 LOT 1 DETAILS

# **PROPOSED 3 LOT SUBDIVISION 437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

OWNED BY & PREPARE FOR **ARTWILL, LLC** 

SCALE:

**APRIL** 19, 2022

![](_page_235_Picture_63.jpeg)

ivil Engineers tructural Engineers raffic Engineers \_and Surveyors \_andscape Architects cientists

45407-120\_DETAILS

C-15

48 Constitution Drive

Bedford, NH 03110

Fax (603) 472-9747

www.tfmoran.com

Phone (603) 472-4488

![](_page_236_Figure_0.jpeg)

and the second se

![](_page_237_Figure_0.jpeg)

![](_page_238_Figure_0.jpeg)

![](_page_239_Figure_0.jpeg)

![](_page_240_Picture_0.jpeg)

÷

	· · ·	
		I don Aber 1-2.
Shelverchoors Shelverchoore		1-9 FigorDrepad
	Lots Aritul SCALE: APPROVED BY:	DRAWN BY
	DATE: 2/12/22 Smithfeld Front Eles wil ADD -1.	REVISED DRAWING NUMBER

61

![](_page_241_Figure_0.jpeg)

![](_page_242_Figure_0.jpeg)

![](_page_243_Figure_0.jpeg)

1. ...**4**...

· ---

![](_page_244_Figure_0.jpeg)

![](_page_245_Figure_0.jpeg)

![](_page_246_Picture_0.jpeg)

Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists

![](_page_246_Picture_2.jpeg)

Job #45407.120

# NHDES

# **Application for Sewer Connection Permit**

FOR

# Proposed 3-Lot Subdivision

437 Lafayette Road Portsmouth, New Hampshire

Tax Map 229, Lot 1

May 20, 2022

**Prepared By:** 

![](_page_246_Picture_12.jpeg)

Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists

**TFMoran, Inc.** 48 Constitution Drive, Bedford, NH 03110 T(603) 472-4488 www.tfmoran.com

![](_page_246_Picture_15.jpeg)

**TFMoran, Inc. Seacoast Division** 170 Commerce Way–Suite 102, Portsmouth, NH 03801 T(603) 431-2222

![](_page_247_Picture_0.jpeg)

Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists

![](_page_247_Picture_2.jpeg)

May 25, 2022

Dennis Greene, PE NHDES Wastewater Engineering Bureau 29 Hazen Drive PO Box 95 Concord, NH 03302

via email: dennis.greene@des.nh.gov & robert.daniel@des.nh.gov

### RE: NHDES Sewer Connection Permit Application Submittal 437 Lafayette Road – Artwill, LLC – Tax Map 229 Lot 1 Project #45407.120

Dear Mr. Greene:

On behalf of our client, Artwill, LLC, please find a NHDES Application for Sewer Connection Permit submission relative to the above-referenced project. The following materials are included in this submission:

- Check in the amount of \$1,800.00 to Treasurer State of NH for permit fees
- Application for Sewer Connection Permit (City signature pending)
- Calculated Design Sewer Flow & NHDES Env-Wq 1000 Table 1008-1: Unit Design Flow
- Environmental One Corportation Pressure Sewer Design Report, dated May 19, 2022
- Partial Set of Site Development Plans titled "Proposed 3 Lot Subdivision, 437 Lafayette Road, Portsmouth, New Hampshire", prepared by TFMoran, Inc., dated April 19, 2022, last revised May 25, 2022 (1 copy 22"x34"). Sheets included in this submittal:
  - o C-00 Cover
  - o C-01 Notes & Legend
  - S-01 Existing Conditions Plan
  - C-05 Utility Plan
  - C-12 C-14 Details

### Project Description

This proposal is for the subdivision of a single lot into three proposed lots, and the construction of two single-family dwelling units and an attached accessory dwelling unit. Other improvements associated with this project include but not limited to grading, utility installation, stormwater management, landscaping, and paving. The existing lot is located at 437 Lafayette Road and is identified on the City of Portsmouth Assessor's Map 229 as Lot 1, and is approximately 65,365 sf (1.50 ac) in size. The site is

![](_page_247_Picture_22.jpeg)

**TFMoran, Inc. Seacoast Division** 170 Commerce Way–Suite 102, Portsmouth, NH 03801 T(603) 431-2222

![](_page_248_Picture_0.jpeg)

NHDES Sewer Connection Permit Application Submittal 437 Lafayette Road – Artwill, LLC – Tax Map 229 Lot 1 Project #45407.120

located in the Single Residence B (SRB) Zone and currently contains one single-family residential building and a detached garage.

The proposed house on Lot #1 is to be serviced by a 6" PVC gravity sewer line, which will tie into an existing manhole at the intersection of Lafayette Road and Artwill Ave. The houses on Lots #2 and #3 will be serviced by 1-1/4" PVC pressure sewer lines that will each connect to a proposed 1-1/2" PVC force main line that runs along Artwill Ave before ultimately connecting to the existing sewer manhole at the intersection.

The proposed project consists of 84 linear feet (LF) of 6" SDR-35 PVC pipe, 239 LF of 1-1/2" SRD-11 PVC pipe, 105 LF of 1-1/4" SDR-11 PVC pipe, two cleanouts along the gravity sewer service line, two E/One grinder pumps, and a terminal flushing manhole for the pressure sewer main.

The City of Portsmouth is concurrently reviewing this application. Any revisions based on their comments will be circled on the plans and forwarded to you.

If you have any questions or concerns, please do not hesitate to contact us.

Respectfully, TFMoran, Inc.

> Mull

Justin Macek, EIT Project Manager

JSM/sdr

cc: Joe Caldarola, Smithfield Construction, Inc. (via joe@smithfieldconstruction.com)

![](_page_249_Figure_0.jpeg)

### NHDES-W-09-008

![](_page_250_Picture_1.jpeg)

# APPLICATION FOR SEWER CONNECTION PERMIT Water Division/Wastewater Engineering Bureau Design Review Section

![](_page_250_Picture_3.jpeg)

### RSA/Rule: RSA 485-A:37 / Env-Wq 703.07

### **TYPE OR PRINT CLEARLY**

Use this application for Sewer Connection Permit to request NHDES review/approval for any proposed sewerage design. Under RSAs 485 and 485-A, design plans for new sewerage facilities – whether publicly or privately owned, and regardless of design flow – must be submitted to NHDES for review/approval action at least 30 days prior to construction. Pursuant to Env-Wq 703, design submittals must include 1 set of engineering plans/specifications, pertinent design calculations, the required fee, and a Municipal Certification (signed by an authorized municipal official, see page 2).

1. Engineer of Record - Contact Information						
Engineer / Contact: Justin Macek				Company: TFMoran Inc.		
Mailing Address: 170 Commerce Way, Suite 102						
Town/City: Portsmouth				<i>State:</i> NH	ZIP: 03801	
Phone Number: 603-431-2222				Email: jmacek@tfm	oran.com	
2. Description of Proposed Work (check all that apply)						
		An extension of a collector or interceptor;				
		A sewage pumping station greater than 50 gpm or serving more than one building;				
	A proposed sewer that serves more than one building or that requires a manhole at the connection.					
Project Name or Description: Smithfield Construction - 3 Lot Subdivision - Residential						
Project Location - Street Address: 437 Lafayette Road						
Project Location - Town / City: Portsmouth						
Name Of Receiving WWTF: Portsmouth Wastewater Treatment Plant						
Average Design Flow (ADF, gal/day): 1,800						
Proposed Sewer Length (Linear ft)			Pipe Diameter (inch	es)	Pipe Material	
84			6		SDR-35 PVC	
239			1-1/2		SDR-11 PVC	
105		1-1/4		SDR-11 PVC		
3. Required Fee						
	Sewer	Sewer connection design submittals must be accompanied by a review fee payment based on the project's				
$\boxtimes$	average design flow - \$0.10 per gal/day ("a dime a gallon") for design flows up to 10,000 gal/day, plus \$0.05 per					
	gal/day for any flows in excess thereof.					
	A fee of \$200 per plan sheet shall be paid for review of modifications to privately owned pump stations, force					
	mains, interceptors, and wastewater treatment facilities which are not associated with an increase in wastewater					
	flow.					
	Fees are not required of municipalities for municipal projects.					
<b><u>Fee Enclosed:</u></b> \$180.00 Please make checks payable to "Treasurer State of NH".						

Italics indicate items are optional. www.des.nh.gov 29 Hazen Drive • PO Box 95 • Concord, NH 03302-0095 (603) 271-3503 • TDD Access: Relay NH 1-800-735-2964

4. Municipal Certification					
On behalf of this Proposed 3-Lot Subdivision, the Town or City of Portsmouth hereby provides					
the following municipal certification.					
The municipal sewage collection system and wastewater treatment facilities have been demonstrated, pursuant to					
Env-Wq 703.07(d), to have adequate processing capability for the proposed added hydraulic flow and organic flow at					
the time of connection. The proposed sewer connection and/or sewerage design meet with the approval of the local					
jurisdictional authority.					
Name Of Municipal Official (Project Location):	Title: City Engineer				
Terry Desmarais, P.E.					
Signature:	Date:				
Email Address: tldesmarais@cityofportsmouth.com					
When the Receiving WWTF is in a different Municipality from that of the Project Location, the following additional					
certification is required.					
Name Of WWTF Official (Host Community):	Title:				
Signature:	Date:				
Email Address:					

### Submit completed application package to:

NHDES Wastewater Engineering Bureau Design Review Section 29 Hazen Drive P.O. Box 95 Concord, NH 03302-0095

**NOTE:** A Separate INDUSTRIAL WASTEWATER INDIRECT DISCHARGE REQUEST (IDR) May be Required For Industrial Waste Contributions, Depending On Quantity And Quality. For Further Information, Contact The Industrial Pretreatment Supervisor Of The Wastewater Engineering Bureau At (603)-271-2052.

Italics indicate items are optional. www.des.nh.gov 29 Hazen Drive • PO Box 95 • Concord, NH 03302-0095 (603) 271-3503 • TDD Access: Relay NH 1-800-735-2964
Project	Propose	Proposed 3-Lot Subdivision							
Location	437 Lafa	437 Lafayette Road							
Portsmouth, NH									
Unit Sewer Flows									
Total Number of Units	3	3							
Based	on 100%	4 Bedroo	m Un	its					
4 Bedroom Houses									
Residences Single Fam	ilv - 2 Bedroo	m		300					
Additional Flow for 2 A	dditional Be	droom		300					
Gallons Perd Day per 4	Bedroom U	nit		600					
Design Sewer Flows									
	Numbe	r GPD/							
	of Units	unit		GPD					
Number of 4 Bedroom	3	600		1,800					
Total Design Flow		}		1,800					
State Fee									
Cost per GPD	\$ 0.10	) 1,800	\$	180.00					
Total Cost			\$	180.00					

Date: 5/20/2022

#### NEW HAMPSHIRE CODE OF ADMINISTRATIVE RULES

(2) Metered water readings for uses that are as similar as possible to the proposed use, taking into consideration factors such as occupancy and frequency of use, determined as specified in (d), below.

(d) Design flows based on metered water readings shall be calculated:

(1) By finding the average of water meter readings over a period of time that is representative of the volume of water used and multiplying the average by a minimum peaking factor of 2 for commercial light flow or a maximum peaking factor of 3 for commercial heavy flow; or

(2) By measuring not less than 6 months of consecutive daily meter readings, including the month(s) of heaviest use for uses that are seasonal in nature, and using the highest daily flow without application of a peaking factor;

(e) The unit design flow figures referenced in (b) and (c), above, shall be as listed in Table 1008-1, below, subject to (f), below:

Use	Unit Design Flow
AIRPORTS	5 GPD/Transient plus 10 GPD/Employee
APARTMENTS	See Dwellings
BARS, LOUNGES	See Food Service
BED & BREAKFAST	60 GPD/Guest, based on the greater of 2 guests per
	room or the actual number of guests the room is
	designed to accommodate, plus 10 GPD/Employee
BUNKHOUSE	60 GPD/Person
CAMPS:	
Campground with Central Comfort Station	45 GPD/site, plus 20 GPD/Site for the dump station
Recreational Campgrounds with 3-way hookups	60 GPD/Site
Construction Camps	50 GPD/Person
Day Camps (not including meals)	15 GPD/Person
Dining Facility	3 GPD/Person/meal
Residential Youth Recreation Camps	25 GPD/Person plus 3 GPD/Person/meal
CATERERS – Function Rooms	12 GPD/patron
CHURCHES:	
Sanctuary Seating	3 GPD/Seat
Church Suppers	12 GPD/Seat
COUNTRY CLUBS – PRIVATE	
Dining Room	10 GPD/Seat
Snack Bar	10 GPD/Seat
Locker & Showers	20 GPD/Locker
DAY CARE CENTERS	10 GPD/Person
DENTISTS	10 GPD/Chair plus 35 GPD/Staff Member
DOCTOR'S OFFICES	250 GPD/Doctor
DOG KENNELS	50 GPD/Kennel, with one dog per kennel
DWELLINGS:	
Apartment - Studio or One-Bedroom	225 GPD
Apartment - 2 or More Bedrooms	150 GPD/Bedroom
Residence - Single-Family	300 GPD plus 150 GPD for each bedroom over 2
Residence - Duplex	300 GPD plus 150 GPD for each bedroom over 2 for
	each unit
Rooming House – With Meals	60 GPD/Person
Rooming House – Without Meals	40 GPD/Person
Senior Housing	See Senior Housing

#### Table 1008-1: Unit Design Flow Figures



# **Environment One Corporation**

# **Pressure Sewer Preliminary**

# **Cost and Design Analysis**

# For

# 437 Lafayette Rd-Portsmouth NH

Prepared For:Justin Macek TF Moran170 Commerce Way - Suite 102PortsmouthNH03801Tel:(603) 431-2222Fax:Prepared By:D.CoppolaMay 19, 2022

\\CWMDFS02\Home - Remote\dcoppola\My Documents\EONE\New Hampshire\Portsmouth\437 Lafayette Rd\437 Lafayette Rd.EOne

#### Prepared By:

D.Coppola

#### PRELIMINARY PRESSURE SEWER - PIPE SIZING AND BRANCH ANALYSIS 437 Lafayette Rd-Portsmouth NH

Zone	Connects	Number	Accum	Gals/day	Max Flow	Max	Max Flow	Pipe Size	Max	Length of Main	Friction Loss	Friction	Accum Fric	Max Main	Minimum Pump	Static Head	Total
Number	to Zone	of Pumps	Pumps	per Pump	Per Pump	Sim Ops	(GPM)	(inches)	Velocity	this Zone	Factor	Loss This	Loss (feet)	Elevation	Elevation	(feet)	Dynamic
		in Zone	in Zone		(gpm)				(FPS)		(ft/100 ft)	Zone					Head (ft)
This spreadsheet was calculated using pipe diameters for: SDR21PVC						Frict	ion loss calcula	ations were ba	used on a Cons	tant for inside roug	ghness "C" of:	1	50				
1.00	1.00	2	2	600	11.00	2	22.00	1.50	3.04	238.00	2.15	5.12	5.12	30.00	24.00	6.00	11.12

Note: This analysis is valid only with the use of progressive cavity type grinder pumps as manufactured by Environment One. \\CWMDFS02\Home - Remote\dcoppola\My Documents\EONE\New Hampshire\Portsmouth\437 Lafayette Rd\437 Lafayette Rd.EOne Prepared By: D.Coppola

#### PRELIMINARY PRESSURE SEWER - ACCUMULATED RETENTION TIME (HR) 437 Lafayette Rd-Portsmouth NH

May 19, 2022

Zone Number	Connects to Zone	Accumulated Total of Pumps this Zone	Pipe Size (inches)	Gallons per 100 lineal feet	Length of Zone	Capacity of Zone	Average Daily Flow	Average Fluid Changes per Day	Average Retention Time (Hr)	Accumulated Retention Time (Hr)
This spreadsheet was calculated using pipe diameters for SDR21PVC Gals per Day per Dwelling								200		
1.00	1.00	2	1.50	12.07	238.00	28.73	1,200	41.77	0.57	0.57

water supply and pollution control equipment



273 Weymouth Street, Rockland, MA 02370 tel. 781-982-9300 · fax. 781-982-1056 www.frmahony.com • www.amphidrome.com info@frmahony.com

# **E/ONE Pressure System Design Report** For 437 Lafayette Rd Portsmouth, NH May 19, 2022



#### water supply and pollution control equipment



273 Weymouth Street, Rockland, MA 02370 tel. 781-982-9300 • fax. 781-982-1056 www.frmahony.com • www.amphidrome.com info@frmahony.com

May 19th, 2022

Justin Macek, EIT Civil Project Engineer TFMoran Seacoast Division 170 Commerce Way - Suite 102 Portsmouth, NH 03801 (603) 431-2222 RE: 437 Lafayette Rd Portsmouth, NH

F.R. MAHONY & ASSOC.

#### Dear Justin;

This preliminary design analysis examines the use of the E/One Pressure Sewer System for your project. E/One is celebrating 50 years of installation and O&M experience along with considerable research and development leading to continuous product and system improvements. E/One remains the worldwide industry standard and industry leader in the pressure sewer technology. The unique characteristics of the E/One Pressure Sewer approach provides not only a technical solution, but also an economic advantage to be realized with low up front and O&M costs.

#### **System Analysis**

Using the information you provided, we ran the enclosed preliminary pressure sewer pipe sizing analysis. This was run through our Low Pressure Sewer Design Software that employs our Flow Velocity and Friction Head Loss vs. Pumps in Simultaneous Operation Spreadsheet. We have used the surface topography provided to make our analyses.

#### **Zone Layout**

Using the preliminary information we laid this into a single 1 1/2 inch flow zone discharging into a gravity main on Lafayette Rd.

Computations are based on the Hazen-Williams formula for friction loss, using calculations of cross-sectional area and flow rate to determine pipe sizes that create "self-cleaning" velocities of 2.0 fps or higher. A "C" factor of 150, SDR 21 PVC pipe and the average expected daily volumes for single family homes are also used in this analysis.

The highest Total Dynamic Head generated is approximately 13 feet which is



273 Weymouth Street, Rockland, MA 02370 tel. 781-982-9300 · fax. 781-982-1056 www.frmahony.com • www.amphidrome.com info@frmahony.com

comprised of static head and friction loss in the proposed pipelines. This is well below our pump's continuous-run rating of 185 ft, and well within its intermittent, i.e., normal, operating range. Flow velocity throughout the system meets or exceeds 2 fps. These characteristics and low retention time indicate that this will be a reliable, low-maintenance system.

#### **Design Flows & System Velocity**

We normally use average daily flows for system designs rather than the peak design flows commonly used for gravity sewer sizing. We do this because the system is sealed and void of inflow and infiltration commonly allowed for in gravity sewer designs. We size the system for an average daily flow of 600+/- gpd generally for single family homes. The pumps selected are rated to flows up to 700 gpd thus peak flows are easily handled. We size the pipelines for the proper scouring velocity based on the pump's output which has a consistent flow rate over a wide range of head conditions. We then look at the pipeline retention time to optimize the line size for the lowest retention that will pass wastewater in a short period of time to reduce sediment in the lines and prevent odor issues. This makes for a very reliable and maintenance free wastewater collection system.

Often we are asked to use the published "State" design values from various flow tables in order to secure approval. We can do this; but then we run the reports based on the actual predicted average flow to optimize the line size as mentioned above.

Many of our installations have seen flows that more closely mirror the EPA water use goals of 70 gpd/capita. We also look at seasonal uses a little more closely due to greater reductions in flow in the offseason. In applications of this type we look to find the best for both seasons.

#### Appurtenances

Cleanouts, Air/Vacuum Release •

Our normal recommendations for valve placement are as follows: flushing connections at 1,000' to 1,500' intervals and at branch ends and junctions; isolation valves at branch junctions; and air release valves at peaks of 25 ft. or more and/or at intervals of 2,000 to 2,500 ft. We recommend one flushing manhole labeled on PDF FRMA markup.



• Service Laterals and Check Valves

Common practice in pressure sewers requires the ability to isolate each lot with a corporation stop off the main and service lateral kit to the lot line. E/One now requires that each pump connection be isolated with a combination curb stop/redundant check valve.

E/One has developed a true wastewater rated check valve which is built in to our stainless steel lateral kit shown in this report. These components are rated to 235 psi and with standard connection fittings rated to 150 psi. These items are included in the budget analyses and shown in this report.

We strongly advise against the use of waterworks check valves as they are not rated for sewage environments. We do not like to recommend brass due to concerns for corrosion. **WEF Manual of Practice FD-12, Second Edition**, page 45 speaks to the limited success of brass or bronze alloys.

"Besides corrosion considerations, brass is subject to de-alloying, while some bronze, such as 85-5-5, will give better performance. The terms *brass* and *bronze* are used loosely, despite having different meanings; the engineer is advised to evaluate these materials with caution."

We have also seen PVC body check valves with pressure rating to 150 psi that do not have the same rating for back pressure on the check valve. This can result in damage to the check valve and pumping issues as the check valve disc can become dislodged under pressure and then become a line obstruction.

Corporation Stops/ Mainline Connections

Connections to the main pressure line do not require WYE type fittings. We commonly use a TEE or saddle connection. We isolate each connection to the main line with a stainless steel corporation value in the same manner used for other utilities such as gas and water services.

We recommend that the service laterals connect to the mainline and do not need to enter a cleanout manhole or other structure. These connections are very similar to a connection of a water service off of a water main.



273 Weymouth Street, Rockland, MA 02370 tel. 781-982-9300 · fax. 781-982-1056 www.frmahony.com • www.amphidrome.com info@frmahony.com

#### **Budget Notes**

We show our outdoor Model DH071-93 station. We show this model in our budget we can formally quote when project gets closer. Please note budget does not include freight.

Costs of pipeline excavation and pump installation are best obtained from sources in your region. You may be better able to determine these costs.

I am looking forward to working with you on this and future projects. Please contact me if you have any questions or require additional information.

Best regards, Daryl Coppola **Outside Sales Engineer** 781-820-5808 dcoppola@frmahony.com Enclosures S R E



273 Weymouth Street, Rockland, MA 02370 tel. 781-982-9300 · fax. 781-982-1056 www.frmahony.com • www.amphidrome.com info@frmahony.com



This image shows the typical layout of an outdoor pump unit for single-family home use. The pump unit is furnished complete, ready for installation. The installer needs to confirm the power cord length and discharge and inlet configuration. Standard products are supplied with 32 foot power supply cable. Standard inlets are 4-inch Schedule 40 Grommets (@ zero degrees) with 1-1/4 inch discharge (@ 180 degrees). Other configurations are available.



SERVICE OPERATIONS

30 DuPaul Street Southbridge, MA 01550

D: (508) 765-0051 F: (508) 765-1244



This detail is shown as a concept sketch when major grade adjustments are required. We recommend that smaller inlet lines match the crown of outlet gravity sewer lines in all cases in order to direct flow to properly drain to the gravity sewer

#### water supply and pollution control equipment



273 Weymouth Street, Rockland, MA 02370 tel. 781-982-9300 • fax. 781-982-1056 www.frmahony.com • www.amphidrome.com info@frmahony.com



F.R. MAHONY & ASSOC.

Standard alarm panels are the Sentry® panel mounted outside of the home as shown in the drawing (above).

Options include emergency generator connection (see photo) and Redundant alarm Remote Sentry® panel shown. Other panel configurations are available. See the partial listing of panel options below.



- Basic Panels include circuit breaker for the pump and separate breaker for the alarm. These panels include alarm light, alarm buzzer and alarm silence button. All F. R. Mahony panels are equipped with dry contacts to enable the connection of the Remote Sentry® (battery powered redundant alarm panel option)
- Standard options include auto transfer generator connection shown above. This panel provides automatic power transfer without having to open the alarm panel or having to operate any manual transfer switching. This feature can be added to the basic panel or the panels offered below.
- Popular options include the "Protection Package" which monitors and protects the system from:

- Pump Run Dry Condition (Pump running out of water)
- Pump Overpressure Condition (Closed valve)
- Brownout Condition (Main voltage under 12% of nameplate)
- High Liquid Level

- The "**Protect Plus**" panel features offer the same items in the "Protection Package" plus the following:
  - High & Low Amperage draw by the pump
  - High & Low voltage to the pump
  - Extended Runtime by the pump (indicating wear or excessive flow) (field adjustable settings)
  - Monitoring of:
    - Real-time Pump Voltage and Current
    - Cycles & Hours (can be reset)
    - Minimum & Maximum Amperage (can be reset)
    - Minimum, Maximum, Average, and Last Run Cycle (in minutes, can be reset)

# F.R. MAHONY & ASSOC. water supply and pollution control equipment



273 Weymouth Street, Rockland, MA 02370 tel. 781-982-9300 • fax. 781-982-1056 www.frmahony.com • www.amphidrome.com info@frmahony.com

#### **Emergency Generator Transfer Options.**

The indoor pump units may be furnished with a receptacle for connection of emergency power supplies. The image to the right shows the connection receptacle on the right side of our Sentry panels. This connection may be connected by your electrician to a remote connection port outside of the home.





trme

Wiring must be performed by a licensed electrician and conforming to NEC and local electrical codes.

The box (left) is shown in the face view (face up) and is intended to be mounted on the outside wall to permit connection of a portable generator to the receptacle on the bottom. Generator operation must always be in well ventilated areas outside of any living space.

The pump may be operated under emergency power provided the automatic transfer option is selected with the Sentry® panel. Normal pump run times are short and should not require the continuous connection of a generator. A single portable generator may be used to

service several homes effectively.



SERIES







273 Weymouth Street, Rockland, MA 02370 tel. 781-982-9300 · fax. 781-982-1056 www.frmahony.com • www.amphidrome.com info@frmahony.com

Other station configurations are available for higher flow requirements. Please contact us for more information. Additional information may be found at www.eone.com

#### Model DH071-93 Outdoor Pump With Bal-Last<sup>TM</sup>



The outdoor model is complete - ready for installation and connection to exterior plumbing and power supply. This unit is fully tested for operation and factory leak tested. No assembly is required and there are no floats to adjust. The pump is furnished complete with the alarm panel and direct bury power supply cable. Standard cable length is 32 feet with 50, 75, and 100

and up to 150 foot cables available. (See Alarm Panel options above)

#### water supply and pollution control equipment



A Division Of

273 Weymouth Street, Rockland, MA 02370 tel. 781-982-9300 • fax. 781-982-1056 www.frmahony.com • www.amphidrome.com info@frmahony.com

**Operation Conditions** 

**11.12** Feet is the highest TDH at simultaneous operating conditions with the expected number of pumps operating in each zone, or the head of an individual pump operating in a single zone condition.

Operating range of E/One pumps from 0-185 feet TDH and from 0 to -60 feet TDH. Your System Range

Anti-siphon valves in E/One cores provide for negative head pumping. In common systems with negative heads of 25-30 feet or more we recommend the use of combination air/vacuum release valves as described below.





Environment One Corporation

D: (508) 765-0051 F: (508) 765-1244

# L

SERVICE OPERATIONS

*30 DuPaul Street Southbridge, MA 01550* 





Cleanout detail can be modified to match typical installation needs. Inline shut offs may be added to isolate flow direction. Image shown is flow through cleanout. These structures can be terminal end of line cleanouts, or junction cleanouts as may be required. Optional air and vacuum relief valves may be added when required.

# **GENERAL INFORMATION**

OWNER MAP 229 LOT 1 ARTWILL, LLC P.O. BOX 370 PORTSMOUTH, NH 03802

APPLICANT MAP 229 LOT 1 ARTWILL, LLC P.O. BOX 370 PORTSMOUTH, NH 03802

PREPARED FOR MAP 229 LOT 1 ARTWILL, LLC P.O. BOX 370 PORTSMOUTH, NH 03802

# **RESOURCE LIST**

PLANNING/ZONING DEPARTMENT 1 JUNKINS AVE PORTSMOUTH, NH 03801 603-610-7216

BUILDING DEPARTMENT JUNKINS AVE PORTSMOUTH, NH 03801 603-610-7243 ROBERT MARSILIA, CHIEF BUILDING INSPECTOR

PUBLIC WORKS 600 PEVERLY HILL RD PORTSMOUTH, NH 03801 603-472-1530 PETER RICE, PUBLIC WORKS DIRECTOR

POLICE DEPARTMENT 3 JUNKINS AVE PORTSMOUTH, NH 03801 603-427-1510 MARK NEWPORT, CHIEF

FIRE DEPARTMENT 170 COURT ST PORTSMOUTH, NH 03801 603-427-1515 PATRICK HOWE, CHIEF

ASSOCIATED PROFESSIONALS ARCHITECT SMITHFIELD CONSTRUCTION, INC. PO BOX 370 PORTSMOUTH, NH 03802 603-674-5204



Copyright 2022 ©TFMoran, Inc. 48 Constitution Drive, Bedford, N.H. 03110

All rights reserved. These plans and materials may not be copied, duplicated, replicated or otherwise reproduced in any form whatsoeve without the prior written permission of TFMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of FMoran, Inc.



# PROPOSED 3 LOT SUBDIVISION

# **437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

# **APRIL 19, 2022** LAST REVISED: MAY 25, 2022

# VICINITY PLAN



1	5/23/2022	UPDATE LAST REVISED DATE.
REV	DATE	DESCRIPTION

DR CK

THESE PLANS ARE PERMIT DRAWINGS ONLY AND HAVE NOT BEEN DETAILED FOR CONSTRUCTION OR BIDDING.

	INDEX OF SHEETS
SHEET	SHEET TITLE
C-00	COVER
C-01	NOTES & LEGEND
S-01	EXISTING CONDITIONS PLAN
S-02	SUBDIVISION PLAN
C-02	SITE PREPARATION & DEMOLITION PLAN
C-03	SITE LAYOUT PLAN
C-04	GRADING & DRAINAGE PLAN
C-05	UTILITY PLAN
C-06	LANDSCAPE PLAN
C-07	EROSION CONTROL PLAN
C-08	EROSION CONTROL NOTES
C-09	TRUCK TURNING PLAN
C-10 - C-15	DETAILS
REFERENCE PLANS B	Y ASSOCIATED PROFESSIONALS
_	ARCHITECTURAL ELEVATION PLAN

# PERMITS/APPROVALS

	NUMBER	APPROVED	EXPIRES
CITY PLANNING BOARD SITE PLAN REVIEW	_	_	_
CITY PLANNING BOARD SUBDIVISION REVIEW	-	-	_
CITY PLANNING BOARD CONDITIONAL USE PERMIT FOR AADU	-	_	_
NHDES SEWER CONNECTION PERMIT	_	_	_





W/

CONTACT DIG SAFE 72 BUSINESS HOURS PRIOR TO CONSTRUCTION

WITH

FMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of

# **GENERAL NOTES**

- 1. THESE PLANS ARE PERMIT DRAWINGS ONLY AND HAVE NOT BEEN DETAILED FOR CONSTRUCTION OR BIDDING.
- 2. THESE PLANS WERE PREPARED UNDER THE SUPERVISION OF A LICENSED PROFESSIONAL ENGINEER. TFMORAN, INC. ASSUMES NO LIABILITY AS A RESULT OF ANY CHANGES OR NON-CONFORMANCE WITH THESE PLANS EXCEPT UPON THE WRITTEN APPROVAL OF THE ENGINEER OF RECORD.
- 3. THE SUBDIVISION PLAN SHALL BE RECORDED IN THE ROCKINGHAM COUNTY REGISTRY OF DEEDS.
- 4. ALL IMPROVEMENTS SHOWN ON THE SITE PLAN SHALL BE CONSTRUCTED AND MAINTAINED IN ACCORDANCE WITH THE PLAN BY THE PROPERTY OWNER AND ALL FUTURE PROPERTY OWNERS. NO CHANGES SHALL BE MADE TO THIS SITE PLAN WITHOUT THE EXPRESS APPROVAL OF THE CITY PLANNING BOARD.
- 5. ALL WORK SHALL CONFORM TO THE APPLICABLE REGULATIONS AND STANDARDS OF THE CITY OF PORTSMOUTH, AND SHALL BE BUILT IN A WORKMANLIKE MANNER IN ACCORDANCE WITH THE PLANS AND SPECIFICATIONS, ALL WORK TO CONFORM TO CITY OF PORTSMOUTH DEPARTMENT OF PUBLIC WORKS STANDARD SPECIFICATIONS. ALL WORK WITHIN THE RIGHT-OF-WAY OF THE CITY AND/OR STATE SHALL COMPLY WITH APPLICABLE STANDARDS. COORDINATE ALL WORK WITHIN THE RIGHT-OF-WAY WITH APPROPRIATE CITY, COUNTY, AND/OR STATE AGENCY.
- 6. THE SITE CONTRACTOR SHALL ENSURE THAT ALL WORK IS PERFORMED IN ACCORDANCE WITH APPLICABLE SECTIONS OF ENV-WQ 1500. THE SITE CONTRACTOR SHALL NOTIFY THE ENGINEER IN ADVANCE OF CONSTRUCTION OF EACH STORMWATER FACILITY TO COORDINATE REQUIRED INSPECTIONS. THE CONTRACTOR SHALL TAKE PROGRESS PHOTOS DURING CONSTRUCTION OF ALL STORMWATER DRAINAGE COMPONENTS AND SEND TO THE ENGINEER.
- 7. SEE EXISTING CONDITIONS PLAN FOR THE HORIZONTAL AND VERTICAL DATUM.
- 8. SEE EXISTING CONDITIONS PLAN FOR BENCHMARK INFORMATION. VERIFY TBM ELEVATIONS PRIOR TO CONSTRUCTION.
- 9. CONTACT EASEMENT OWNERS PRIOR TO COMMENCING ANY WORK WITHIN THE EASEMENTS.
- 10. PRIOR TO COMMENCING ANY SITE WORK, ALL LIMITS OF WORK SHALL BE CLEARLY MARKED IN THE FIELD.
- 11. SITE WORK SHALL BE CONSTRUCTED FROM A COMPLETE SET OF PLANS, NOT ALL FEATURES ARE DETAILED ON EVERY PLAN. THE ENGINEER IS TO BE NOTIFIED OF ANY CONFLICT WITHIN THIS PLAN SET.
- 12. TFMORAN, INC. ASSUMES NO LIABILITY FOR WORK PERFORMED WITHOUT AN ACCEPTABLE PROGRAM OF TESTING AND INSPECTION AS APPROVED BY THE ENGINEER OF RECORD.
- 13. TEMPORARY FENCING SHALL BE PROVIDED AND COVERED WITH A FABRIC MATERIAL TO CONTROL DUST MITIGATION.
- 14. ALL DEMOLITION SHALL INSURE MINIMUM INTERFERENCE WITH ROADS, STREETS, WALKWAYS, AND ANY OTHER ADJACENT OPERATING FACILITIES. PRIOR WRITTEN PERMISSION FROM THE OWNER/DEVELOPER AND LOCAL PERMITTING AUTHORITY IS REQUIRED IF CLOSURE/OBSTRUCTIONS TO ROADS, STREET, WALKWAYS, AND OTHERS IS DEEMED NECESSARY. CONTRACTOR TO PROVIDE ALTERNATE ROUTES AROUND CLOSURES/OBSTRUCTIONS PER LOCAL/STATE/FEDERAL REGULATIONS.
- 15. REFER TO ARCHITECTURAL PLANS FOR LAYOUT OF BUILDING FOUNDATIONS AND CONCRETE ELEMENTS WHICH ABUT THE BUILDING SUCH AS STAIRS, SIDEWALKS, LOADING DOCK RAMPS, PADS, AND COMPACTOR PADS. DO NOT USE SITE PLANS FOR LAYOUT OF FOUNDATIONS.
- 16. IN THE EVENT OF A CONFLICT BETWEEN PLANS, SPECIFICATIONS, AND DETAILS, THE ENGINEER SHALL BE NOTIFIED IMMEDIATELY FOR CLARIFICATION.
- 17. IF CONDITIONS AT THE SITE ARE DIFFERENT THAN SHOWN ON THE PLANS, THE ENGINEER SHALL BE NOTIFIED PRIOR TO PROCEEDING WITH THE AFFECTED WORK.
- 18. CONTRACTOR'S GENERAL RESPONSIBILITIES:
- A. BID AND PERFORM THE WORK IN ACCORDANCE WITH ALL LOCAL, STATE, AND NATIONAL CODES, SPECIFICATIONS, REGULATIONS, AND STANDARDS AND CONDITIONS OF ALL PROJECT-SPECIFIC PERMITS AND APPROVALS AS LISTED ON THE COVER SHEET TO THESE PLANS OR OTHERWISE REQUIRED.
- B. NOTIFY ENGINEER IN WRITING OF ANY DISCREPANCIES OF PROPOSED LAYOUT AND/OR EXISTING FEATURES.
- C. EMPLOY A LICENSED SURVEYOR TO DETERMINE ALL LINES AND GRADES AND LAYOUT OF SITE ELEMENTS AND BUILDINGS.
- D. THE CONTRACTOR SHALL BE RESPONSIBLE TO BECOME FAMILIAR WITH THE SITE AND ALL SURROUNDING CONDITIONS. THE CONTRACTOR SHALL ADVISE THE APPROPRIATE AUTHORITY OF INTENTIONS AT LEAST 48 HOURS IN ADVANCE.
- E. TAKE APPROPRIATE MEASURES TO REDUCE, TO THE FULLEST EXTENT POSSIBLE, NOISE, DUST, AND UNSIGHTLY DEBRIS. CONSTRUCTION ACTIVITIES SHALL BE CARRIED OUT BETWEEN THE HOURS OF 7:00 AM AND 9:00 PM, MONDAY THROUGH FRIDAY IN ACCORDANCE WITH THE APPLICABLE MUNICIPAL ORDINANCES AND REGULATIONS OF THE CITY OF PORTSMOUTH, NEW HAMPSHIRE.
- F. MAINTAIN EMERGENCY ACCESS TO ALL AREAS AFFECTED BY WORK AT ALL TIMES.
- G. IN ACCORDANCE WITH RSA 430:53 AND AGR 3800, THE CONTRACTOR SHALL NOT TRANSPORT INVASIVE SPECIES OFF THE PROPERTY, AND SHALL DISPOSE OF INVASIVE SPECIES ON-SITE IN A LEGAL MANNER.
- H. COORDINATE WITH ALL UTILITY COMPANIES AND CONTACT DIGSAFE (811 OR 888-344-7233) AT LEAST 72 HOURS PRIOR TO ANY EXCAVATION.
- I. PROTECT NEW AND EXISTING BURIED UTILITIES DURING INSTALLATION OF ALL SITE ELEMENTS. DAMAGED UTILITIES SHALL BE REPAIRED OR REPLACED AT NO ADDITIONAL COST TO THE OWNER.
- J. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE MEANS AND METHODS OF CONSTRUCTION AND FOR CONDITIONS AT THE SITE. THESE PLANS, PREPARED BY TFMORAN, INC., DO NOT EXTEND TO OR INCLUDE SYSTEMS PERTAINING TO THE SAFETY OF THE CONSTRUCTION CONTRACTOR OR THEIR EMPLOYEES, AGENTS, OR REPRESENTATIVES IN THE PERFORMANCE OF THE WORK. THE SEAL OF THE SURVEYOR OR ENGINEER HEREON DOES NOT EXTEND TO ANY SUCH SAFETY SYSTEMS THAT MAY NOW OR HEREAFTER BE INCORPORATED INTO THESE PLANS. THE CONSTRUCTION CONTRACTOR SHALL PREPARE OR OBTAIN THE APPROPRIATE SAFETY SYSTEMS WHICH MAY BE REQUIRED BY THE US OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA) AND/OR LOCAL REGULATIONS.
- K. WRITTEN DIMENSIONS HAVE PRECEDENCE OVER SCALED DIMENSIONS. THE CONTRACTOR SHALL USE CAUTION WHEN SCALING REPRODUCED PLANS. IN CASE OF CONFLICT BETWEEN THIS PLAN SET AND ANY OTHER DRAWING AND/OR SPECIFICATION, THE ENGINEER SHALL BE NOTIFIED IMMEDIATELY FOR CLARIFICATIONS.
- L. VERIFY LAYOUT OF PROPOSED BUILDING FOUNDATIONS WITH ARCHITECT AND THAT PROPOSED FOUNDATION MEETS PROPERTY LINE AND/OR WETLAND SETBACKS PRIOR TO COMMENCING ANY FOUNDATION CONSTRUCTION.
- M. PROVIDE AN AS-BUILT PLAN AT THE COMPLETION OF THE PROJECT TO THE PLANNING DIRECTOR AND PER CITY REGULATIONS.
- N. IF ANY DEVIATIONS FROM THE APPROVED PLANS AND SPECIFICATIONS HAVE BEEN MADE, THE SITE CONTRACTOR SHALL PROVIDE AS-BUILT DRAWINGS STAMPED BY A LICENSED SURVEYOR OR QUALIFIED ENGINEER ALONG WITH A LETTER STAMPED BY A QUALIFIED ENGINEER DESCRIBING ALL SUCH DEVIATIONS, AND BEAR ALL COSTS FOR PREPARING AND FILING ANY NEW PERMITS OR PERMIT AMENDMENTS THAT MAY BE REQUIRED.
- O. AT COMPLETION OF CONSTRUCTION, THE SITE CONTRACTOR SHALL PROVIDE A LETTER CERTIFYING THAT THE PROJECT WAS COMPLETED IN ACCORDANCE WITH THE APPROVED PLANS AND SPECIFICATIONS, AND A LETTER STAMPED BY A QUALIFIED ENGINEER THAT THEY HAVE OBSERVED ALL UNDERGROUND DETENTION SYSTEMS, INFILTRATION SYSTEMS, OR FILTERING SYSTEMS PRIOR TO BACKFILL, AND THAT SUCH SYSTEMS CONFORM TO THE APPROVED PLANS AND SPECIFICATIONS.

# **GRADING & DRAINAGE NOTES**

- 1. THE CONTRACTOR SHALL PREPARE, MAINTAIN, AND EXECUTE A S.W.P.P.P. IN ACCORDANCE WITH EPA REGULATIONS AND THE CONSTRUCTION GENERAL PERMIT.
- 2. THE CONTRACTOR SHALL COORDINATE WITH THE OWNER TO SUBMIT AN ENOI AT LEAST 14 DAYS IN ADVANCE OF ANY EARTHWORK ACTIVITIES AT THE SITE.
- 3. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO CHECK THE ACCURACY OF THE TOPOGRAPHY AND REPORT ANY DISCREPANCIES TO THE ENGINEER PRIOR TO ANY EARTHWORK BEING PERFORMED ON THE SITE. NO CLAIM FOR EXTRA WORK WILL BE CONSIDERED FOR PAYMENT AFTER EARTHWORK HAS COMMENCED.
- 4. THE CONTRACTOR SHALL REFER TO THE GEOTECHNICAL REPORT FOR INFORMATION ABOUT SOIL AND GROUNDWATER CONDITIONS. THE CONTRACTOR SHALL FOLLOW THE GEOTECHNICAL ENGINEER'S RECOMMENDED METHODS TO ADDRESS ANY SOIL AND GROUNDWATER ISSUES THAT ARE FOUND ON SITE, INCLUDING AND NOT LIMITED TO DEWATERING METHODS, PERIMETER DRAINS AND TIE INTO STORMWATER MANAGEMENT SYSTEM, ETC.
- 5. COORDINATE WITH GEOTECHNICAL/STRUCTURAL PLANS FOR SITE PREPARATION AND OTHER BUILDING INFORMATION.
- COORDINATE WITH ARCHITECTURAL PLANS FOR DETAILED GRADING AT BUILDING, AND SIZE AND LOCATION OF ALL BUILDING SERVICES.
- 7. COORDINATE WITH MECHANICAL AND PLUMBING PLANS FOR ROOF DRAIN INFORMATION.
- 8. LIMITS OF WORK ARE SHOWN AS APPROXIMATE. THE CONTRACTOR SHALL COORDINATE ALL WORK TO PROVIDE SMOOTH TRANSITIONS. THIS INCLUDES GRADING, PAVEMENT, CURBING, SIDEWALKS, AND ALIGNMENTS.
- 9. THE CONTRACTOR SHALL PROVIDE A FINISH PAVEMENT SURFACE FREE OF LOW SPOTS AND PONDING AREAS. CRITICAL AREAS INCLUDE BUILDING ENTRANCE, RAMPS, AND LOADING AREAS
- 10. THE SITE SHALL BE GRADED SO ALL FINISHED PAVEMENT HAS POSITIVE DRAINAGE AND SHALL NOT POND WATER DEEPER THAN 1/4" FOR A PERIOD OF MORE THAN 15 MINUTES AFTER FLOODING.
- 11. ALL ELEVATIONS SHOWN AT CURB ARE TO THE BOTTOM OF CURB UNLESS OTHERWISE NOTED. CURBS HAVE A 6" REVEAL UNLESS OTHERWISE NOTED.
- 12. ALL SIDEWALK AND OTHER CURB REVEALS SHALL BE 6" WITH A TOLERANCE OF PLUS OR MINUS 3/8". WHERE SIDEWALK IS TO BE FLUSH. THE PAVEMENT REVEAL SHALL BE 1/4" WITH A TOLERANCE OF 1/8".
- 13. ADJUST ALL MANHOLES, CATCH BASINS, CURB BOXES, ETC. WITHIN LIMITS OF WORK TO FINISH GRADE PRIOR TO INSTALLATION OF FINISHED PAVEMENT.
- 14. ROAD AND DRAINAGE CONSTRUCTION SHALL CONFORM TO THE DETAILS SHOWN ON THE PLANS AND SHALL MEET LOCAL STANDARDS AND THE REQUIREMENTS OF THE LATEST NHDOT STANDARD SPECIFICATIONS FOR ROADS AND BRIDGE CONSTRUCTION AND THE NHDOT STANDARD STRUCTURE DRAWINGS UNLESS OTHERWISE NOTED.
- 15. STORMWATER DRAINAGE SYSTEM SHALL BE CONSTRUCTED TO LINE AND GRADE AS SHOWN ON THE PLANS. CONSTRUCTION METHODS SHALL CONFORM TO NHDOT STANDARD SPECIFICATIONS, SECTION 603. CATCH BASINS AND DRAIN MANHOLES SHALL CONFORM TO SECTION 604. ALL CATCH BASIN GRATES SHALL BE TYPE B AND CONFORM TO NHDOT STANDARDS AND SPECIFICATIONS UNLESS OTHERWISE NOTED.
- 16. NO FILL SHALL BE PLACED IN ANY WETLAND AREA.
- 17. ALL EXCAVATIONS SHALL BE THOROUGHLY SECURED ON A DAILY BASIS BY THE CONTRACTOR AT THE COMPLETION OF CONSTRUCTION OPERATIONS IN THE IMMEDIATE AREA.
- 18. ALL DISTURBED AREAS NOT TO BE PAVED OR OTHERWISE TREATED SHALL RECEIVE 6" LOAM, SEED, FERTILIZER, AND MULCH.

19. DENSITY REQUIREMENTS: MINIMUM DENSITY\* 95%

95%

90%

LOCATION BELOW PAVED OR CONCRETE AREAS TRENCH BEDDING MATERIAL AND SAND BLANKET BACKFILL BELOW LOAM AND SEED AREAS

\*ALL PERCENTAGES OF COMPACTION SHALL BE OF THE MAXIMUM DRY DENSITY AT THE OPTIMUM MOISTURE CONTENT AS DETERMINED AND CONTROLLED IN ACCORDANCE WITH ASTM D-1557, METHOD C. FIELD DENSITY TESTS SHALL BE MADE IN ACCORDANCE WITH ASTM D-1556 OR ASTM D-6938.

		Pinnin
REV	DATE	DESCRIPTION

SEDIMENT OIL SEPARATOR TAPPING SLEEVE, VALVE, AND BOX

SMH

SOS

TSV

SEWER MANHOLE

UTILITY POLF

# UTILITY NOTES

1. LENGTH OF PIPE IS FOR CONVENIENCE ONLY. ACTUAL PIPE LENGTH SHALL BE DETERMINED IN THE FIELD.

2. ALL PROPOSED UTILITY WORK, INCLUDING MATERIAL, INSTALLATION, TERMINATION, EXCAVATION, BEDDING, BACKFILL, COMPACTION, TESTING, CONNECTIONS, AND CONSTRUCTION SHALL BE COORDINATED WITH AND COMPLETED IN ACCORDANCE WITH THE APPROPRIATE REQUIREMENTS, CODES, AND STANDARDS OF ALL CORRESPONDING UTILITY ENTITIES AND SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.

3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING AND DETERMINING THE LOCATION, SIZE, AND ELEVATION OF ALL EXISTING UTILITIES, SHOWN OR NOT SHOWN ON THESE PLANS, PRIOR TO THE START OF ANY CONSTRUCTION. THE ENGINEER SHALL BE NOTIFIED IN WRITING OF ANY UTILITIES FOUND INTERFERING WITH THE PROPOSED CONSTRUCTION AND APPROPRIATE REMEDIAL ACTION BE AGREED TO BY THE ENGINEER BEFORE PROCEEDING WITH THE WORK. THE CONTRACTOR SHALL BE RESPONSIBLE TO CONTACT "DIGSAFE" (811) AT LEAST 72 HOURS BEFORE DIGGING.

4. COORDINATE ALL WORK ADJACENT TO PROPOSED BUILDINGS WITH ARCHITECTURAL BUILDING DRAWINGS. CONFIRM UTILITY PENETRATIONS AND INVERT ELEVATIONS ARE COORDINATED PRIOR TO INSTALLATION.

5. THE CONTRACTOR SHALL CONTACT ALL UTILITY COMPANIES OWNING UTILITIES, EITHER OVERHEAD OR UNDERGROUND, WITHIN THE CONSTRUCTION AREA AND SHALL COORDINATE AS NECESSARY WITH THE UTILITY COMPANIES OF SAID UTILITIES. THE PROTECTION OR RELOCATION OF UTILITIES IS ULTIMATELY THE RESPONSIBILITY OF THE CONTRACTOR.

6. THE EXACT LOCATION OF NEW UTILITY CONNECTIONS SHALL BE DETERMINED BY THE CONTRACTOR IN COORDINATION WITH UTILITY COMPANY, COUNTY AGENCY, AND/OR PRIVATE UTILITY COMPANY.

7. THE CONTRACTOR SHALL PROVIDE AND INSTALL ALL MANHOLES, BOXES, FITTINGS, CONNECTORS, COVER PLATES, AND OTHER MISCELLANEOUS ITEMS NOT NECESSARILY DETAILED ON THESE DRAWINGS TO RENDER THE UTILITY INSTALLATION COMPLETE AND OPERATIONAL

8. ALL UTILITY COMPANIES REQUIRE INDIVIDUAL CONDUITS. CONTRACTOR TO COORDINATE WITH TELEPHONE, CABLE, AND ELECTRIC COMPANIES REGARDING NUMBER, SIZE, AND TYPE OF CONDUITS REQUIRED PRIOR TO INSTALLATION OF ANY CONDUIT.

- 9. SANITARY SEWER SHALL BE CONSTRUCTED TO THE STANDARDS AND SPECIFICATIONS AS SHOWN ON THESE PLANS. ALL SEWER MAINS AND FITTINGS SHALL BE PVC AND SHALL CONFORM TO ASTM F 679 (SDR 35 MINIMUM). FORCE MAINS AND FITTINGS SHALL CONFORM TO NH CODE OF ADMINISTRATIVE RULES ENV-WQ 700. ALL SEWER CONSTRUCTION SHALL BE IN ACCORDANCE WITH NH CODE OF ADMINISTRATIVE RULES ENV-WQ 700. SANITARY MANHOLES SHALL CONFORM TO NHDES WATER DIVISION WASTEWATER ENGINEERING BUREAU STANDARDS AND SPECIFICATIONS SHOWN HEREON.
- 10. ON-SITE WATER DISTRIBUTION SHALL BE TO CITY OF PORTSMOUTH STANDARDS AND SPECIFICATIONS. WATER MAINS SHALL HAVE A MINIMUM OF 5.5' COVER. WHERE WATER PIPES CROSS SEWER LINES A MINIMUM OF 18" VERTICAL SEPARATION BETWEEN THE TWO OUTSIDE PIPE WALLS SHALL BE OBSERVED. HORIZONTAL SEPARATION BETWEEN WATER AND SEWER SHALL BE 10' MINIMUM. WHERE A SANITARY LINE CROSSES A WATER LINE, SEWER LINE MUST BE CONSTRUCTED OF FORCE MAIN MATERIALS (PER ENV-WQ 704.08) FROM BUILDING OR MANHOLE TO MANHOLE, OR SUBSTITUTE RUBBER-GASKETED PRESSURE PIPE FOR THE SAME DISTANCE. WHEN SANITARY LINES PASS BELOW WATER LINES, LAY PIPE SO THAT NO JOINT IN THE SANITARY LINE WILL BE CLOSER THAN 6' HORIZONTALLY TO THE WATER LINE
- 11. THRUST BLOCKS SHALL BE PROVIDED AT ALL LOCATIONS WHERE WATER LINE CHANGES DIRECTIONS OR CONNECTS TO ANOTHER WATER LINE.
- 12. THE GENERAL CONTRACTOR IS RESPONSIBLE FOR CONDUIT AND WIRING TO ALL SIGNS AND LIGHTS. CONDUIT TO BE A MINIMUM OF 24" BELOW FINISH GRADE.
- 13. ALL PROPOSED UTILITIES SHALL BE UNDERGROUND. ALL UNDERGROUND CONDUITS SHALL HAVE NYLON PULL ROPES.
- 14. THE CONTRACTOR SHALL ARRANGE AND PAY FOR ALL INSPECTIONS. TESTING, AND RELATED SERVICES AND SUBMIT COPIES OF ACCEPTANCE TO THE OWNER, UNLESS OTHERWISE INDICATED.
- 15. PROVIDE PERMANENT PAVEMENT REPAIR FOR ALL UTILITY TRENCHES IN EXISTING ROAD OR PAVEMENT TO REMAIN. SAW CUT TRENCH, PAVEMENT, AND GRANULAR BASE THICKNESS TO MATCH EXISTING PAVEMENT. OBTAIN ALL PERMITS REQUIRED FOR TRENCHING.
- 16. UNLESS OTHERWISE SPECIFIED, ALL UNDERGROUND STRUCTURES, PIPES, CHAMBERS, ETC. SHALL BE COVERED WITH A MINIMUM OF 18" OF COMPACTED SOIL BEFORE EXPOSURE TO VEHICLE LOADS

17. THE PROPERTY WILL BE SERVICED BY THE FOLLOWING: DRAINAGE PRIVATE

DNAINAGE	E I
SEWER	Μl
WATER	Μl
GAS	١U
ELECTRIC	E١
TELEPHONE	СС
CABLE	CC

**IUNICIPAL** INITIL

INICIPA

VERSOURCE CONSOLIDATED COMMUNICATIONS FKA FAIRPOINT COMMUNICATIONS COMCAST

SITE DEVELOPMENT PLANS TAX MAP 229 LOT 1 **NOTES & LEGEND PROPOSED 3 LOT SUBDIVISION 437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE OWNED BY & PREPARE FOR **ARTWILL**, LLC **APRIL 19, 2022** SCALE: NTS ivil Engineers 48 Constitution Drive tructural Engineers Bedford, NH 03110 ffic Engineers Phone (603) 472-4488 ind Surveyors Fax (603) 472-9747 andscape Architects www.tfmoran.com cientists |45407-120 DR JSM FB C - 0145407-120\_NOTES DR CK



Since James	11	
477516		
A STAL	1.5%	
0.55/ INO.	0.00	
5 S// 844	U.S.	
15×1 1.	123	
A CODEV	1152	
USE COHEY	19	
COLWELL		- 1
		۸ I
	1,001	V)
SIGNATURE	vill	$\sim$
and the second sec		

1	5/25/2022	NO REVISIONS THIS SHEET
REV.	DA TE	DESCRIPTION



SEE UTILTIY NOTES ON SHEET C-01. . CONTRACTOR SHALL COORDINATE WITH CITY OF PORTSMOUTH DPW PRIOR TO CONSTRUCTING SEWER MANHOLE CONNECTION.



TAX MAP 229 LOT 1 UTILITY PLAN

# PROPOSED 3 LOT SUBDIVISION **437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

OWNED BY & PREPARE FOR **ARTWILL, LLC** 

1"=40' (11"X17") SCALE: 1"=20' (22"X34")

**APRIL 19, 2022** 

Civil Engineers Structural Engineers Traffic Engineers Land Surveyors Landscape Architects Scientists

45407-120\_UTILITY

C-05

| 48 Constitution Drive

Bedford, NH 03110

Fax (603) 472-9747

www.tfmoran.com

Phone (603) 472-4488



# PRESSURE SEWER **TESTING NOTES**

- 1. PIPE AND JOINT MATERIALS: MATERIAL
  - BACKFILL REQUIREMENTS.

  - AGAINST CORROSION, SUCH AS WITH CATHODIC PROTECTION.
- HEAD OR AT LEAST 100 PSI.
- 3. DAMAGED PIPE SHALL BE REJECTED AND REMOVED FROM THE JOB SITE.
- SEWER WYE OR AT THE FOUNDATION WALL, APPROPRIATE MANUFACTURED ADAPTERS SHALL BE USED.
- THOROUGHLY TAMPED BY HAND OR WITH APPROPRIATE MECHANICAL DEVICES.
- THE TRENCH.
- SHALL NOT BE PERMITTED.
- A VAULT TO FACILITATE MAINTENANCE.
- 10. WATER SERVICE SHALL NOT BE LAID IN SAME TRENCH AS SEWER SERVICE.
- PLACING BEDDING MATERIAL AND SETTING OF THE BASE OR POURING CONCRETE.



WHERE ORDERED BY THE ENGINEER TO STABILIZE THE TRENCH BASE, SCREENED GRAVEL OR CRUSHED STONE 1/2 INCH TO 1 1/2 INCH SHALL BE USED. 12. LOCATION: THE LOCATION OF THE TEE OR WYE SHALL BE RECORDED AND FILED IN THE MUNICIPAL RECORDS. 13. INTERNAL STEPS IN MANHOLES ARE PROHIBITED PER PORTSMOUTH DPW STANDARDS.



11. BEDDING: SCREENED GRAVEL AND/OR CRUSHED STONE FREE FROM CLAY, LOAM, ORGANIC MATERIAL AND MEETING ASTM C33/C33M STONE SIZE 67 AND FREE FROM CLAY, LOAM AND ORGANNIC MATTER. THE EXCAVATION SHALL BE PROPERLY DEWATERED WHILE

9. PRESSURE SEWERAGE SHALL HAVE AN ISOLATION VALVE OR CURB STOP VALVE INSTALLED AT THE PROPERTY LINE / LIMITED COMMON AREA. IF A CHECK VALVE IS USED AT THE PROPERTY LINE, THE VALVE SHALL BE INSTALLED WITHIN

7. THE CENTERLINE OF ALL BUILDING CONNECTIONS SHALL ENTER THE TOP HALF OF THE SEWER. 8. ILLEGAL CONNECTIONS: NOTHING BUT SANITARY WASTE FLOW FROM TOILETS, SINKS, LAUNDRY ETC. SHALL BE PERMITTED. ROOF LEADERS, FOOTING DRAINS, SUMP PUMPS OR OTHER SIMILAR CONNECTIONS CARRYING RAIN WATER, DRAINAGE OR GROUND WATER

SPECIFIED IN NOTE 11. BEDDING AND RE-FILL FOR DEPTH OF 12 INCHES ABOVE THE TOP OF THE PIPE SHALL BE CAREFULLY AND 6. PIPE JOINTS MUST BE MADE UNDER DRY CONDITIONS. IF WATER IS PRESENT, ALL NECESSARY STEPS SHALL BE TAKEN TO DEWATER

4. JOINTS SHALL BE DEPENDENT UPON A NEOPRENE OR ELASTOMERIC GASKET FOR WATER-TIGHTNESS. ALL JOINTS SHALL BE PROPERLY MATCHED WITH THE PIPE MATERIALS USED. WHERE DIFFERING MATERIALS ARE TO BE CONNECTED, AS AT THE STREET 5. SEWER SERVICE INSTALLATION: THE PIPE SHALL BE HANDLED, PLACED AND JOINTED IN ACCORDANCE WITH INSTALLATION GUIDES OF THE APPROPRIATE MANUFACTURER. IT SHALL BE CAREFULLY BEDDED ON A 6 INCH LAYER OF CRUSHED STONE AND/OR GRAVEL AS

2. TESTING: THE COMPLETED SEWER SERVICE SHALL BE SUBJECTED TO A THIRD PARTY LEAKAGE TEST ANY OF THE FOLLOWING MANNERS: (PRIOR TO BACKFILLING) PRESSURE SEWERS SHALL BE TESTED IN ACCORDANCE WITH SECTION 5 OF THE AWWA C600, "INSTALLATION OF CAST IRON WATER MAINS AND THEIR APPURTENANCES" STANDARD IN EFFECT WHEN THE TEST IS CONDUCTED AT A PRESSURE EQUAL TO THE GREATER OF 150 PERCENT OF THE DESIGN OPERATING TOTAL DYNAMIC

DAMAGE TO AN IRON PIPE, OR OTHERWISE REDUCE THE TYPICAL LIFE EXPECTANCY OF THE PIPE, SUCH AS MAY OCCUR WITH CERTAIN SOIL TYPES, LOW PH LEVELS, OR WATER CONDITIONS, THE PIPE SHALL BE PROTECTED

D. HDPE PIPE USED FOR PRESSURE SEWERS SHALL BE CERTIFIED BY ITS MANUFACTURER AS CONFORMING TO THE ASTM D3035 STANDARD IN EFFECT WHEN THE PIPE IS MANUFACTURED. E. IF DI PIPE IS USED IN AN ENVIRONMENT THAT COULD CAUSE CORROSION OR OTHER DETERIORATION OF OR

C. PVC PIPE USED PRESSURE SEWERS SHALL BE CERTIFIED BY ITS MANUFACTURER AS CONFORMING TO THE ASTM D2241 OR ASTM D1785 STANDARDS IN EFFECT WHEN THE PIPE IS MANUFACTURED.

B. PRESSURE SEWERS SHALL BE TREATED AS GRAVITY SEWERS FOR PURPOSES OF FOUNDATION BEDDING AND

A. PRESSURE SEWERS SHALL BE CONSTRUCTED OF DUCTILE IRON (DI), HIGH DENSITY POLYETHYLENE (HDPE), OR PVC



# **PROPOSED 3 LOT SUBDIVISION 437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

OWNED BY & PREPARE FOR **ARTWILL**, LLC

SCALE: AS SHOWN

**APRIL 19, 2022** 



		SERVIC SUMI DE FOM		TES				
1. 2.	PIPE AND JOINT MATERIA A. PLASTIC SEWER PI	ALS: PE			_	<u></u>		N/////
	1. PIPE AND FIT ASTM STANDARDS	GENERIC PIPE	SIZES APPROVED	andards:				
	D3034 F679 F789 F794 D2680	*PVC (SOLID WALL) PVC (SOLID WALL) PVC (SOLID WALL) PVC (RIBBED WALL) *ABS (COMPOSITES WALL)	8" THROUGH 1 18" THROUGH 2 4" THROUGH 1 8" THROUGH 3 8" THROUGH 1	15" (SDR 35) 27" (T-1 & T-2) 18" (T-1 TO T-3) 36" 15"			SUITABLE	COMPACT 1'LAYEF
	*PVC: PC *ABS: AC	OLY VINYL CHLORIDE CRYLONITRILE-BUTADIENE-STYREN	Ξ				*	
	2. JOINTS SEALS ELASTOMERIC BELL AND SI	S FOR PVC PIPE SHALL BE OIL F C MATERIAL CONFORMING TO ASTM PIGOT TYPE.	RESISTANT COMPRESS 1 D-3212 AND SHAL	SION RINGS OF LL BE PUSH-ON,				
	ABS TRUSS COMPOUNDIN	PIPE AND FITTINGS SHALL CONFO NG SHALL BE TO ASTM D-1788 (	ORM TO ASTM D-268 (CLASS 322).	30, POLYMER			- SAND BLANKET	12" MIN
	JOINTS FOR ACCORDANCE	ABS TRUSS PIPE SHALL BE CHE E WITH ASTM D-2680, FORMING A	MICAL WELDED COUP A CHEMICAL WELDED	PLINGS TYPE SC IN JOINT.				
	B. DUCTILE-IRON PIPI 1. DUCTILE IRON STANDARDS (	E, FITTINGS AND JOINTS. PIPE AND FITTINGS SHALL CONFO OF THE LINITED STATES OF AMER	DRM TO THE FOLLOW	/ING LITLITE				
	A21.50 T A21.51 E	THICKNESS DESIGN OF DUCTILE IF DUCTILE IRON CASTINGS. DUCTILE IRON PIPE, CENTRIFUGALI	RON PIPE AND WITH	ASTM A-536 Molds or			BEDDING	• • • • • • • • • • • • • • • • • • •
	2. JOINTS SHALL SHALL CONF( 421-11-F	SAND-LINED MOLDS FOR WATER BE OF THE MECHANICAL OR PUS ORM TO: RUBBER GASKETS JOINTS FOR CA	OR OTHER LIQUIDS. SH-ON TYPE. JOINTS	S AND GASKETS		BEDDING TO BE TH	IOROUGHLY COMPACTED	<u>♀_</u> <u></u> <u>12" MIN∳(Le</u> (SEE NOTE 10)
3.	DAMAGED PIPE SHALL B	BE REJECTED AND REMOVED FROM	1 THE JOB SITE.		TR	ENCH	CROSS	-SECT
4.	JOINTS SHALL BE DEPEI TIGHTNESS. ALL JOINT DIFFERING MATERIALS FOUNDATION WALL, AI	NDENT UPON A NEOPRENE OR EI IS SHALL BE PROPERLY MATCHED ARE TO BE CONNECTED, AS AT PPROPRIATE MANUFACTURED ADAF	LASTOMERIC GASKET ) WITH THE PIPE MA' THE STREET SEWER PTERS SHALL BE USI	FOR WATER— ITERIALS USED. WHERE WYE OR AT THE ED.				
5.	TEES AND WYES: WHERE APPROPRIATE CONNEC BOLTED, CLAMPED OR OPENING IN THE SEW STUFFING CLOTH OR THE CONNECTION, AN	E A TEE OR WYE IS NOT AVAILAB CTION SHALL BE MADE, FOLLOWIN R EPOXY—CEMENTED SADDLE TAPF (ER. THE PRACTICE OF BREAKING OTHER SUCH MATERIAL AROUND ND ANY OTHER SIMILAR CRUDE PF	LE IN THE EXISTING G MANUFACTURERS' PED INTO A SMOOTHI AN OPENING WITH A THE JOINT, OR APPI RACTICES OR INEPT	STREET SEWER, AN INSTRUCTIONS USING A LY DRILLED OR SAWN A SLEDGE HAMMER, LYING MORTAR TO HOLD OR HASTY IMPROVISATION:	S		2 LAYERS (4" THICI	K) OF 2" x 2' x 8'
	WILL NOT BE PERMIT UP TO AND INCLUDIN	TED. THE CONNECTION SHALL BE NG 15" DIAMETER.	CONCRETE ENCASED	D AS SHOWN IN THE DET.	AIL	1	RIGID STYROFOAM THAN LAYERS (2" THICK) OF	INSULATION IF LESS 5 FEET OF COVER - 2" x 2' x 8' RIGID
6.	SEWER SERVICE INSTALL ACCORDANCE WITH IN CAREFULLY BEDDED C NOTE 10. BEDDING AI CAREFULLY AND THOR	ATION: THE PIPE SHALL BE HANE STALLATION GUIDES OF THE APPF DN A 6 INCH LAYER OF CRUSHED ND RE—FILL FOR DEPTH OF 12 I ROUGHLY TAMPED BY HAND OR W	DLED, PLACED AND J ROPRIATE MANUFACTU D STONE AND/OR GF NCHES ABOVE THE T ITH APPROPRIATE ME	JOINTED IN JRER. IT SHALL BE RAVEL AS SPECIFIED IN TOP OF THE PIPE SHALL ECHANICAL DEVICES.	BE		STYROFOAM INSULATION FEET BUT LESS THAN	IF GREATER THAN 5 I 6 FEET OF COVER -
	THE PIPE SHALL BE I CONNECTION TO THE JOINTS MUST BE MAD SHALL BE TAKEN TO	LAID AT A CONTINUOUS AND CON FOUNDATION AT A GRADE OF NO DE UNDER DRY CONDITIONS. IF W. DEWATER THE TRENCH.	ISTANT GRADE FROM T LESS THAN 1/4" ATER IS PRESENT, A	THE STREET SEWER INCH PER FOOT. PIPE ILL NECESSARY STEPS			UNDISTURBED	SOIL
7.	TESTING: THE COMPLETE ANY OF THE FOLLOWING	ED SEWER SERVICE SHALL BE SU G MANNERS: (PRIOR TO BACKFILLI	BJECTED TO A THIRE NG)	D PARTY LEAKAGE TEST IN	N			ţ
	A. AN OBSERVATION T INFLATABLE BLADDE TEE. AFTER INFLATI HEIGHT OF 5 FEET	TEE SHALL BE INSTALLED AS SHO ER OR PLUG SHALL BE INSERTED ION, WATER SHALL BE INTRODUCE ABOVE THE LEVEL OF THE PLUC	WN AND WHEN REAL JUST UPSTREAM FR D INTO THE SYSTEM G.	DY FOR TESTING, AN ROM THE OPENING IN THE I ABOVE THE PLUG TO A	Ξ			<b>▲</b>
	B. THE PIPE SHALL E NEARLY AS POSSI SHALL BE PERMIT BE MADE THROUG	BE LEFT EXPOSED AND LIBERALLY BELE, WET TRENCH CONDITIONS O TED TO RISE IN THE TRENCH OV SH THE CLEANOUT WITH A FLASHL	' HOSED WITH WATEF R, IF TRENCH IS WE ER THE PIPE. INSPE IGHT.	R, TO SIMULATE, AS LT, THE GROUND WATER LCTIONS FOR LEAKS SHALI	L			NOTES
	C. DRY FLUORESCENE IS DRY, THE PIPE WATER SHALL BE SHALL BE MADE I	E DYE SHALL BE SPRINKLED INTO SHALL BE LIBERALLY HOSED WI PERMITTED TO RISE IN THE TREM IN THE FIRST DOWN-STREAM MA	) THE TRENCH OVER TH WATER, OR IF TH NCH OVER THE PIPE. ANHOLE.	THE PIPE. IF THE TRENC IE TRENCH IS WET, GROU . OBSERVATION FOR LEAK	CH IND (S			1. GAPS BETWEEN 2' x 2' PIECE
	LEAKAGE OBSERVED II ACCEPTANCE AND THE WATER TIGHTNFSS	N ANY ONE OF THE ABOVE ALTER E PIPE SHALL BE DUG-UP IF NE	RNATE TESTS SHALL CESSARY AND RE-LA	BE CAUSE FOR NON– AID SO AS TO ASSURE			SEWEF	R TRE
8.	ILLEGAL CONNECTIONS: I ETC. SHALL BE PERI CONNECTIONS CARRY	NOTHING BUT SANITARY WASTE FL MITTED. ROOF LEADERS, FOOTING YING RAIN WATER, DRAINAGE OR (	LOW FROM TOILETS, DRAINS, SUMP PUM GROUND WATER SHAI	SINKS, LAUNDRY IPS OR OTHER SIMILAR LL NOT BE PERMITTED.		_		
9.	WATER SERVICE SHALL I	NOT BE LAID IN SAME TRENCH A	S SEWER SERVICE.					
10.	AND MEETING ASTM C 100% PASSIN	NAVEL AND/OK CRUSHED STONE F 233-67. NG 1 INCH SCREEN	NEE FRUM CLAY, LO	Jam, URGANIG MATERIAL				
	90%-100% PASSI 20%-55% PASSI 0%-10% PASSI	NG 3/4 INCH SCREEN NG 3/8 INCH SCREEN ING #4 SIEVE				STREET	► R	THIS PORT
	U%-5% PASSI WHERE ORDERED BY TH STONE 1/2 INCH TO 1	ING #& SIEVE IE ENGINEER TO STABILIZE THE TI 1/2 INCH SHALL BE USED	RENCH BASE, SCREE	NED GRAVEL OR CRUSHE	D		S COUNT WEMENT	
11.	LOCATION: THE LOCATION RECORDS. IN ADDITION	N OF THE TEE OR WYE SHALL BE N, A FERROUS METAL ROD OR P F TYPICAL "CHIMNEY" DETAIL TO	E RECORDED AND FI IPE SHALL BE PLACE	ILED IN THE MUNICIPAL ED OVER THE TEE OR WY IE BURIED PIPE WITH A D	Έ )IP		– cros: /Er – PA	
12.	CHIMNEYS: IF VERTICAL	DROP INTO SEWER IS GREATER T	THAN 4 FEET, A CHII	MNEY SHALL BE	٥٢		M COVER IMUM COV	
	MANUFACTURER MAY	BE USED IF APPROVED BY THE E	ENGINEER.	LOOMMENDED BI THE PH		FF	6' MINIMU	- OBSERVATION TE
					WYE OR T	ES 4 & 5)		
						-		
					$\mathcal{Y}$	<u>Sewer</u>	<u>SERVICE: MIN</u>	IIMUM SLOPE
					STREET SI	EWER		
Co	pyright 2022 ©TFMoran,	, Inc.		DIG SAFE				
48 All du	Constitution Drive, Bed rights reserved. These plicated, replicated or o	ford, N.H. 03110 e plans and materials may not b therwise reproduced in anv form	pe copied, whatsoever				SEW	'ER SE
wit Th	hout the prior written p is plan is not effective Moran, Inc.	unless signed by a duly authori:	zed officer of	ACT DIG Sale 72 Dillouree				
I I ''	*							

COMPACT IN

1'LAYERS

12" MIN.

1/2 OD

S" MIN (FARTH)



# **GENERAL NOTES**

1.	IT IS THE INTENTION THAT THE MANHOLE, INCLUDING ALL COMPONENT PARTS, HAVE ADEQUATE SPACE, STRENGTH AND LEAKPROOF QUALITIES CONSIDERED NECESSARY FOR THE INTENDED SERVICE. SPACE REQUIREMENTS AND CONFIGURATIONS, SHALL BE AS SHOWN ON THE DRAWING. MANHOLES SHALL BE AN ASSEMBLY OF PRECAST SECTIONS, WITH STEEL REINFORCEMENT, WITH ADEQUATE JOINTING, OR CONCRETE CAST MONOLITHICALLY IN PLACE WITH REINFORCEMENT. IN ANY APPROVED MANHOLE, THE COMPLETE STRUCTURE SHALL BE OF SUCH MATERIAL AND QUALITY AS TO WITHSTAND LOADS OF 8 TONS (H-20 LOADING) WITHOUT FAILURE AND PREVENT LEAKAGE IN EXCESS OF ONE GALLON PER DAY PER VERTICAL FOOT OF MANHOLE, CONTINUOUSLY FOR THE LIFE OF THE STRUCTURE. A PERIOD GENERALLY IN EXCESS OF 25 YEARS IS TO BE UNDERSTOOD IN BOTH CASES.	INSIDE FACE OF MAN FORMED OPENING — FILL WITH MORTAR —
2.	BARRELS, CONE SECTIONS AND CONCRETE GRADE RINGS SHALL BE PRECAST REINFORCED CONCRETE AND SHALL CONFORM ENV-WQ 704.12 & 704.13.	
3. 4	PRECAST CONCRETE BARREL SECTIONS, CONES AND BASES SHALL CONFORM TO ASTM C478-06.	
г. Е	CROWN OF THE INCOMING PIPE.	
э. 6.	ALL PRECAST SECTIONS AND BASES SHALL HAVE THE DATE OF MANUFACTURE AND THE NAME OR	INSIDE FACE OF MAN
7.	TRADEMARK OF THE MANUFACTURER IMPRESSED OR INDELIBLY MARKED ON THE INSIDE WALL.	FILL WITH MORTAR -
8	DAMP-PROOFING COATING.	
0.	REINFORCED CONCRETE SLAB COVER MAY BE USED HAVING AN ECCENTRIC ENTRANCE OPENING AND CAPABLE OF SUPPORTING H-20 LOADS.	
9.	HORIZONTAL JOINTS BETWEEN SECTIONS OF PRECAST CONCRETE BARRELS SHALL BE OF AN OVERLAPPING TYPE, SEALED FOR WATERTIGHTNESS USING A DOUBLE ROW OF AN ELASTOMERIC OR MASTIC-LIKE SEALANT. APPROVED ELASTOMERIC SEALANTS ARE: - SIKAFLEX-12-SL	
10.	<ul> <li>SONNEBORN BUILING PRODUCTS-SONOLASTIC SL-1</li> <li>THE MINIMUM INTERNAL DIAMETER OF MANHOLES SHALL BE 48 INCHES. FOR SEWERS LARGER THAN</li> </ul>	
10.	24-INCH DIAMETER. MANHOLE DIAMETERS SHALL BE INCREASED SO AS TO PROVIDE AT LEAST 12-INCHES OF SHELF ON EACH SIDE OF THE SEWER.	INSIDE FACE OF MA
11.	LEAKAGE TEST SHALL BE PERFORMED IN ACCORDANCE TO ENV-WQ 704.17.	POURED OR HAL
	(a) ALL MANHOLES SHALL BE TESTED FOR LEAKAGE USING A VACUUM TEST IN ACCORDANCE WITH THE ASTM C1244 STARNDARD IN EFFECT WHEN THE TESTING IS PERFORMED.	WATERPLUG, EMBE Approved Equa Formed o
	(b) THE MANHOLE VACUUM TEST SHALL CONFORM TO THE FOLLOWING:	TONMED
	<ol> <li>THE INITIAL VACUUM GUAGE TEST PRESSURE SHALL BE 10 INCHES Hg.</li> <li>THE MINIMUM ACCEPTABLE TEST HOLD TIME FOR 1-INCH Hg PRESSURE DROP TO 9 INCHES SHALL BE:</li> </ol>	
	A. NOT LESS THAN 2 MINUTES FOR MANHOLES LESS THAN 10 FEET DEEP.	
	B. NOT LESS THAN 2.5 MINUTES FOR MANHOLES 10 TO 15 FEET DEEP.	
	(c) THE MANHOLE SHALL BE REPAIRED AND RETESTED IF THE TEST HOLD TIMES FAIL TO ACHIEVE THE	
	(d) INVERTS AND SHELVES SHALL NOT BE INSTALLED UNTIL AFTER SUCCESSFUL TESTING IS COMPLETE.	FORMED OPENING -
	(e) FOLLOWING COMPLETION OF THE LEAKAGE TEST, THE FRAME AND COVER SHALL BE PLACED ON TOP OF THE MANHOLE OR SOME OTHER MEANS USED TO PREVENT ACCIDENTAL ENTRY BY UNAUTHORIZED PERSONS, CHILDREN OR ANIMALS, UNTIL THE CONTRACTOR IS READY TO MAKE FINAL ADJUSTMENT TO	
12.	BRICK MASONRY FOR SHELF, INVERT AND GRADE ADJUSTMENT SHALL COMPLY WITH ASTM C32-05, CLAY OR SHALE, FOR GRADE SS HARD BRICK.	
13.	MORTAR SHALL BE COMPOSED OF PORTLAND CEMENT AND SAND WITH OR WITHOUT HYDRATED LIME ADDITION. PROPORTIONS IN MORTAR OF PARTS BY VOLUMES SHALL BE: (a) 4.5 PARTS SAND AND 1.5 PARTS CEMENT; OR (b) 4.5 PARTS SAND, 1 PART CEMENT AND 0.5 PART HYDRATED LIME	INSIDE FACE OF MAN
	CEMENT SHALL BE TYPE II PORTLAND CEMENT CONFORMING TO ASTM C150-05. HYDRATED LIME SHALL BE	
	PURPOSES". SAND SHALL CONSIST OF INERT NATURAL SAND CONFORMING TO ASTM C33-03 "STANDARD SPECIFICATIONS FOR CONCRETE, FINE AGGREGATES".	FILL WITH MORTAR —
14.	INVERTS AND SHELVES: MANHOLES SHALL HAVE A BRICK PAVED OR PRECAST CONCRETE SHELF AND INVERT, CONSTRUCTED TO CONFORM TO THE SIZE OF THE PIPE AND FLOW. AT CHANGES IN DIRECTIONS, THE INVERTS SHALL BE LAID OUT IN CURVES OF THE LONGEST RADIUS POSSIBLE TANGENT TO THE CENTER LINE OF THE SEWER PIPES. SHELVES SHALL BE CONSTRUCTED TO THE ELEVATION OF THE HIGHEST PIPE CROWN AND SLOPE TO DRAIN TOWARD THE FLOWING THROUGH CHANNEL. UNDERLAYMENT OF INVERT AND SHELF SHALL CONSIST OF BRICK MASONRY.	STAINLESS STEEL — INTERNAL CLAMP
15.	FRAMES AND COVERS: FRAMES AND COVERS: SEWER MANHOLE FRAMES AND COVERS SHALL BE CITY OF PORTSMOUTH STANDARD, AND SHALL BE PURCHASED AND PICKED UP AT PORTSMOUTH DEPARTMENT OF PUBLIC WORKS WATER DEPARTMENT. THEY SHALL BE OF HEAVY DUTY DESIGN, CLASS 30, CONFORMING TO ASTM A48/48M AND PROVIDE A 30-INCH CLEAR OPENING. THE CASTING SHALL BE OF EVEN GRAINED CAST IRON, SMOOTH, AND FREE FROM SCALE, LUMPS, BLISTERS, SAND HOLES AND DEFECTS. CONTACT SURFACES OF COVERS AND FRAMES SHALL BE MACHINED AT THE FOUNDRY TO PREVENT ROCKING OF COVERS IN ANY ORIENTATION.	
16.	BEDDING: PRECAST BASES SHALL BE PLACED ON A 6-INCH LAYER OF COMPACTED BEDDING MATERIAL THAT CONFORMS TO ASTM C33-03 NO. 67 STONE AND FREE FROM CLAY, LOAM AND ORGANNIC MATTER. THE EXCAVATION SHALL BE PROPERLY DEWATERED WHILE PLACING BEDDING MATERIAL AND SETTING OF THE BASE OR POURING CONCRETE. WATER-STOPS SHALL BE USED AT THE HORIZONTAL JOINT OF THE CAST-IN-PLACE MANHOLES.	_  (
	100% PASSING 1" SCREEN 90–100% PASSING 3/4" SCREEN 20–55% PASSING 3/8" SCREEN 0–10% PASSING #4 SIEVE 0–5% PASSING #8 SIEVE	
17.	FLEXIBLE JOINT: A FLEXIBLE JOINT SHALL BE PROVIDED WIDHIN THE FOLLOWING DISTANCES FROM ANY	INS
10	INCHES FOR PVC PIPE LARGER THAN 15" DIAMETER.	FIL
18.	NO FLEXIBLE JOINT SHALL BE REQUIRED FOR DUCTILE IRON PIPE OR PVC PIPE UP THROUGH TS-INCH DIAMETER.	
19. 20	INTERNAL STEPS ARE PROHIBITED PER CITY OF PORTSMOUTH DPW STANDARDS.	
20.	PIPE TO MANHOLE JOINTS SHALL BE ONLY AS FOLLOWS:	
	A. ELASTOMERIC, RUBBER SLEEVE WITH WATERTIGHT JOINTS AT THE MANHOLE OPENING AND PIPE SURFACES.	
	B. CAST INTO WALL OR SECUREED WITH STAINLESS STEEL CLAMPS.	
	C. ELASTOMERIC SEALING RING CAST IN THE MANHOLE OPENING WITH THE SEAL FORMED ON THE SURFACE OF THE PIPE BY COMPRESSION OF THE RING.	
	D. NON–SHRINK GROUTED JOINTS WHERE WATERTIGHT BONDING TO THE MANHOLE AND PIPE CAN BE OBTAINED.	
22.	THE INVERT OF THE INCOMING PIPE SHALL BE NO MORE THAN 6 INCHES ABOVE THE OUTGOING PIPE UNLESS A DROP ENTRY IS USED.	
Cc 48	pyright 2022 ©TFMoran, Inc. Constitution Drive, Bedford, N.H. 03110	
All du wit	rights reserved. These plans and materials may not be copied, uplicated, replicated or otherwise reproduced in any form whatsoever thout the prior written permission of TFMoran, Inc.	
Th TF	is plan is not effective unless signed by a duly authorized officer of Moran, Inc.	







### LANDSCAPE GUARANTEE AND MAINTENANCE NOTES

- 1. CONTRACTOR WILL BE RESPONSIBLE FOR ALL MEANS, METHODS AND TECHNIQUES OF WATERING.
- 2. CONTRACTOR WILL BEGIN WATERING IMMEDIATELY AFTER PLANTING. ALL PLANTS WILL BE THOROUGHLY WATERED TWICE DURING THE FIRST 24 HOUR PERIOD AFTER PLANTING. ALL PLANTS WILL BE WATERED WEEKLY, OR MORE OFTEN, IF NECESSARY DURING THE FIRST GROWING SEASON BUT NOT LESS THAN ONE YEAR.
- 3. WATER ALL LAWNS AS REQUIRED. DO NOT LET NEWLY PLANTED LAWNS DRY OUT DURING THE FIRST FOUR WEEKS MINIMUM.
- 4. ALL NEW LAWNS WILL BE MAINTAINED AND MOWED A MINIMUM THREE (3) TIMES BEFORE REQUESTING REVIEW BY LANDSCAPE ARCHITECT OR OWNER'S REPRESENTATIVE FOR ACCEPTANCE. MAINTENANCE AND MOWING WILL CONTINUE UNTIL ACCEPTED BY LANDSCAPE ARCHITECT OR OWNERS' REPRESENTATIVE IS ISSUED IN WRITING.
- 5. THE CONTRACTOR WILL MAINTAIN AND GUARANTEE ALL PLANTINGS TO BE IN GOOD HEALTHY, FLOURISHING AND ACCEPTABLE CONDITION FOR A PERIOD OF ONE (1) YEAR BEGINNING AT THE DATE OF ACCEPTANCE BY THE LANDSCAPE ARCHITECT OR OWNER'S REPRESENTATIVE. ALL GRASSES, TREES AND SHRUBS THAT, IN THE OPINION OF THE LANDSCAPE ARCHITECT OR OWNER'S REPRESENTATIVE SHOWING LESS THAN 80% HEALTHY GROWTH AT THE END OF ONE (1) YEAR PERIOD WILL BE IMMEDIATELY REPLACED BY THE CONTRACTOR.
- 7. ALL DAY LILIES WILL BE DEADHEADED AND CUT BACK EVERY FALL. ALL ORNAMENTAL GRASSES WILL BE CUT BACK EVERY FALL OR EARLY SPRING.
- B. DECIDUOUS PLANT MATERIAL INSTALLED AFTER SEPTEMBER 30 AND BEFORE APRIL 15 WILL NOT BE REVIEWED THAT SEASON FOR ACCEPTANCE DUE TO STAGE OF LEAF PHYSIOLOGY. THIS PLANT MATERIAL WILL NOT BE REVIEWED UNTIL FOLLOWING GROWING SEASON. GUARANTEE PERIOD WILL BEGIN ONLY AFTER ACCEPTANCE BY LANDSCAPE ARCHITECT OR OWNERS' REPRESENTATIVE.
- 9. EVERGREEN PLANT MATERIAL INSTALLED AFTER OCTOBER 30 AND BEFORE APRIL 15 WILL NOT BE REVIEWED THAT SEASON FOR ACCEPTANCE DUE TO END OF GROWTH SEASON. THIS PLANT MATERIAL WILL NOT BE REVIEWED UNTIL FOLLOWING GROWING SEASON. GUARANTEE PERIOD WILL BEGIN ONLY AFTER ACCEPTANCE BY LANDSCAPE ARCHITECT OR OWNERS' REPRESENTATIVE.

### HYDROSEEDING NOTES

- 1. HYDROSEEDING MAY BE USED AS AN ALTERNATE METHOD OF SEEDING. THE APPLICATION OF LIMESTONE AS NECESSARY, FERTILIZER AND GRASS SEED MAY BE ACCOMPLISHED IN ONE OPERATION BY THE USE OF A SPRAYING MACHINE APPROVED BY THE LANDSCAPE ARCHITECT OR CIVIL ENGINEER. THE MATERIALS SHALL BE MIXED WITH WATER IN THE MACHINE AND SHALL CONFORM TO RELATIVE REQUIREMENTS OF SECTION 644 OF NH. STANDARD SPECIFICATIONS FOR ROAD AND BRIDGE CONSTRUCTION.
- 2. (FOR MASSACHUSETTS PROJECTS PLUG IN SECTION 765.65 OF MASS. DPW CURRENT STANDARD SPECIFICATIONS FOR HIGHWAYS AND BRIDGES).

### **INVASIVE PLANT NOTES**

1. EXISTING NON-NATIVE, INVASIVE PLANT SPECIES WILL BE IDENTIFIED, REMOVED, DESTROYED AND LEGALLY DISPOSED OF OFF-SITE IN ACCORDANCE WITH THE LATEST UNIVERSITY OF NEW HAMPSHIRE COOPERATIVE EXTENSION METHODS OF DISPOSING NON-NATIVE INVASIVE PLANTS. SEE "MANAGE AND CONTROL INVASIVES" AND PROPERLY DISPOSE OF INVASIVE PLANTS".

### **PRICING & CONSTRUCTION DOCUMENT NOTES**

- 1. CONTRACTOR WILL PRICE PLANT MATERIAL IN QUANTITIES SUFFICIENT TO COMPLETE PLANTINGS GRAPHICALLY SHOWN ON THESE DRAWINGS OR IN PLANT LIST, WHICHEVER IS GREATER. IN CASES OF DISCREPANCY BETWEEN PLAN AND LIST CLARIFY WITH LANDSCAPE ARCHITECT PRIOR TO PLACING PURCHASE ORDER AND AGAIN PRIOR TO PLANTING.
- 2. CONTRACTOR WILL VERIFY PRIOR TO PRICING IF SITE SOILS ARE VERY POORLY DRAINING OR IF LEDGE IS PRESENT. IF CONTRACTOR ENCOUNTERS VERY POORLY DRAINING SOILS (BATH TUB EFFECT) OR LEDGE THAT IMPACTS PROPOSED PLANTING PLAN, NOTIFY LANDSCAPE ARCHITECT OR OWNERS' REPRESENTATIVE FOR DIRECTION PRIOR TO PRICING AND AGAIN PRIOR TO PERFORMING ANY WORK.
- 3. PARKING AREA PLANTED ISLANDS WILL HAVE MINIMUM OF 1'-0" TOPSOIL PLACED TO THE TOP OF CURB ELEVATION. REMOVE ALL CONSTRUCTION DEBRIS BEFORE PLACING TOPSOIL.
- 4. EXISTING TREES SHOWN ON THE PLAN WILL REMAIN UNDISTURBED. ALL EXISTING TREES SHOWN TO REMAIN WILL BE PROTECTED WITH A 4-FOOT SNOW FENCE PLACED AT THE DRIP LINE OF THE BRANCHES OR AT 8 FEET MINIMUM FROM THE TREE TRUNK.
- 5. CONTRACTOR WILL STAKE OR PLACE ON GROUND ALL PROPOSED PLANT MATERIALS PER PLAN. CONTACT LANDSCAPE ARCHITECT FOR REVIEW AND APPROVAL PRIOR TO INSTALLATION.
- 6. COORDINATE WITH LANDSCAPE ARCHITECT'S CONTRACTED NUMBER OF SITE VISITS WHEN PLANNING FOR INSPECTION. NOTIFY LANDSCAPE ARCHITECT 72 HOURS MINIMUM IN ADVANCE OF REQUESTED SITE VISIT.
- 7. CONTRACTOR WILL DEVELOP A WRITTEN WATERING SCHEDULE AND WILL SUBMIT WATERING SCHEDULE TO OWNERS' REPRESENTATIVE. CONTRACTOR WILL WATER ALL NEW PLANTS INCLUDING LAWNS THAT ARE NOT "IRRIGATED" VIA A PERMANENT IRRIGATION SYSTEM FOR THE FIRST 12 MONTHS.

### PORTSMOUTH NOTES

- 1. THE PROPERTY OWNER AND ALL FUTURE PROPERTY OWNER'S WILL BE RESPONSIBLE FOR THE MAINTENANCE AND OF ALL REQUIRED SCREENING AND LANDSCAPE MATERIALS INDICATED ON THESE PLAN(S).
- 2. ALL REQUIRED PLANT MATERIAL WILL BE TENDED TO AND KEPT FREE OF REFUSE AND DEBRIS.
- 3. ALL REQUIRED FENCES AND WALLS WILL BE MAINTAINED IN GOOD REPAIR.
- THE PROPERTY OWNER WILL BE RESPONSIBLE TO REMOVE AND REPLACE DEAD OR DISEASED PLANT MATERIALS IMMEDIATELY WITH THE SAME TYPE, SIZE AND QUANTITY OF PLANT MATERIALS AS ORIGINALLY INSTALLED, UNLESS ALTERNATIVE PLANTINGS ARE REQUESTED, JUSTIFIED AND APPROVED BY THE PLANNING BOARD OR PLANNING DIRECTOR.
- 5. ALL IMPROVEMENTS SHOWN ON THIS PLAN WILL BE CONSTRUCTED AND MAINTAINED IN ACCORDANCE WITH THIS PLAN BY THE PROPERTY OWNER AND ALL FUTURE PROPERTY OWNERS. NO CHANGES WILL BE MADE TO THIS PLAN WITHOUT THE WRITTEN APPROVAL OF THE PORTSMOUTH PLANNING BOARD OR PLANNING DIRECTOR.
- 7. THE LANDSCAPE PLAN WILL BE RECORDED IN THE ROCKINGHAM COUNTY REGISTRY OF DEEDS.
- 8. MAINTENANCE OF LANDSCAPING TO FOLLOW THE NOFA STANDARDS FOR ORGANIC LAND CARE 6TH EDITION PRACTICES FOR THE DESIGN AND MAINTENANCE OF ECOLOGICAL LANDSCAPES. ("NOFA STANDARDS FOR ORGANIC LAND CARE." NOFA STANDARDS FOR ORGANIC LAND CARE 6TH EDITION PRACTICES FOR THE DESIGN AND MAINTENANCE OF ECOLOGICAL LANDSCAPES, NORTHEAST ORGANIC FARMING ASSOCIATION OF CONNECTICUT, INC, 2017, HTTP://WWW.ORGANICLANDCARE.NET/SITES/DEFAULT/FILES/NOFA\_ORGANIC\_LAND\_CARE\_STANDARDS\_6THEDITION\_2017\_OPT.PDF.)

#### SEEDING NOTES

- 1. SLOPES UP TO AND INCLUDING 3:1 GRADE, SEED WILL BE NEW ENGLAND EROSION CONTROL & RESTORATION MIX PER NEW ENGLAND WETLANDS PLANTS INC., AMHERST, MA.
- 2. SLOPES STEEPER THAN 3:1 GRADE, SEED WILL BE NEW ENGLAND EROSION CONTROL & RESTORATION MIX PER NEW ENGLAND WETLANDS PLANTS INC., AMHERST, MA. SEE CIVIL FOR ADDITIONAL EROSION CONTROL MEASURES.
- 3. GENERAL SEED WILL BE NHDOT SPECIFICATION SECTION 644, TABLE 644-1-PARK SEED TYPE 15, INCLUDING NOTES TO TABLE 1, 2 & 3.

Copyright 2022 ©TFMoran, Inc. 48 Constitution Drive, Bedford, N.H. 03110

All rights reserved. These plans and materials may not be copied, duplicated, replicated or otherwise reproduced in any form whatsoever without the prior written permission of TFMoran, Inc.

This plan is not effective unless signed by a duly authorized officer of FMoran, Inc.





# SHRUB PLANTING





NOTES:

1. A 10 FOOT MINIMUM EDGE TO EDGE HORIZONTAL SEPARATION SHALL BE PROVIDED BETWEEN ALL WATER AND SANITARY SEWER LINES. AN 18" MINIMUM OUTSIDE TO OUTSIDE VERTICAL SEPARATION SHALL BE PROVIDED AT ALL WATER AND SANITARY SEWER CROSSINGS.

2. PROTECTION OF WATER SUPPLIES:

A. THERE SHALL BE NO PHYSICAL CONNECTION BETWEEN A PUBLIC OR PRIVATE POTABLE WATER SUPPLY SYSTEM AND A SEWER OR SEWER APPURTENANCE WHICH WOULD PERMIT THE PASSAGE OF SEWAGE OR POLLUTED WATER INTO THE POTABLE SUPPLY. NO WATER PIPE SHALL PASS THROUGH OR COME IN CONTACT WITH ANY PART OF A SEWER OR SEWER MANHOLE

B. NO SEWER SHALL BE LOCATED WITHIN THE WELL PROTECTED RADII ESTABLISHED IN ENV-WS 300 FOR ANY PUBLIC WATER SUPPLY WELLS OR WITHIN 100 FEET OF ANY PRIVATE WATER SUPPLY WELL.

C. SEWERS SHALL BE LOCATED AT LEAST 10 FEET HORIZONTALLY FROM ANY EXISTING OR PROPOSED WATER MAIN.

D. A DEVIATION FROM THE SEPARATION REQUIREMENTS OF (B) OR (C) ABOVE SHALL BE ALLOWED WHERE NECESSARY TO AVOID CONFLICT WITH SUBSURFACE STRUCTURES, UTILITY CHAMBERS, AND BUILDING FOUNDATIONS, PROVIDED THAT THE SEWER IS CONSTRUCTED IN ACCORDANCE WITH THE FORCE MAIN CONSTRUCTION REQUIREMENTS SPECIFIED IN ENV-WQ 704.06.

E. WHENEVER SEWERS MUST CROSS WATER MAINS, THE SEWER SHALL BE CONSTRUCTED AS FOLLOWS:

a. VERTICAL SEPARATION OF THE SEWER AND WATER MAIN SHALL BE NOT LESS THAN 18 INCHES, WITH WATER ABOVE SEWER AND

b. SEWER PIPE JOINTS SHALL BE LOCATED AT LEAST 6 FEET HORIZONTALLY FROM THE WATER MAIN.

# WATER & SEWER CROSSING

NOT TO SCALE



# SITE DEVELOPMENT PLANS

TAX MAP 229 LOT 1 DETAILS

# **PROPOSED 3 LOT SUBDIVISION 437 LAFAYETTE ROAD** PORTSMOUTH, NEW HAMPSHIRE

OWNED BY & PREPARE FOR **ARTWILL, LLC** 

SCALE:

**APRIL** 19, 2022



ivil Engineers tructural Engineers raffic Engineers \_and Surveyors \_andscape Architects cientists

45407-120\_DETAILS

C-15

48 Constitution Drive

Bedford, NH 03110

Fax (603) 472-9747

www.tfmoran.com

Phone (603) 472-4488