



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 1
5 Post Office Square, Suite 100
Boston, MA 02109-3912

CERTIFIED MAIL, RETURN RECEIPT REQUESTED

APR 18 2017

Suzanne Woodland, Esq.
Deputy City Attorney
City of Portsmouth
1 Junkins Avenue
Portsmouth, NH 03801

Re: City of Portsmouth, New Hampshire - Consent Decree 09-cv-283-PB ("CD")

Dear Attorney Woodland:

The U.S. Environmental Protection Agency ("EPA") has received and reviewed the November 2016 *City of Portsmouth, New Hampshire Final CSO Post-Construction Monitoring Plan/Report*, prepared by Hazen. EPA is providing written comments in Attachment A to this letter.

Portsmouth's early sewer separation projects resulted in a 60% reduction of the wastewater collection system served by combined sewers and the elimination of 11 of the City's 14 original combined sewer overflow ("CSO") outfalls. The City's Phase 1 sewer separation projects completed under the 2009 CD further reduced the remaining combined sewer area by another two-thirds to about 20% of the total service area. After completion of the Phase 1 CSO abatement projects under the CD, the City's CSO discharge monitoring documents significant reductions in the volume of untreated CSO discharges from its remaining CSOs to South Mill Pond (outfalls 010A and 010B) and the Piscataqua River (outfall 013), down from approximately 13 million gallons to approximately 3.5 million gallons per year. Although the CSO discharge volumes and frequencies have been greatly reduced, post-construction monitoring also documents that CSO discharges continue to occur and indicates that Portsmouth has not achieved full compliance with the Clean Water Act ("CWA"), EPA's CSO Policy, and all applicable federal and state regulations and permits; hence, additional CSO abatement is needed.

We are aware that the City is preparing to implement projects listed in its Capital Improvements Plan ("CIP") to remove infiltration and inflow in the wastewater collection system to further reduce CSO discharge volume and frequency. The CIP projects include Union Street and Pleasant Street sewer reconstruction, annual sewer replacement projects and additional CSO long-term control plan projects.

Pursuant to Section IV, paragraph 12.c. of the CD, **within 60 days of receipt of this letter**, please submit to EPA a Supplemental Compliance Plan for Phase 2 CSO abatement activities including a proposed implementation schedule to achieve full compliance with the CWA, EPA's CSO Policy, and all applicable federal and state regulations and permits.

If you have any questions, please contact Tonia Bandrowicz at (617) 918-1734 or have the City's technical staff contact Joy Hilton at (617) 918-1877.

Sincerely,



Susan Studien, Director
Office of Environmental Stewardship

APR 18 2017

Attachment

cc: Mark Pollins, Director of Water Enforcement, USEPA
Joy Hilton, USEPA Region 1
Tracy L. Wood, NHDES, Wastewater Engineering Bureau Administrator
Allen Brooks, Esq., Department of Justice, Environmental Protection Bureau
Chief
Tonia Bandrowicz, Senior Enforcement Counsel, USEPA Region 1
David Gordon, Esq., US Department of Justice
Tom Irwin, Esq., Conservation Law Foundation
John P. Bohenko, City Manager
Brian Goetz, Deputy Director of Public Works
Nancy Colbert-Puff, Deputy City Manager
Terry Desmarais, City Engineer, Portsmouth

ATTACHMENT A

COMMENTS on the Portsmouth, NH Final Post-Construction Monitoring Plan/Report

1. In Table ES-1, Portsmouth summarizes its predicted CSO activation volumes in the 5 years previously selected to represent system “average” performance – these years are 1968, 1988, 1989, 1990, and 1993. That table notes a total five-year volume for the South Pond CSOs (10A and 10B) of 5.67 MG, and a total volume of 0.53 MG for CSO 013. Portsmouth notes that the 10A/10B average is therefore 1.1 MG/year for the five years, which is less than the 2010 Report prediction of an average of 2.1 MG per year. Portsmouth also states that the average of 0.1 per year for CSO 013 is really 0 because the one event in those five years occurred during a storm having approximately a 5-year return frequency. Portsmouth’s second assertion is inappropriate, as the CSO 013 prediction was presented as 0, not <1 or as 0.1.
2. In Section 1, Portsmouth notes that it has carried out “flow/water quality monitoring” in developing and implementing its LTCP. As noted above and as discussed below in Comment #13 water quality monitoring results are not presented in this report.
3. In Table 2 in Section 1.1, the City lists seven LTCP separation projects and their completion dates. Completion date is listed simply by year, with the last area (Aldrich) completed in 2015. The City should provide month as well as year of completion for each area – most particularly for the Aldrich Area, as it was completed in the same year (2015) as post construction monitoring was carried out.
4. Section 1.1 provides a description of each separation area and Figures 2 through 6 provide maps of those areas. The City should clearly cross reference the currently used area names with the Planning Area names used in the 2009 Consent Decree and the First Modification of the Decree. It appears that Court/State is the current State Street Area, and Cass and Aldrich appear to be Islington #1 and #2 respectively. The City should confirm these assumptions in the report. Also, there is an inconsistency in the completion date listed for the Cass Area in Table 2 (2013) and Section 1.1.1 (2014); the City should identify the actual date.
5. In Section 1.1, the City should discuss whether and in what ways the scopes of these projects changed between their inclusion in the 2009 Consent Decree and actual project completion.
6. Section 1.2 states that the overall goal of the PCMP/R “is to provide a framework for assessing the performance of collection system infrastructure improvements implemented through 2015. The Consent Decree requires this PCMP to address three objectives:

“determine: i) whether the LTCP measures, when completed, meet all design

criteria and performance criteria specified in the LTCP; ii) whether the Combined Sewer Overflow Facility, and the WWTFs with respect to the treatment of combined sewage, comply with the technology-based and water quality-based requirements of the CWA, the CSO Policy, and all applicable federal and state regulations and permits; and iii) that there are no CSO Discharges.”

The City’s statement acknowledges that the Plan/Report only addresses the first of those three requirements. The second and third of those requirements could be satisfied when Portsmouth submits to EPA a Supplemental Compliance Plan for Phase 2 CSO abatement including a proposed implementation schedule within 60 days of receipt of this letter.

7. The City presents a list of temporary and permanent meters in Table 6 (these appear to be the PCMP meters), as well as a map of metering locations in Figure 7 that includes earlier I/I metering locations as well as the PCMP meter locations. In Appendices C and D, the City presents comparative hydrographs of various meter locations for dry and wet weather conditions, respectively. A number of the meter designations presented in the appendices do not correspond to those in the table and figure. The City should use consistent meter designations throughout the report.
8. The report does not discuss the quality and limitations of the rainfall and flow data collected during its brief 12-week post construction monitoring program that occurred in April, May and June of 2015.
9. In Section 2.3 the City notes that CSO activation data, based upon the CSO’s permanent flow meters was used for model verification; however, the report does not provide the results of that verification or discuss the number of activations experienced by each CSO since the separation projects have been completed. The report should present a listing of each such activation, including date, associated storm characteristics (rainfall total, peak intensity, and event duration), discharge volume and duration.
10. Section 3 of the report describes the City’s use of its hydraulic model to evaluate the “typical year(s)” performance of its collection system. As noted above, the report provides comparative hydrographs for meter sites under dry weather conditions (i.e., during selected dry periods) as well as for the entire monitoring period (characterized as wet weather conditions). As such, the report fails to provide adequate documentation of the degree of calibration achieved – particularly under wet weather conditions – which are the most critical conditions for combined system performance.
11. The report should include the following information in Section 3 and/or in related appendices:
 - a. Model input parameters pre- and post- recalibration. These should be provided on a catchment basis, and should include catchment areas, RTK factors, D factors (if utilized; however, the report does not discuss their use and so it is assumed they were not employed to adjust R based on initial

abstraction use and recovery), as well as groundwater model parameters such as soil porosity, wilting point, field capacity, saturated conductivity, soil tension, etc. The City should also provide a comparison of all final values to generally recommended ranges of those values, to demonstrate that none have been adjusted outside what are generally considered to be “reasonable” ranges.

- b. A much more detailed evaluation of model calibration. The report provides a model-to-meter comparison for the individual meters in Table 8 (note: the report incorrectly references Table 7). This comparison is for the total dry and wet weather flow volume at each location over the 12-week monitoring period. Not surprisingly, the percent differences at most locations are low. This is most likely because the comparison is dominated by dry weather flow, which typically is more closely calibrated in a collection system model. The City cites industry calibration standards; however, wet weather standards should be applied on an individual wet weather event-basis, as well as to wet weather overall. In addition, peak flow rate and depth of flow are also used as calibration criteria. In a system that relies on flow reduction via separation and conveyance and treatment to address its CSOs, peak flow is an important calibration criterion.
 - c. In presenting the above additional statistics, the City should use additional tabular summaries, as well as more detailed event-specific hydrographs and what are known as “45 degree” scatter plots. The latter plot, plot the model value on one axis and the meter value on the other. A perfect match lands on a 45-degree line on the plot.
 - d. As noted above, the City should also provide a comparison of the model’s prediction of CSOs during the monitored events to those measured by the permanent CSO meters.
12. The City notes in Section 1 that among its CSO control efforts it has carried out water quality monitoring. If any such monitoring has been carried out post-construction, the results should be presented herein. If not, an appropriate program of water quality monitoring should be carried out, and its results used to evaluate the degree to which the second CD-stated objective has been satisfied. An appropriate water quality monitoring program would be expected to include bacteria (fecal coliform or E. coli), nitrogen species, phosphorus, and dissolved oxygen. If non-compliance with water quality standards and/or non-attainment of designated uses is identified, use of a water quality model to evaluate the City’s contribution to such non-compliance and non-attainment may be appropriate. This activity could be included in the City’s Supplemental Compliance Plan for Phase 2 CSO abatement including a proposed implementation schedule that is to be submitted within 60 days of receipt of this letter.

