

**ADDENDUM NO. 4**  
**September 19, 2023**

**CORPORATE DRIVE RECONSTRUCTION  
PORTSMOUTH, NEW HAMPSHIRE**

The following changes and information are hereby incorporated into the Contract Documents (Project Manual and Drawings).

**GENERAL**

Additional questions received after Addendum No.3:

Q1: Is the existing granite curb set in concrete?

A1: *This information is not known.*

Q2: If there is concrete on the face of the existing granite curb, to what extent will the City require us to remove/sandblast off the concrete?

A2: *From Question 1 above, it is not known if the existing granite curb is set in concrete. However, salvaged granite curb incorporated into the work shall be reasonably clean, square and uniform. Exposed curb (i.e. reveal) shall be free of concrete and/or other surface irregularities.*

**PROJECT MANUAL**

**1. Advertisement for Bids (A-1.1)**

**Change** the bid opening from September 21, 2023 at 2:00 PM to September 22, 2023 at 9:00 AM in the first sentence of the first paragraph on page A-1.1 as follows:

“Separate sealed BIDS for the construction of **Corporate Drive Reconstruction** will be received at the **City of Portsmouth Purchasing Department, City Hall, 1 Junkins Avenue, Portsmouth, NH 03801**, until **9:00 AM** ~~2:00 p.m.~~ local time on **September 22 21, 2023**. BIDS will then be publicly opened and read aloud at said office and time. The Project includes, but is not limited to, drainage, roadway, sidewalk, and stormwater improvements along 6,600 linear feet of Corporate Drive from the vicinity of Goose Bay Drive to Grafton Road.”

**2. Bid Schedule (A-3.13)**

The Bid Schedule provided as Attachment “C” in Addendum #2 does not provide a value for the allowance under Item 912 R&R Landscaping. Item 912 R&R Landscaping is **Modified** to provide a \$10,000 allowance as shown below:

912	1	Allow	R&R Landscaping: <u>Ten Thousand</u> Dollars and <u>Zero</u> Cents per	Allow	<b>\$10,000</b>	<b>\$10,000</b> / Allow
-----	---	-------	---	-------	-----------------	----------------------------

**Delete** Page A-3.13 from the Bid Schedule provided in Addendum #2 and **Replace** with the new Page A-3.13 (Attachment A)

**ATTACHMENTS**

A- Bid Schedule (A-3.13) (1 Page)

UNDERWOOD ENGINEERS, INC.



Benjamin T. Dreyer, P.E.  
Senior Project Manager

CONTRACTOR'S BID SCHEDULE

Item No.	Est. Quantity	Units	Item Description (and Unit Price written in words)		Unit Price	Amount
632.0112	300	LF	Retroflective Paint Pavement Marking, 12" Line _____ Dollars and _____ Cents per	LF	/ LF	
632.3112	300	LF	Retroflective Thermoplastic Pavement Marking, 12" Line _____ Dollars and _____ Cents per	LF	/ LF	
632.32	80	SF	Retroflective Thermoplastic Pavement Marking, Symol or Word _____ Dollars and _____ Cents per	SF	/ SF	
646.512	8,700	SY	Turf Establishment w. Mulch, Tackifiers and Loam (F): _____ Dollars and _____ Cents per	SY	/ SY	
912	1	Allow	R&R Landscaping: <i>Ten Thousand</i> Dollars and <i>Zero</i> Cents per	Allow	<b>\$10,000</b> / Allow	<b>\$10,000</b>
<b>TOTAL SCHEDULE 2</b>						