

ADDENDUM NUMBER 1:
Mechanic Street Pump Station Esthetic Improvements Bid Proposal #30-13

Issued: April 15, 2013

This Addendum forms part of the original document marked: **Mechanic Street Pump Station Esthetic Improvements Bid Proposal #30-13**

A. Bidding Requirements:

1. **The bid due date has been changed to Friday, April 19, 2013 @ 2:00p.m.** This extended due date will allow additional time for bidders to review and modify their proposal forms based on the bid package modifications listed below.

B. Bidder's Questions - The following questions have been asked and answered.

Question #1 Is it the responsibility of the contractor to have the new parapet screen wall engineered and show engineering calculations to prove the structure is strong enough wind and cantilever strength? The specs only tell us how to attach to the roof. The fastening and cantilevering of the wall is not detailed.

Answer #1 It is the responsibility of the contractor to have engineering calculations demonstrating the parapet structure meets required loadings, stresses, and strengths per state and local codes. The specifications and drawing indicate the manner in which the parapet should be fastened to the roof, but alternate methods may be suggested providing they meet the aforementioned requirements.

Question #2 Are the unit prices listed on the bid sheet to be included in the base bid or not and just considered for an ADD? Obviously the deduct is to be included in the base bid.

Answer #2 Both the Alternate (Bid Alternate #1) and the Unit Pricing costs are to be separate from the Base Bid and used for reference purposes. If the City chooses to implement the Alternate or Unit Pricing costs the Base Bid will be adjusted accordingly.

C. Bid Documents - The following items supersede the associated original sections:

- **DELETED - SECTION 027800 – BELGIAN BLOCK UNIT PAVING**
No Belgian Block Curbing will be installed as part of this project. Granite Curbing will remain in its existing location, in its entirety for the project site.
- Remove asphalt pavement walkway from existing door along Mechanic Street, to the corner of the walkway adjacent to the electric meter. The removal of this asphalt will allow for the specified lattice work and plantings to be placed adjacent to the building face.

All else remains unchanged from original bid document.

Please acknowledge receipt of this addendum within your proposal, failure to do so may subject a bidder to disqualification.

End of Addendum #1