

CITY OF PORTSMOUTH  
Public Works Department

RFP #33-23

Under Bridge Lighting

February 27, 2023

**ADDENDUM #1**

Question:

1. Will the City allow exposed conduit to be installed above the travel lanes at these sites as opposed to cutting and repaving to cross both Woodbury and Maplewood?

**Answer: No, the conduit needs to be run underground.**

**Please acknowledge this addendum, in writing, within your proposal. Failure to do so may subject a bidder to disqualification.**