

CITY OF PORTSMOUTH
Department of Public works

Bid # 58-23 City Hall Signage and Lobby Renovations

ADDENDUM 3

Please note the following change in Addendum 2:

SECTION 211000 - WATER-BASED FIRE-SUPPRESSION SYSTEMS

PART 1 - GENERAL

1.1 SECTION REQUIREMENTS, Article B. Work Conditions.

Delete paragraph 1 and replace with:

1. Shutdown of the building fire suppression system required for this work will be done during normal business hours and not exceed 10 hours a day.
2. Contractor will shut down system when needed and return the system to operational at the end of each day.
3. The City will provide fire watch during this time.

Bidder will acknowledge this addendum within your proposal. Failure to do so may subject bidder to disqualification.

End of Addendum 3