

City of Portsmouth
Portsmouth, New Hampshire
Community Development Department

BID #01-23
City Hall Masonry Repairs

ADDENDUM #1
August 10, 2022

This addendum forms part of the specifications and modifies the original documents, marked Bid #25-04 as specified below.

PROPOSALFORM

Delete Proposal Form and Replace with Proposal Form Revised 08 10 2022 attached.

TECHNICAL SPECIFICATIONS

SECTION 04 01 05 - MASONRY RESTORATION AND CLEANING

Clarification: A restoration cleaning and final cleaning are specified.

2.2 COMPONENTS- EXTERIOR RESTORATION AND CLEANING

Add to Paragraph E 1-3:

4. Bidder will base bid on Type O mortar and will test mortar for strength.

SECTION 042000 UNIT MASONRY

2.3 MORTAR AND GROUT

Delete Paragraph A.3 and replace with-

3. For exterior, above-grade, load-bearing and nonload-bearing walls and parapet walls; for other applications, use Type O.

DRAWINGS

Delete Attachment 1 and replace with revised drawing dated August 10, 2022 attached.

Please acknowledge this addendum, in writing, within your proposal. Failure to do so may subject a bidder to disqualification.